


APPENDIX A

PRELIMINARY SITE PLAN

SITE PLAN



-  1. STADIUM
-  2. PARK SPACE
-  3. SDSU CAMPUS EXPANSION
-  4. HOTEL & CONFERENCE CENTER
-  5. TAILGATE PARK
-  6. RESIDENTIAL

APPENDIX B

LAND USE BREAKDOWN

**SDSU MISSION VALLEY PROJECT
AVERAGE POTABLE WATER DEMAND**


Area	Net Area, ft2	Net Area, ac	Dwelling Units	Dwelling Unit Density, DU/ac	Unit Density, Pop./DU	Total Population	Average Water Demand, gpd
Campus						<i>Stories</i>	
A1	28084	0.64	--	--	--	5	15,086
A2	20064	0.46	--	--	--	3	6,467
A3	27720	0.64	--	--	--	3	8,935
A4	28084	0.64	--	--	--	4	12,069
B1	28084	0.64	--	--	--	5	15,086
B2	20064	0.46	--	--	--	3	6,467
B3	16720	0.38	--	--	--	3	5,389
C1	16720	0.38	--	--	--	3	5,389
C2	28084	0.64	--	--	--	3	9,052
C3	23718	0.54	--	--	--	5	12,741
D1	27720	0.64	--	--	--	3	8,935
D2	22880	0.53	--	--	--	3	7,375
D3	33630	0.77	--	--	--	3	10,839
D4	28084	0.64	--	--	--	4	12,069
E1	30090	0.69	--	--	--	5	16,164
F1	30090	0.69	--	--	--	5	16,164
Sub-Total	409836.0	9.4					168,012
Residential							
R1	118102	2.7	302	111	1.8	544	81,540
R2	81911	1.9	353	188	1.6	565	84,720
R3	77895	1.8	356	199	1.5	534	80,100
R4	47483	1.1	29	27	3.0	87	13,050
R5	76000	1.7	313	179	1.6	501	75,120
R6	76000	1.7	488	280	1.5	732	109,800
R7	82930	1.9	485	255	1.5	728	109,125
R8	101102	2.3	347	150	1.7	590	88,485
R9	32351	0.7	40	54	2.5	100	15,000
R10	75573	1.7	319	184	1.6	510	76,560
R11	76000	1.7	465	267	1.5	698	104,625
R12	81240	1.9	209	112	1.8	376	56,430
R13	67288	1.5	311	201	1.5	467	69,975
R14	52295	1.2	260	217	1.5	390	58,500
R15	57935	1.3	261	196	1.6	418	62,640
H1 Res	108518	2.5	71	28	3.0	213	31,950
Sub-Total	1212623	1.7	4609	165	1.7	7451	1,117,650
Hotel							
H1	173934	4.0	255				26,174
H2	63644	1.5	145				9,577
Sub-Total		5.5					36,053
Parks							
SDSU Parks	1350360	31.0					124,000
Stadium							
SDSU Stadium	NA	NA	35000				140,000
Retail	95000	2.2					11,000
TOTAL							1,596,715

APPENDIX C

PEAKING FACTOR GRAPHS


PEAKING FACTOR ZONES
(BOUNDARIES BASED ON LAND USE GROUPINGS)


FIGURE 2-3



July 1999

FIGURE 2-2
MAXIMUM DAY DEMAND FACTOR





APPENDIX D

**EMAIL CORRESPONDENCE
AND
MANUFACTURER LITERATURE
FOR FIRE-SERVICE TYPE WATER METERS**

Fernando Fregoso

From: Andrew Oven
Sent: Thursday, March 28, 2019 4:19 PM
To: Fernando Fregoso
Subject: FW: SDSU Mission Valley - 8" Domestic Meters

Fernando,

Let me know how this impacts our thinking about meter numbers and sizes.

Andrew Oven, P.E.
Dexter Wilson Engineering, Inc.
(760) 438-4422

From: Wilson, Leonard <LLWilson@sandiego.gov>
Sent: Thursday, March 28, 2019 2:34 PM
To: Andrew Oven <Andrew@dwilsoneng.com>
Subject: RE: SDSU Mission Valley - 8" Domestic Meters

Andrew,

I confirmed with Lorraine Gain and the meter shop will allow the Badger Recordall Fire Series Assembly (FSAA) meters. The following is the cut sheet web-link:

<https://www.badgermeter.com/resources/2504a38c-75e0-4921-b26e-7cfcdd4d67bd/recordall%20fire%20series%20assembly%20with%20turbine%20bypass%20sizes%204%206%208%2010%2012%20inch%20product%20data%20sheet%20fsa-ds-00703-en.pdf/>

The meter shop will allow all sizes of FSAA Models (4-inch through 12-inch). The subject meters meet AWWA Standard C703. Allow 3 months for the meter shop to order the meter and for Badger to deliver it.

Let me know if you have any questions.

Thank you,
Leonard

Leonard L. Wilson, P.E.
Senior Civil Engineer
City of San Diego
Development Services Department
Water and Sewer Development Review

T (619) 446-5421
LLWilson@sandiego.gov

Visit SanDiego.gov/DSD to pay invoices, schedule inspections, check project status, request a code enforcement investigation and other online services.

CONFIDENTIAL COMMUNICATION

This electronic mail message and any attachments are intended only for the use of the addressee(s) named above and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you are not an intended recipient, or the employee or agent responsible for delivering this e-mail to the

intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you received this e-mail message in error, please immediately notify the sender by replying to this message or by telephone. Thank you.

From: Andrew Oven <Andrew@dwilsoneng.com>
Sent: Tuesday, March 19, 2019 5:28 PM
To: Wilson, Leonard <LLWilson@sandiego.gov>
Subject: RE: SDSU Mission Valley - 8" Domestic Meters

Leonard,

We checked with Badger; the largest compound meter they have is 6". Are we talking to the wrong people or asking for the wrong type of meter? Can you confirm with the meter shop that they can get an 8" or 10" Badger compound meter?

Thanks.

Andrew Oven, P.E.
Dexter Wilson Engineering, Inc.
(760) 438-4422

From: Wilson, Leonard <LLWilson@sandiego.gov>
Sent: Tuesday, March 19, 2019 10:18 AM
To: Andrew Oven <Andrew@dwilsoneng.com>
Subject: RE: SDSU Mission Valley - 8" Domestic Meters

Andrew,

I'm told by the meter shop that the current large meter contract is with Badger and it would be a compound meter.

Let me know if you have any questions.

Thank you,
Leonard

Leonard L. Wilson, P.E.
Senior Civil Engineer
City of San Diego
Development Services Department
Water and Sewer Development Review

T (619) 446-5421
LLWilson@sandiego.gov

Visit SanDiego.gov/DSD to pay invoices, schedule inspections, check project status, request a code enforcement investigation and other online services.

CONFIDENTIAL COMMUNICATION

This electronic mail message and any attachments are intended only for the use of the addressee(s) named above and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you are not an intended recipient, or the employee or agent responsible for delivering this e-mail to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you received this e-mail message in error, please immediately notify the sender by replying to this message or by telephone. Thank you.

From: Wilson, Leonard
Sent: Monday, March 18, 2019 4:31 PM
To: Andrew Oven <Andrew@dwilsoneng.com>
Subject: RE: SDSU Mission Valley - 8" Domestic Meters

Andrew,

Let me check and I'll get back to you. Lorraine Gain, the meter shop supervisor, is out of the office until March 28th so I'm tracking another person down who can answer your question.

Thank you,
Leonard

Leonard L. Wilson, P.E.
Senior Civil Engineer
City of San Diego
Development Services Department
Water and Sewer Development Review

T (619) 446-5421
LLWilson@saniego.gov

Visit SanDiego.gov/DSD to pay invoices, schedule inspections, check project status, request a code enforcement investigation and other online services.

CONFIDENTIAL COMMUNICATION

This electronic mail message and any attachments are intended only for the use of the addressee(s) named above and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you are not an intended recipient, or the employee or agent responsible for delivering this e-mail to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you received this e-mail message in error, please immediately notify the sender by replying to this message or by telephone. Thank you.

From: Andrew Oven <Andrew@dwilsoneng.com>
Sent: Monday, March 18, 2019 3:20 PM
To: Wilson, Leonard <LLWilson@saniego.gov>
Subject: SDSU Mission Valley - 8" Domestic Meters

Leonard,

Is there someone in the Meter Shop with whom I can correspond to get some idea of what manufacturer/model compound meter the Shop would supply for the SDSU Mission Valley campus?

Thank you.

Andrew Oven, P.E.
Dexter Wilson Engineering, Inc.
2234 Faraday Avenue
Carlsbad, CA 92008
(760) 438-4422



Badger Meter

Recordall® Fire Series Assembly (FSAA)

Cold Water Meter & Strainer with Turbine Bypass

UL Certified & FM 1044 Standard Approved for Fire Service Applications

NSF/ANSI Standards 61 and 372 Certified

DESCRIPTION

Recordall® Fire Series assemblies meet or exceed all pressure and performance requirements as stated in the most recent revision of AWWA Standard C703. The assembly's primary turbine meter features cast iron housing, while the turbine bypass meter is cast in a lead-free bronze alloy. Fire Series assemblies comply with the lead-free provisions of the Safe Drinking Water Act and are also certified to NSF/ANSI Standards 61 and 372. These assemblies carry the NSF-61 Mark, Trade Designation: FSAA-01.

Badger Meter® Fire Series assemblies also conform to UL 327 and FM 1004. The strainer conforms to UL 321 and FM 5551. The valve conforms to UL 312 and FM 1045.

Offered in five sizes, Fire Series assemblies are designed for revenue-generating flexibility and control on high volume fire service water measurement applications and feature:

- Direct coupled turbine based on an exclusive “floating rotor” design that reduces bearing friction—and associated wear and tear
- Turbine meter bypass
- Low head loss for optimum pressure during fire extinguishing
- Integral fire service strainer to protect the meter element from debris and prevent downstream blockage
- Tamper-resistant calibration vane allowing in-line accuracy adjustments while under pressure
- Factory-calibrated and tested measuring elements that are unitized for simplified installation and inventory
- Meters and encoders are compatible with Badger Meter ORION® family of endpoints and other approved technologies

Applications

Use the Recordall Fire Series assembly for measuring potable cold water in your vital fire protection systems. Select this assembly when the fire service main is used for both high-volume fire applications, such as sprinkler systems, and low-volume domestic services, such as general purpose plumbing.

These assemblies use proven turbine technology to help provide accurate measurement and optimal performance during fire service events.

Operation & Performance

If water enters the meter at a low flow rate, a spring-loaded check valve on the downstream side holds the clapper assembly in a closed position. Water is diverted through a 2 inch turbine bypass meter. This enables accurate registration of domestic use, leakage or misuse of water intended for stand-by fire protection. When a major flow is required, the resulting water pressure opens the check valve and allows water to flow through the main turbine chamber at full pipe capacity. A small amount of water will continue to flow through the bypass when the clapper assembly is fully open.

FSA-DS-00703-EN-02 (October 2015)



Direct magnetic drive is achieved when the magnet carrier is driven by a gear train coupled to the rotor. The gear train consists of two sets of gears connected by a vertical transmission shaft. One gear set is at the magnet carrier, the other is a worm gear set at the rotor shaft. When water enters the main turbine chamber at high volume rates, it contacts a multi-vaned rotor. The resulting rotor rotation is then transmitted by magnetic coupling to a sealed register or encoder. The direct magnetic drive provides a reliable meter-to-registration coupling.

Construction

The Recordall Fire Series assembly's construction complies with AWWA C703 standards. It consists of the following basic components: meter housing, an AWWA Class II measuring chamber, a check valve with bypass piping, valve assembly, a 2 inch turbine bypass measuring chamber and sealed registers or encoders. The assembly also includes a strainer, which features an open area at least six times the area of the nominal pipe size. The strainer is equipped with a flushing outlet port (or optional valve) for flushing debris from the upstream side of the strainer screen.

To simplify maintenance, the registers or encoders and measuring elements can be removed without removing the meter housing. Interchangeability of certain parts between meters also minimizes spare parts inventory investment

Tamper-Proof Features

Unauthorized removal of the register or encoder is inhibited by the optional tamper-detection seal wire screw, TORX® tamper-resistant seal screw or the proprietary tamper-resistant keyed seal screw. Each can be installed at the meter site or at the factory.

Meter Installation

The meter is designed for installations where flow is in one direction only. Companion flanges for installation of meters on various pipe types and sizes are available in cast iron or NL bronze as an option. See the “Recordall® Fire Series Assemblies (FSAA) User Manual” for installation guidelines.



Product Data Sheet

SPECIFICATIONS

FSAA Model Includes 2 in. (50 mm) Turbine Bypass Meter	4 in. (100 mm)	6 in. (150 mm)	8 in. (200 mm)	10 in. (250 mm)	12 in. (305 mm)
Meter Flanges, AWWA C207 Class D	4 in. (100 mm)	6 in. (150 mm)	8 in. (200 mm)	10 in. (250 mm)	12 in. (305 mm)
Typical Operating Range (100% ± 1.5%)	4...1250 gpm (0.91...284 m ³ /h)	4...2500 gpm (0.91...568 m ³ /h)	4...4500 gpm (0.91...1022 m ³ /h)	4...7000 gpm (0.91...1590 m ³ /h)	4...7000 gpm (0.908...1590 m ³ /h)
Typical Low Flow (95% minimum)	2.5 gpm (0.57 m ³ /h)	2.5 gpm (0.57 m ³ /h)	2.5 gpm (0.57 m ³ /h)	2.5 gpm (0.57 m ³ /h)	2.5 gpm (0.57 m ³ /h)
Maximum Continuous Flow	1000 gpm (227 m ³ /h)	2000 gpm (454 m ³ /h)	3500 gpm (795 m ³ /h)	5500 gpm (1249 m ³ /h)	5500 gpm (1249 m ³ /h)
Maximum Intermittent Flow	1250 gpm (284 m ³ /h)	2500 gpm (568 m ³ /h)	4500 gpm (1022 m ³ /h)	7000 gpm (1590 m ³ /h)	7000 gpm (1590 m ³ /h)
Maximum Operating Pressure	175 psi (12 bar)				
Maximum Operating Temperature	120° F (49° C)				
Pressure Loss at Crossover	3 psi (0.28 bar)				
Check Valve	Valve body conforms to UL 312 and FM 1044.				
Bypass Line	Specify right-facing (standard, as shown) or left-facing assembly.				
Strainer	Screen open area is at least six times the area of the nominal pipe size. Equipped with a 2 in. (4 in. model) or 3 in. (all other models) flushing port to flush debris from upstream side of strainer screen. Optional flush valve assembly available.				
Optional Equipment	Two isolation valves with test tee				

MATERIALS

Meter Housing	Fusion-bonded epoxy coated ductile cast iron
Bypass Meter Housing	Lead-free bronze alloy
Bypass Measuring Chamber	Injection-molded thermoplastic
Bypass	Water works brass piping conforming to AWWA C800
Nose Cone & Straightening Vanes	Thermoplastic
Rotor	Thermoplastic
Rotor Radial Bearings	Lubricated thermoplastic
Rotor Thruster Bearing	Sapphire jewels
Rotor Bearing Pivots	Passivated 316 stainless steel
Calibration Mechanism	Stainless steel & thermoplastic
Magnet	Ceramic
Turbine Shaft & Bolts	Stainless steel
Clapper Assembly (clapper, spring, hinge & pins)	Stainless steel
Clapper Seal	Elastomeric, EPDM
Valve Seat	Stainless steel
Valve & Strainer Cover Plate	Fusion-bonded epoxy coated steel
Valve & Strainer Cover Plate Gasket	Elastomeric sheet / O-ring
Valve Body	Fusion-bonded epoxy coated steel / stainless steel
Strainer Screen & Trim	Stainless steel
Strainer Body	Fusion-bonded epoxy coated steel
Trim	Zinc-plated steel or (optional) all stainless steel

REGISTERS / ENCODERS


Standard—Sweep-Hand Registration

The standard register is a straight-reading, permanently sealed magnetic drive register. Dirt, moisture, tampering and lens fogging problems are eliminated. The register has a six-odometer wheel totalization display, 360° test circle with center sweep hand, and flow finder to detect leaks. Register gearing is made of self-lubricating engineered polymer, which minimizes friction and provides long life. The multi-position register simplifies meter installation and reading. The register capacity is 10,000,000 gallons (1,000,000 ft³, 100,000 m³).

Optional—Encoders for AMR/AMI Reading Solutions

AMR/AMI solutions are available for all Recordall Disc Series meters. All reading options can be removed from the meter without disrupting water service. Badger Meter encoders provide years of reliable, accurate readings for a variety of applications and are also available pre-wired to Badger Meter approved AMR/AMI solutions. See details at www.badgermeter.com.


PHYSICAL DIMENSIONS



Fire Series FSAA Model	4 in. (100 mm)	6 in. (150 mm)	8 in. (200 mm)	10 in. (250 mm)	12 in. (305 mm)
Meter & Pipe Size	4 in. (100 mm)	6 in. (150 mm)	8 in. (200 mm)	10 in. (250 mm)	12 in. (305 mm)
Shipping Weight-Fully Assembled	312 lb (142 kg)	507 lb (230 kg)	767 lb (348 kg)	1073 lb (487 kg)	1073 lb (487 kg)
Length (A)	33 in. (838 mm)	45 in. (1143 mm)	53 in. (1346 mm)	68 in. (1727 mm)	68 in. (3727 mm)
Height (B)	20-5/8 in. (524 mm)	22-3/8 in. (mm)	25-1/16 in. (637 mm)	25-5/16 in. (643 mm)	33 in. (838 mm)
Height (C)	10-5/8 in. (270 mm)	11-1/16 in. (mm)	12-1/16 in. (306 mm)	14-13/16 in. (mm)	15-3/4 in. (mm)
Length (D) Standard Bypass	22-7/8 in. (581 mm)	25-7/8 in. (657 mm)	29-5/8 in. (752 mm)	33-7/16 in. (849 mm)	33-7/16 in. (849 mm)
Length (D) Optional 2nd Bypass	N/A	29 in. (737 mm)	30-1/4 in. (368 mm)	34-1/16 in. (865 mm)	34-1/16 in. (865 mm)
Length (E) Standard Bypass	16-1/8 in. (410 mm)	16-3/8 in. (416 mm)	17-1/8 in. (435 mm)	19-11/16 in. (500 mm)	19-11/16 in. (500 mm)
Length (E) Optional 2nd Bypass	N/A	19-1/2 in. (241 mm)	17-3/4 in. (451 mm)	20-5/16 in. (516 mm)	20-5/16 in. (516 mm)



PRESSURE LOSS CHART

Rate of flow in gallons per minute (gpm).



ACCURACY CHARTS (CONTINUED)


Rate of flow in gallons per minute (gpm).



APPENDIX E

**CANDIDATE REDUCED PRESSURE ZONE
BACKFLOW PREVENTER ASSEMBLY**

SPECIFICATION SUBMITTAL SHEET



FEATURES

- Sizes: 2 1/2" 3" 4" 6" 8" 10"
- Maximum working water pressure 175 PSI
 Maximum working water temperature 140°F
 Hydrostatic test pressure 350 PSI
 End connections (Grooved for steel pipe) AWWA C606
 (Flanged) ANSI B16.1
 Class 125

OPTIONS (Suffixes can be combined)

- with OS & Y gate valves (standard)
- L - less shut-off valves (flanged body connections)
- LM - less water meter
- with remote reading meter
- with gpm meter (standard)
- CFM - with cu ft/min meter
- G - with groove end gate valves
- FG - with flanged inlet gate connection and grooved outlet gate connection
- MS - with Integral Relief Valve Monitor Switch
- PI - with Post Indicator Gate Valve (3"-10")

ACCESSORIES

- Air gap (Model AG)
- Repair kit (rubber only)
- Thermal expansion tank (Model WXTP)
- OS & Y Gate valve tamper switch (OSY-40)
- QT-SET Quick Test Fitting Set
- Test Cock Lock (Model TCL24)

APPLICATION

Designed for installation on potable water lines in fire protection systems to protect against both backsiphonage and backpressure of contaminated water into the potable water supply. The Model 375DA shall provide protection where a potential health hazard exists. Incorporates metered by-pass to detect leaks and unauthorized water use.


STANDARDS COMPLIANCE

(Unless otherwise noted, applies to sizes 2 1/2" thru 10")

- ASSE® Listed 1047 (2 1/2" thru 8")
- UL® Classified
- AWWA Compliant C550
- CSA® Certified (4" & 6")
- C-UL® Classified
- FM® Approved
- NYC MEA 218-01-M VOL 3
- Approved by the Foundation for Cross Connection Control and Hydraulic Research at the University of Southern California

MATERIALS

- Main valve body Ductile Iron ASTM A 536 Grade 4
- Access covers Ductile Iron ASTM A 536 Grade 4
- Coatings FDA Approved fusion epoxy finish
- Internals Stainless steel, 300 Series
NORYL™, NSF Listed
- Fasteners Stainless Steel, 300 Series
- Elastomers EPDM (FDA approved)
Buna Nitrile (FDA approved)
- Polymers NORYL™, NSF Listed
- Springs Stainless steel, 300 series
- Sensing line Stainless steel, braided hose



Attention: Model 375DA (flange body) and Model 375ADA (grooved body) have different lay lengths.

Relief Valve discharge port:
 2 1/2" - 6" - 2.75 sq. in.
 8" - 10" - 3.69 sq. in.

MODEL 375DAG SHOWN ABOVE

DIMENSIONS & WEIGHTS (do not include pkg.)


MODEL 375DA SIZE	DIMENSION (approximate)																WEIGHT				
	A		B LESS GATE VALVES		C		D		E OS&Y OPEN		E OS&Y CLOSED		F		G		LESS GATE VALVES		WITH OS&Y GATE VALVES		
	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kg	lbs.	kg	
2 1/2	65	31	787	15 7/8	403	7 1/4	184	9	229	16 3/8	416	13 7/8	352	9 1/2	241	8 3/8	213	75	34	185	84
3	80	32	813	15 7/8	403	7 1/4	184	9	229	18 7/8	479	15 5/8	397	9 1/2	241	8 3/8	213	78	35.4	208	94.4
4	100	37 5/8	956	19 1/2	495	8	203	9	229	22 3/4	578	18 1/4	464	11	279	7 1/4	184	116	52.7	306	138.9
6	150	44 3/4	1137	23 1/2	597	10	254	10 1/2	267	30 1/8	765	23 3/4	603	12 3/8	314	9 1/4	235	194	88	494	224.3
8	200	60 3/4	1543	37 3/4	959	11	279	15 1/2	394	37 3/4	959	29 1/4	743	15 3/8	391	16 3/4	426	382	173.4	858	390
10	250	63 3/4	1619	37 3/4	959	11	279	15 1/2	394	45 3/4	1162	35 3/8	899	15 3/8	391	16 3/4	426	412	187	1230	558.4

(Patent No. 5,913,331)


DOCUMENT #: BF-375DA
 REVISION: 11/12

FLOW CHARACTERISTICS

MODEL 375DA 2 1/2", 3" & 4" (STANDARD & METRIC)



MODEL 375DA 6", 8" & 10" (STANDARD & METRIC)




◇ Rated Flow (Established by approval agencies)


TYPICAL INSTALLATION

Local codes shall govern installation requirements. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code. Unless otherwise specified, the assembly shall be mounted at a minimum of 12" (305mm) and a maximum of 30" (762mm) above adequate drains with sufficient side clearance for testing and maintenance. The installation shall be made so that no part of the unit can be submerged.

Capacity thru Schedule 40 Pipe (GPM)				
Pipe size	5 ft/sec	7.5 ft/sec	10 ft/sec	15 ft/sec
2 1/2"	75	112	149	224
3"	115	173	230	346
4"	198	298	397	595
6"	450	675	900	1351
8"	780	1169	1559	2339
10"	1229	1843	2458	3687
12"	1763	2644	3525	5288



OUTDOOR INSTALLATION



INDOOR INSTALLATION

SPECIFICATIONS

The Reduced Pressure Detector Backflow Prevention Assembly shall be ASSE® Listed 1047, and supplied with full port OS & Y gate valves. The main body and access cover shall be epoxy coated ductile iron (ASTM A 536 Grade 4), the seat ring and check valve shall be NORYL™, the stem shall be stainless steel (ASTM A 276) and the seat disc elastomers shall be EPDM. The checks and the relief valve shall be accessible for maintenance without removing the device from the line. The Reduced Pressure Detector Backflow Prevention Assembly shall be a WILKINS Model 375DA.

APPENDIX F

BUILD-OUT WATER SYSTEM COMPUTER MODELING OUTPUT

NODE AND PIPE DIAGRAM REFERENCE:

Exhibit A

CONDITIONS MODELED:

1. Average Day Demand
2. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820.
3. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 794 and 796.
4. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 784 and 788.
5. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 780 and 800.
6. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 720 and 724.
7. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820 with Pipe 143 closed.
8. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 720 and 724 with Pipe 129 closed.
9. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 720 and 724 with Pipe 125 closed.
10. Peak Hour Demand

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Average Day Demand

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	0.0	0
41	16	306.2	0.49
45	48	306.2	0.05
49	16	1087.5	1.74
53	48	1393.7	0.25
101	12	0.0	0
105	12	-50.0	0.14
109	16	-75.0	0.12
117	8	269.9	1.72
121	16	344.9	0.55
125	16	645.3	1.03
127	16	-1087.5	1.74
129	16	-442.2	0.71
131	8	300.4	1.92
133	16	442.2	0.71
135	8	283.1	1.81
137	16	159.1	0.25
139	12	-50.9	0.14
141	8	255.3	1.63
143	12	-306.2	0.87
145	16	-306.2	0.49

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	321.5	0.1
41	16	1203.0	1.92
45	48	1203.0	0.21
49	16	5123.5	8.18
53	48	6326.5	1.12
101	12	321.5	0.91
105	12	226.5	0.64
109	16	179.0	0.29
117	8	1462.4	9.33
121	16	1283.4	2.05
125	16	2911.9	4.65
127	16	-5123.5	8.18
129	16	-2211.6	3.53
131	8	1628.5	10.39
133	16	2211.6	3.53
135	8	1477.1	9.43
137	16	734.6	1.17
139	12	335.6	0.95
141	8	1538.6	9.82
143	12	-1203.0	3.41
145	16	-1203.0	1.92

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 794 and 796

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	328.4	0.1
41	16	1132.0	1.81
45	48	1132.0	0.2
49	16	5116.2	8.16
53	48	6248.2	1.11
101	12	328.4	0.93
105	12	233.4	0.66
109	16	185.9	0.3
117	8	1497.4	9.56
121	16	1311.6	2.09
125	16	2953.4	4.71
127	16	-5116.2	8.16
129	16	-2162.8	3.45
131	8	1641.8	10.48
133	16	2162.8	3.45
135	8	1507.3	9.62
137	16	655.5	1.05
139	12	256.5	0.73
141	8	1388.5	8.86
143	12	-1132.0	3.21
145	16	-1132.0	1.81

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 784 and 788

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	327.4	0.1
41	16	1109.4	1.77
45	48	1109.4	0.2
49	16	5102.6	8.14
53	48	6212.0	1.1
101	12	327.4	0.93
105	12	232.4	0.66
109	16	184.9	0.29
117	8	1492.2	9.52
121	16	1307.3	2.09
125	16	2954.7	4.71
127	16	-5102.6	8.14
129	16	-2147.8	3.43
131	8	1647.4	10.51
133	16	2147.8	3.43
135	8	1520.8	9.71
137	16	627.0	1
139	12	228.0	0.65
141	8	1337.4	8.54
143	12	-1109.4	3.15
145	16	-1109.4	1.77

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 780 and 800

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	323.4	0.1
41	16	1129.7	1.8
45	48	1129.7	0.2
49	16	5118.2	8.17
53	48	6247.8	1.11
101	12	323.4	0.92
105	12	228.4	0.65
109	16	180.9	0.29
117	8	1469.9	9.38
121	16	1289.0	2.06
125	16	2944.7	4.7
127	16	-5118.2	8.17
129	16	-2173.5	3.47
131	8	1655.7	10.57
133	16	2173.5	3.47
135	8	1528.9	9.76
137	16	644.6	1.03
139	12	245.6	0.7
141	8	1375.2	8.78
143	12	-1129.7	3.2
145	16	-1129.7	1.8

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 720 and 724

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	300.2	0.09
41	16	994.1	1.59
45	48	994.1	0.18
49	16	4875.5	7.78
53	48	5869.6	1.04
101	12	300.2	0.85
105	12	205.2	0.58
109	16	157.7	0.25
117	8	1358.8	8.67
121	16	1201.0	1.92
125	16	2848.4	4.54
127	16	-4875.5	7.78
129	16	-2027.1	3.23
131	8	1647.3	10.51
133	16	2027.1	3.23
135	8	1550.6	9.9
137	16	476.5	0.76
139	12	77.5	0.22
141	8	1071.6	6.84
143	12	-994.1	2.82
145	16	-994.1	1.59

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (143) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	368.4	0.12
41	16	0.0	0
45	48	0.0	0
49	16	6279.6	10.02
53	48	6279.6	1.11
101	12	368.4	1.05
105	12	273.4	0.78
109	16	225.9	0.36
117	8	1643.5	10.49
121	16	1417.6	2.26
125	16	3243.1	5.17
127	16	-6279.6	10.02
129	16	-3036.5	4.84
131	8	1825.5	11.65
133	16	3036.5	4.84
135	8	1488.5	9.5
137	16	1548.0	2.47
139	12	1149.0	3.26
141	8	1149.0	7.33
143-XX	12		
145	16	0.0	0

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (129) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 720 and 724

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	400.3	0.13
41	16	1968.8	3.14
45	48	1968.8	0.35
49	16	3800.7	6.06
53	48	5769.5	1.02
101	12	400.3	1.14
105	12	305.3	0.87
109	16	257.8	0.41
117	8	1859.0	11.86
121	16	1601.2	2.55
125	16	3800.7	6.06
127	16	-3800.7	6.06
129-XX	16		
131	8	2199.5	14.04
133	16	0.0	0
135	8	479.6	3.06
137	16	-479.6	0.77
139	12	-878.6	2.49
141	8	1090.2	6.96
143	12	-1968.8	5.58
145	16	-1968.8	3.14

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (125) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 720 and 724

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	1489.2	0.47
41	16	1535.3	2.45
45	48	1535.3	0.27
49	16	3145.3	5.02
53	48	4680.6	0.83
101	12	1489.2	4.22
105	12	1394.2	3.95
109	16	1346.7	2.15
117	8	636.7	4.06
121	16	-710.0	1.13
125-XX	16		
127	16	-3145.3	5.02
129	16	-3145.3	5.02
131	8	710.0	4.53
133	16	3145.3	5.02
135	8	2447.3	15.62
137	16	698.0	1.11
139	12	299.0	0.85
141	8	1834.4	11.71
143	12	-1535.3	4.36
145	16	-1535.3	2.45

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Peak Hour Demand

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	325.4	0.1
41	16	1050.1	1.68
45	48	1050.1	0.19
49	16	4896.1	7.81
53	48	5946.2	1.05
101	12	325.4	0.92
105	12	100.4	0.28
109	16	-12.1	0.02
117	8	1256.9	8.02
121	16	1269.0	2.02
125	16	2751.7	4.39
127	16	-4896.1	7.81
129	16	-2144.4	3.42
131	8	1482.7	9.46
133	16	2144.4	3.42
135	8	1287.4	8.22
137	16	857.0	1.37
139	12	-88.0	0.25
141	8	962.1	6.14
143	12	-1050.1	2.98
145	16	-1050.1	1.68

Project: SDSU Mission Valley

Build-Out Water System

Node Data

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Average Day Demand

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.9	0.0
28	56	536	208.0	208.0	0.0
104	117	390	118.3	117.8	0.5
108	87	390	131.3	130.8	0.5
112	54	390	145.6	145.1	0.5
116	54	390	145.6	145.2	0.4
120	50	390	147.3	146.9	0.4
124	58	390	143.8	143.4	0.4
126	69	390	139.1	138.6	0.5
128	70	390	138.6	138.2	0.5
130	95	390	127.8	127.3	0.5
132	100	390	125.6	125.4	0.3

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.2	1.1
108	87	390	131.3	130.1	1.2
112	54	390	145.6	144.4	1.2
116	54	390	145.6	144.9	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	137.1	2.0
128	70	390	138.6	136.5	2.1
130	95	390	127.8	125.3	2.5
132	100	390	125.6	125.3	0.3

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 794 and 796

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.1	1.1
108	87	390	131.3	130.1	1.2
112	54	390	145.6	144.4	1.2
116	54	390	145.6	144.9	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	137.1	2.0
128	70	390	138.6	136.6	2.0
130	95	390	127.8	125.5	2.3
132	100	390	125.6	125.3	0.3

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 784 and 788

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.1	1.1
108	87	390	131.3	130.1	1.2
112	54	390	145.6	144.4	1.2
116	54	390	145.6	144.9	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	137.1	2.0
128	70	390	138.6	136.6	2.0
130	95	390	127.8	125.6	2.2
132	100	390	125.6	125.3	0.3

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 780 and 800

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.2	1.1
108	87	390	131.3	130.1	1.2
112	54	390	145.6	144.4	1.2
116	54	390	145.6	144.9	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	137.1	2.0
128	70	390	138.6	136.6	2.1
130	95	390	127.8	125.5	2.3
132	100	390	125.6	125.3	0.3

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 720 and 724

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.2	1.1
108	87	390	131.3	130.2	1.1
112	54	390	145.6	144.5	1.1
116	54	390	145.6	145.0	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	143.2	0.7
126	69	390	139.1	137.3	1.8
128	70	390	138.6	136.8	1.8
130	95	390	127.8	126.0	1.9
132	100	390	125.6	125.3	0.3

Scenario: Pipe Break (143) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.0	1.3
108	87	390	131.3	129.9	1.3
112	54	390	145.6	144.2	1.4
116	54	390	145.6	144.9	0.7
120	50	390	147.3	146.8	0.5
124	58	390	143.8	142.9	1.0
126	69	390	139.1	135.8	3.3
128	70	390	138.6	135.0	3.7
130	95	390	127.8	120.2	7.6
132	100	536	188.9	188.7	0.2

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (129) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 720 and 724

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	116.9	1.4
108	87	390	131.3	129.8	1.5
112	54	390	145.6	144.1	1.5
116	54	390	145.6	144.9	0.7
120	50	390	147.3	146.9	0.5
124	58	390	143.8	135.6	8.3
126	69	390	139.1	130.8	8.3
128	70	390	138.6	130.4	8.2
130	95	390	127.8	122.0	5.9
132	100	390	125.6	125.3	0.3

Scenario: Pipe Break (125) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 720 and 724

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.8	0.1
28	56	536	208.0	207.9	0.1
104	117	390	118.3	108.3	10.0
108	87	390	131.3	120.0	11.3
112	54	390	145.6	133.8	11.8
116	54	390	145.6	133.6	12.0
120	50	390	147.3	146.9	0.4
124	58	390	143.8	143.0	0.9
126	69	390	139.1	135.7	3.4
128	70	390	138.6	135.2	3.5
130	95	390	127.8	124.0	3.8
132	100	390	125.6	125.3	0.3

Project: SDSU Mission Valley

Build-Out Water System

Node Data

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Peak Hour Demand

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.2	1.1
108	87	390	131.3	130.1	1.1
112	54	390	145.6	144.4	1.1
116	54	390	145.6	145.0	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	137.1	1.9
128	70	390	138.6	136.6	2.1
130	95	390	127.8	125.8	2.0
132	100	390	125.6	125.3	0.3

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

U N I T S S P E C I F I E D

FLOWRATE = gallons/minute
 HEAD (HGL) = feet
 PRESSURE = psig

R E G U L A T I N G V A L V E D A T A

VALVE LABEL	VALVE TYPE	VALVE SETTING (ft or gpm)
CRPRV	PRV-1	388.65
FRPRS	PRV-1	389.26
OPRS	PRV-1	389.03

P I P E L I N E D A T A

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E NAME	NODE #1	NODE #2	LENGTH (ft)	DIAMETER (in)	ROUGHNESS COEFF.	MINOR LOSS COEFF.
21	0	I-CRPRV	860.20	36.00	120.0000	0.00
41	24	I-FRPRS	56.50	16.00	120.0000	0.00
45	28	24	4114.40	48.00	120.0000	0.00
49	28	I-OPRS	19.30	16.00	120.0000	0.00
53	0	28	5084.10	48.00	120.0000	0.00
101	O-CRPRV	104	3549.60	12.00	120.0000	0.00
105	104	108	537.90	12.00	120.0000	0.00
109	108	112	897.10	16.00	120.0000	0.00
117	112	I-706	94.60	8.00	120.0000	0.00
121	116	112	1065.20	16.00	120.0000	0.00
125	120	116	63.90	16.00	120.0000	0.00
127	120	O-OPRS	14.80	16.00	120.0000	0.00
129	124	120	169.50	16.00	120.0000	0.00
131	116	I-704	47.20	8.00	120.0000	0.00
133	124	126	957.70	16.00	120.0000	0.00
135	126	I-702	51.10	8.00	120.0000	0.00
137	126	128	531.20	16.00	120.0000	0.00
139	128	130	2373.60	12.00	120.0000	0.00
141	130	I-700	183.90	8.00	120.0000	0.00
143	130	132	1236.90	12.00	120.0000	0.00
145	132	O-FRPRS	22.10	16.00	120.0000	0.00
700	O-700	I-701	49.00	10.00	120.0000	0.00
701	O-701	804	120.90	12.00	120.0000	0.00
702	O-702	I-703	39.80	10.00	120.0000	0.00
703	O-703	708	90.60	12.00	120.0000	0.00
704	O-704	I-705	45.30	10.00	120.0000	0.00
705	O-705	714	350.30	12.00	120.0000	0.00
706	O-706	I-707	75.80	10.00	120.0000	0.00
707	O-707	744	278.30	12.00	120.0000	0.00
709	710	708	41.50	12.00	120.0000	0.00
713	710	712	317.30	12.00	120.0000	0.00
715	712	714	399.80	12.00	120.0000	0.00
717	714	716	19.20	12.00	120.0000	0.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

721	716	720	256.50	12.00	120.0000	0.00
725	720	710	449.80	8.00	120.0000	0.00
729	720	724	473.10	8.00	120.0000	0.00
733	740	716	1112.30	12.00	120.0000	0.00
737	740	744	318.40	12.00	120.0000	0.00
745	744	752	349.40	12.00	120.0000	0.00
749	752	756	397.60	8.00	120.0000	0.00
753	756	736	38.60	8.00	120.0000	0.00
757	736	740	268.50	8.00	120.0000	0.00
761	732	736	467.90	8.00	120.0000	0.00
765	728	732	467.90	8.00	120.0000	0.00
769	720	728	286.50	12.00	120.0000	0.00
773	708	728	726.40	12.00	120.0000	0.00
777	772	728	315.90	12.00	120.0000	0.00
781	772	776	207.80	8.00	120.0000	0.00
785	780	772	254.70	12.00	120.0000	0.00
789	768	772	463.00	8.00	120.0000	0.00
793	732	768	316.60	8.00	120.0000	0.00
797	768	784	251.60	8.00	120.0000	0.00
801	764	768	467.60	8.00	120.0000	0.00
805	756	764	275.50	8.00	120.0000	0.00
809	788	764	254.00	8.00	120.0000	0.00
813	764	760	401.50	8.00	120.0000	0.00
817	760	752	286.20	12.00	120.0000	0.00
821	760	792	274.00	12.00	120.0000	0.00
825	792	794	571.30	12.00	120.0000	0.00
827	794	796	987.60	12.00	120.0000	0.00
829	796	816	775.40	12.00	120.0000	0.00
831	792	788	409.80	12.00	120.0000	0.00
833	788	798	286.20	8.00	120.0000	0.00
837	784	788	467.90	12.00	120.0000	0.00
841	780	784	467.60	12.00	120.0000	0.00
845	800	780	276.40	12.00	120.0000	0.00
849	798	800	936.80	8.00	120.0000	0.00
853	804	800	782.00	12.00	120.0000	0.00
857	812	798	797.00	8.00	120.0000	0.00
861	808	812	440.70	8.00	120.0000	0.00
865	808	804	509.80	12.00	120.0000	0.00
869	820	808	420.20	12.00	120.0000	0.00
873	816	820	449.10	12.00	120.0000	0.00
877	816	812	323.30	8.00	120.0000	0.00

P U M P / L O S S E L E M E N T D A T A

THERE IS A DEVICE AT NODE 700 DESCRIBED BY THE FOLLOWING DATA: (ID= 8" Badger FSAA)

HEAD (ft)	FLOWRATE (gpm)
0.00	0.00
-4.62	100.00
-6.92	1500.00
-20.77	3000.00
-36.92	4000.00

SDSU Mission Valley Project
Ultimate Water System Analysis (505166B5)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

THERE IS A DEVICE AT NODE 701 DESCRIBED BY THE FOLLOWING DATA: (ID= 10" Wilkins 375DA)

HEAD (ft)	FLOWRATE (gpm)
-23.08	0.00
-31.15	100.00
-32.31	2000.00
-46.15	3100.00

THERE IS A DEVICE AT NODE 702> (ID= 8" Badger FSAA)
THERE IS A DEVICE AT NODE 703> (ID= 10" Wilkins 375DA)
THERE IS A DEVICE AT NODE 704> (ID= 8" Badger FSAA)
THERE IS A DEVICE AT NODE 705> (ID= 10" Wilkins 375DA)
THERE IS A DEVICE AT NODE 706> (ID= 8" Badger FSAA)
THERE IS A DEVICE AT NODE 707> (ID= 10" Wilkins 375DA)

N O D E D A T A

NODE NAME	NODE TITLE	EXTERNAL DEMAND (gpm)	JUNCTION ELEVATION (ft)	EXTERNAL GRADE (ft)
24		0.00	100.00	
28		0.00	56.00	
104		50.00	117.00	
108		25.00	87.00	
112		0.00	54.00	
116		0.00	54.00	
120		0.00	50.00	
124		0.00	58.00	
126		0.00	69.00	
128		210.00	70.00	
130		0.00	95.00	
132		0.00	100.00	
O-700		0.00	88.00	
O-701		0.00	88.00	
I-702		0.00	69.00	
I-703		0.00	69.00	
I-704		0.00	58.00	
I-705		0.00	58.00	
I-706		0.00	54.00	
I-707		0.00	54.00	
708		0.00	75.00	
710		0.00	75.00	
712		0.00	75.00	
714		0.00	71.00	
716		19.50	71.00	
720		114.50	71.00	
724		137.20	68.00	
728		0.00	71.00	
732		0.00	67.00	
736		0.00	65.00	
740		0.00	65.00	

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

744	0.00	63.00	
752	43.50	63.00	
756	39.20	65.00	
760	89.20	63.00	
764	0.00	65.00	
768	125.80	67.00	
772	128.40	71.00	
776	63.30	74.00	
780	0.00	77.00	
784	30.00	74.00	
788	27.20	71.00	
792	86.10	68.00	
794	18.90	55.00	
796	18.70	56.00	
798	97.20	68.00	
800	40.40	82.00	
804	0.00	84.00	
808	0.00	84.00	
812	0.00	58.00	
816	29.60	64.00	
820	0.00	86.00	
0	----	0.00	536.00
I-CRPRV	0.00	102.50	
O-FRPRS	----	100.80	389.26
I-OPRS	0.00	49.80	
I-700	0.00	88.00	
I-701	0.00	88.00	
O-702	0.00	69.00	
O-703	0.00	69.00	
O-704	0.00	58.00	
O-705	0.00	58.00	
O-706	0.00	54.00	
O-707	0.00	54.00	
O-CRPRV	----	102.50	388.65
I-FRPRS	0.00	100.80	
O-OPRS	----	49.80	389.03

O U T P U T O P T I O N D A T A

OUTPUT SELECTION: ALL RESULTS ARE INCLUDED IN THE TABULATED OUTPUT
 MAXIMUM AND MINIMUM PRESSURES = 5
 MAXIMUM AND MINIMUM VELOCITIES = 5

S Y S T E M C O N F I G U R A T I O N

NUMBER OF PIPES(P) = 74
 NUMBER OF END NODES(J) = 55
 NUMBER OF PRIMARY LOOPS(L) = 19
 NUMBER OF SUPPLY NODES(F) = 1
 NUMBER OF SUPPLY ZONES(Z) = 1

=====
 Case: 0

RESULTS OBTAINED AFTER 19 TRIALS: ACCURACY = 0.14110E-05

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

SDSU Mission Valley Project
 Ultimate Water System Analysis
 Average Day Demand

PIPELINE RESULTS

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

PIPE NAME	NODE NUMBERS		FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
	#1	#2						
21	0	I-CRPRV	0.00	0.00	0.00	0.00	0.00	0.00
41	24	I-FRPRS	306.22	0.00	0.00	0.49	0.08	0.08
45	28	24	306.22	0.00	0.00	0.05	0.00	0.00
49	28	I-OPRS	1087.48	0.02	0.00	1.74	0.85	0.85
53	0	28	1393.70	0.03	0.00	0.25	0.01	0.01
101	O-CRPRV	104	0.00	0.00	0.00	0.00	0.00	0.00
105	104	108	-50.00	0.01	0.00	0.14	0.01	0.01
109	108	112	-75.00	0.01	0.00	0.12	0.01	0.01
117	112	I-706	269.87	0.18	0.00	1.72	1.87	1.87
121	116	112	344.87	0.11	0.00	0.55	0.10	0.10
125	120	116	645.27	0.02	0.00	1.03	0.32	0.32
127	120	O-OPRS	-1087.48	0.01	0.00	1.74	0.85	0.85
129	124	120	-442.21	0.03	0.00	0.71	0.16	0.16
131	116	I-704	300.40	0.11	0.00	1.92	2.28	2.28
133	124	126	442.21	0.15	0.00	0.71	0.16	0.16
135	126	I-702	283.10	0.10	0.00	1.81	2.05	2.05
137	126	128	159.11	0.01	0.00	0.25	0.02	0.02
139	128	130	-50.89	0.03	0.00	0.14	0.01	0.01
141	130	I-700	255.32	0.31	0.00	1.63	1.69	1.69
143	130	132	-306.22	0.41	0.00	0.87	0.33	0.33
145	132	O-FRPRS	-306.22	0.00	0.00	0.49	0.08	0.08
700	O-700	I-701	255.32	0.03	0.00	1.04	0.57	0.57
701	O-701	804	255.32	0.03	0.00	0.72	0.23	0.23
702	O-702	I-703	283.10	0.03	0.00	1.16	0.69	0.69
703	O-703	708	283.10	0.03	0.00	0.80	0.28	0.28
704	O-704	I-705	300.40	0.03	0.00	1.23	0.77	0.77
705	O-705	714	300.40	0.11	0.00	0.85	0.32	0.32
706	O-706	I-707	269.87	0.05	0.00	1.10	0.63	0.63
707	O-707	744	269.87	0.07	0.00	0.77	0.26	0.26
709	710	708	-109.76	0.00	0.00	0.31	0.05	0.05
713	710	712	37.40	0.00	0.00	0.11	0.01	0.01
715	712	714	37.40	0.00	0.00	0.11	0.01	0.01
717	714	716	337.79	0.01	0.00	0.96	0.39	0.39
721	716	720	257.74	0.06	0.00	0.73	0.24	0.24
725	720	710	-72.37	0.07	0.00	0.46	0.16	0.16
729	720	724	137.20	0.25	0.00	0.88	0.54	0.54
733	740	716	-60.55	0.02	0.00	0.17	0.02	0.02
737	740	744	-32.38	0.00	0.00	0.09	0.01	0.01
745	744	752	237.49	0.07	0.00	0.67	0.21	0.21
749	752	756	20.40	0.01	0.00	0.13	0.02	0.02
753	756	736	-73.29	0.01	0.00	0.47	0.17	0.17
757	736	740	-92.94	0.07	0.00	0.59	0.26	0.26
761	732	736	-19.65	0.01	0.00	0.13	0.01	0.01
765	728	732	40.43	0.03	0.00	0.26	0.06	0.06
769	720	728	78.41	0.01	0.00	0.22	0.03	0.03
773	708	728	173.34	0.08	0.00	0.49	0.11	0.11
777	772	728	-211.31	0.05	0.00	0.60	0.17	0.17
781	772	776	63.30	0.03	0.00	0.40	0.13	0.13

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

785	780	772	5.35	0.00	0.00	0.02	0.00	0.00
789	768	772	-24.96	0.01	0.00	0.16	0.02	0.02
793	732	768	60.09	0.04	0.00	0.38	0.12	0.12
797	768	784	-16.06	0.00	0.00	0.10	0.01	0.01
801	764	768	24.69	0.01	0.00	0.16	0.02	0.02
805	756	764	54.49	0.03	0.00	0.35	0.10	0.10
809	788	764	-30.87	0.01	0.00	0.20	0.03	0.03
813	764	760	-1.07	0.00	0.00	0.01	0.00	0.00
817	760	752	-173.59	0.03	0.00	0.49	0.11	0.11
821	760	792	83.32	0.01	0.00	0.24	0.03	0.03
825	792	794	-18.12	0.00	0.00	0.05	0.00	0.00
827	794	796	-37.02	0.01	0.00	0.11	0.01	0.01
829	796	816	-55.72	0.01	0.00	0.16	0.01	0.01
831	792	788	15.34	0.00	0.00	0.04	0.00	0.00
833	788	798	35.31	0.01	0.00	0.23	0.04	0.04
837	784	788	16.30	0.00	0.00	0.05	0.00	0.00
841	780	784	62.37	0.01	0.00	0.18	0.02	0.02
845	800	780	67.72	0.01	0.00	0.19	0.02	0.02
849	798	800	-28.16	0.03	0.00	0.18	0.03	0.03
853	804	800	136.28	0.06	0.00	0.39	0.07	0.07
857	812	798	33.73	0.03	0.00	0.22	0.04	0.04
861	808	812	39.24	0.02	0.00	0.25	0.05	0.05
865	808	804	-119.05	0.03	0.00	0.34	0.06	0.06
869	820	808	-79.81	0.01	0.00	0.23	0.03	0.03
873	816	820	-79.81	0.01	0.00	0.23	0.03	0.03
877	816	812	-5.52	0.00	0.00	0.04	0.00	0.00

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	255.32	300.54	295.23	-5.3
701	255.32	295.20	263.71	-31.5
702	283.10	319.73	314.34	-5.4
703	283.10	314.31	282.78	-31.5
704	300.40	330.89	325.45	-5.4
705	300.40	325.41	293.85	-31.6
706	269.87	334.71	329.36	-5.4
707	269.87	329.31	297.79	-31.5

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.97	100.00	435.97	188.92
28		0.00	535.97	56.00	479.97	207.99
104		50.00	388.88	117.00	271.88	117.81
108		25.00	388.88	87.00	301.88	130.82
112		0.00	388.89	54.00	334.89	145.12
116		0.00	389.00	54.00	335.00	145.17
120		0.00	389.02	50.00	339.02	146.91

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

124	0.00	388.99	58.00	330.99	143.43
126	0.00	388.84	69.00	319.84	138.60
128	210.00	388.83	70.00	318.83	138.16
130	0.00	388.85	95.00	293.85	127.34
132	0.00	389.26	100.00	289.26	125.35
O-700	0.00	383.23	88.00	295.23	127.93
O-701	0.00	351.71	88.00	263.71	114.27
I-702	0.00	388.73	69.00	319.73	138.55
I-703	0.00	383.31	69.00	314.31	136.20
I-704	0.00	388.89	58.00	330.89	143.39
I-705	0.00	383.41	58.00	325.41	141.01
I-706	0.00	388.71	54.00	334.71	145.04
I-707	0.00	383.31	54.00	329.31	142.70
708	0.00	351.75	75.00	276.75	119.92
710	0.00	351.75	75.00	276.75	119.92
712	0.00	351.75	75.00	276.75	119.92
714	0.00	351.74	71.00	280.74	121.66
716	19.50	351.73	71.00	280.73	121.65
720	114.50	351.67	71.00	280.67	121.63
724	137.20	351.42	68.00	283.42	122.82
728	0.00	351.67	71.00	280.67	121.62
732	0.00	351.64	67.00	284.64	123.34
736	0.00	351.65	65.00	286.65	124.21
740	0.00	351.72	65.00	286.72	124.24
744	0.00	351.72	63.00	288.72	125.11
752	43.50	351.65	63.00	288.65	125.08
756	39.20	351.64	65.00	286.64	124.21
760	89.20	351.61	63.00	288.61	125.07
764	0.00	351.61	65.00	286.61	124.20
768	125.80	351.60	67.00	284.60	123.33
772	128.40	351.61	71.00	280.61	121.60
776	63.30	351.59	74.00	277.59	120.29
780	0.00	351.61	77.00	274.61	119.00
784	30.00	351.61	74.00	277.61	120.30
788	27.20	351.61	71.00	280.61	121.60
792	86.10	351.61	68.00	283.61	122.90
794	18.90	351.61	55.00	296.61	128.53
796	18.70	351.61	56.00	295.61	128.10
798	97.20	351.59	68.00	283.59	122.89
800	40.40	351.62	82.00	269.62	116.84
804	0.00	351.68	84.00	267.68	115.99
808	0.00	351.65	84.00	267.65	115.98
812	0.00	351.62	58.00	293.62	127.24
816	29.60	351.62	64.00	287.62	124.64
820	0.00	351.64	86.00	265.64	115.11
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.95	49.80	486.15	210.67
I-700	0.00	388.54	88.00	300.54	130.24
I-701	0.00	383.20	88.00	295.20	127.92
O-702	0.00	383.34	69.00	314.34	136.21
O-703	0.00	351.78	69.00	282.78	122.54
O-704	0.00	383.45	58.00	325.45	141.03
O-705	0.00	351.85	58.00	293.85	127.34
O-706	0.00	383.36	54.00	329.36	142.72
O-707	0.00	351.79	54.00	297.79	129.04
O-CRPRV	----	388.88	102.50	286.38	124.10
I-FRPRS	0.00	535.96	100.80	435.16	188.57
O-OPRS	----	389.03	49.80	339.23	147.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.67	O-701	114.27
28	207.99	820	115.11
24	188.92	808	115.98
I-FRPRS	188.57	804	115.99
I-CRPRV	187.85	800	116.84

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	1.92	813	0.01
135	1.81	785	0.02
49	1.74	877	0.04
127	1.74	831	0.04
117	1.72	837	0.05

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	CLOSED	187.85	124.10	0.00
FRPRS	PRV-1	125.00	ACTIVATED	188.57	125.00	306.22
OPRS	PRV-1	147.00	ACTIVATED	210.67	147.00	1087.48

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	1393.70	

NET SYSTEM INFLOW = 1393.70
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 1393.70

=====
 Case: 1

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 1)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 9 TRIALS: ACCURACY = 0.50450E-04

**SDSU Mission Valley Project
 Ultimate Water System Analysis
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 808 and 820**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	N O D E N U M B E R S		F L O W R A T E gpm	H E A D L O S S ft	M I N O R L O S S ft	L I N E V E L O . ft/s	H L + M L / 1000 ft/f	H L / 1000 ft/f
	#1	#2						
21	0	I-CRPRV	321.50	0.00	0.00	0.10	0.00	0.00
41	24	I-FRPRS	1203.00	0.06	0.00	1.92	1.02	1.02
45	28	24	1203.00	0.02	0.00	0.21	0.00	0.00
49	28	I-OPRS	5123.53	0.29	0.00	8.18	14.93	14.93
53	0	28	6326.53	0.53	0.00	1.12	0.10	0.10
101	O-CRPRV	104	321.50	1.28	0.00	0.91	0.36	0.36
105	104	108	226.50	0.10	0.00	0.64	0.19	0.19
109	108	112	179.00	0.03	0.00	0.29	0.03	0.03
117	112	I-706	1462.42	4.05	0.00	9.33	42.83	42.83
121	116	112	1283.42	1.23	0.00	2.05	1.15	1.15
125	120	116	2911.90	0.34	0.00	4.65	5.24	5.24
127	120	O-OPRS	-5123.53	0.22	0.00	8.18	14.93	14.93
129	124	120	-2211.64	0.53	0.00	3.53	3.15	3.15
131	116	I-704	1628.48	2.47	0.00	10.39	52.27	52.27
133	124	126	2211.64	3.02	0.00	3.53	3.15	3.15
135	126	I-702	1477.06	2.23	0.00	9.43	43.63	43.63
137	126	128	734.58	0.22	0.00	1.17	0.41	0.41
139	128	130	335.58	0.92	0.00	0.95	0.39	0.39
141	130	I-700	1538.57	8.65	0.00	9.82	47.06	47.06
143	130	132	-1203.00	5.12	0.00	3.41	4.14	4.14
145	132	O-FRPRS	-1203.00	0.02	0.00	1.92	1.02	1.02
700	O-700	I-701	1538.57	0.78	0.00	6.28	15.87	15.87
701	O-701	804	1538.57	0.79	0.00	4.36	6.53	6.53
702	O-702	I-703	1477.06	0.59	0.00	6.03	14.72	14.72
703	O-703	708	1477.06	0.55	0.00	4.19	6.06	6.06
704	O-704	I-705	1628.48	0.80	0.00	6.65	17.63	17.63
705	O-705	714	1628.48	2.54	0.00	4.62	7.26	7.26
706	O-706	I-707	1462.42	1.10	0.00	5.97	14.45	14.45
707	O-707	744	1462.42	1.65	0.00	4.15	5.95	5.95
709	710	708	-474.16	0.03	0.00	1.35	0.74	0.74
713	710	712	142.62	0.03	0.00	0.40	0.08	0.08
715	712	714	142.62	0.03	0.00	0.40	0.08	0.08
717	714	716	1771.10	0.16	0.00	5.02	8.48	8.48
721	716	720	1172.80	1.01	0.00	3.33	3.95	3.95
725	720	710	-331.54	1.23	0.00	2.12	2.74	2.74
729	720	724	260.68	0.83	0.00	1.66	1.76	1.76
733	740	716	-561.26	1.12	0.00	1.59	1.01	1.01
737	740	744	1.76	0.00	0.00	0.00	0.00	0.00
745	744	752	1464.18	2.08	0.00	4.15	5.96	5.96
749	752	756	65.27	0.05	0.00	0.42	0.14	0.14

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

753	756	736	-461.46	0.20	0.00	2.95	5.06	5.06
757	736	740	-559.50	1.94	0.00	3.57	7.23	7.23
761	732	736	-98.04	0.13	0.00	0.63	0.29	0.29
765	728	732	333.92	1.30	0.00	2.13	2.78	2.78
769	720	728	1026.10	0.88	0.00	2.91	3.08	3.08
773	708	728	1002.90	2.15	0.00	2.84	2.96	2.96
777	772	728	-1695.08	2.47	0.00	4.81	7.82	7.82
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42
785	780	772	-1193.45	1.04	0.00	3.39	4.08	4.08
789	768	772	-137.40	0.25	0.00	0.88	0.54	0.54
793	732	768	431.96	1.42	0.00	2.76	4.48	4.48
797	768	784	358.85	0.80	0.00	2.29	3.18	3.18
801	764	768	28.51	0.01	0.00	0.18	0.03	0.03
805	756	764	452.25	1.34	0.00	2.89	4.87	4.87
809	788	764	-408.17	1.02	0.00	2.61	4.03	4.03
813	764	760	15.57	0.00	0.00	0.10	0.01	0.01
817	760	752	-1316.25	1.40	0.00	3.73	4.89	4.89
821	760	792	1162.35	1.06	0.00	3.30	3.89	3.89
825	792	794	1168.04	2.24	0.00	3.31	3.92	3.92
827	794	796	1132.13	3.66	0.00	3.21	3.70	3.70
829	796	816	1096.60	2.71	0.00	3.11	3.49	3.49
831	792	788	-169.28	0.04	0.00	0.48	0.11	0.11
833	788	798	550.69	2.01	0.00	3.51	7.02	7.02
837	784	788	363.49	0.21	0.00	1.03	0.45	0.45
841	780	784	61.64	0.01	0.00	0.17	0.02	0.02
845	800	780	-1131.82	1.02	0.00	3.21	3.70	3.70
849	798	800	-220.33	1.21	0.00	1.41	1.29	1.29
853	804	800	-834.72	1.65	0.00	2.37	2.10	2.10
857	812	798	-586.35	6.28	0.00	3.74	7.88	7.88
861	808	812	-384.36	1.59	0.00	2.45	3.61	3.61
865	808	804	-2373.30	7.43	0.00	6.73	14.58	14.58
869	820	808	-757.66	0.74	0.00	2.15	1.76	1.76
873	816	820	1242.34	1.97	0.00	3.52	4.40	4.40
877	816	812	-201.99	0.35	0.00	1.29	1.10	1.10

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1538.57	287.46	280.37	-7.1
701	1538.57	279.59	248.19	-31.4
702	1477.06	314.03	307.20	-6.8
703	1477.06	306.62	275.28	-31.3
704	1628.48	328.01	320.47	-7.5
705	1628.48	319.68	288.18	-31.5
706	1462.42	329.20	322.44	-6.8
707	1462.42	321.34	290.01	-31.3

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.45	100.00	435.45	188.69
28		0.00	535.47	56.00	479.47	207.77
104		95.00(1.90)	387.38	117.00	270.38	117.16
108		47.50(1.90)	387.28	87.00	300.28	130.12
112		0.00	387.25	54.00	333.25	144.41
116		0.00	388.47	54.00	334.47	144.94
120		0.00	388.81	50.00	338.81	146.82
124		0.00	388.28	58.00	330.28	143.12
126		0.00	385.26	69.00	316.26	137.05
128		399.00(1.90)	385.04	70.00	315.04	136.52
130		0.00	384.12	95.00	289.12	125.28
132		0.00	389.24	100.00	289.24	125.34
O-700		0.00	368.37	88.00	280.37	121.49
O-701		0.00	336.19	88.00	248.19	107.55
I-702		0.00	383.03	69.00	314.03	136.08
I-703		0.00	375.62	69.00	306.62	132.87
I-704		0.00	386.01	58.00	328.01	142.14
I-705		0.00	377.68	58.00	319.68	138.53
I-706		0.00	383.20	54.00	329.20	142.65
I-707		0.00	375.34	54.00	321.34	139.25
708		0.00	343.73	75.00	268.73	116.45
710		0.00	343.70	75.00	268.70	116.44
712		0.00	343.67	75.00	268.67	116.42
714		0.00	343.64	71.00	272.64	118.14
716		37.05(1.90)	343.48	71.00	272.48	118.07
720		217.55(1.90)	342.46	71.00	271.46	117.63
724		260.68(1.90)	341.63	68.00	273.63	118.57
728		0.00	341.58	71.00	270.58	117.25
732		0.00	340.28	67.00	273.28	118.42
736		0.00	340.41	65.00	275.41	119.35
740		0.00	342.35	65.00	277.35	120.19
744		0.00	342.35	63.00	279.35	121.05
752		82.65(1.90)	340.27	63.00	277.27	120.15
756		74.48(1.90)	340.22	65.00	275.22	119.26
760		169.48(1.90)	338.87	63.00	275.87	119.54
764		0.00	338.88	65.00	273.88	118.68
768		239.02(1.90)	338.86	67.00	271.86	117.81
772		243.96(1.90)	339.11	71.00	268.11	116.18
776		120.27(1.90)	339.02	74.00	265.02	114.84
780		0.00	338.07	77.00	261.07	113.13
784		57.00(1.90)	338.06	74.00	264.06	114.43
788		51.68(1.90)	337.85	71.00	266.85	115.64
792		163.59(1.90)	337.81	68.00	269.81	116.92
794		35.91(1.90)	335.57	55.00	280.57	121.58
796		35.53(1.90)	331.91	56.00	275.91	119.56
798		184.68(1.90)	335.84	68.00	267.84	116.07
800		76.76(1.90)	337.05	82.00	255.05	110.52
804		0.00	335.40	84.00	251.40	108.94
808		2000.00	327.97	84.00	243.97	105.72
812		0.00	329.56	58.00	271.56	117.68
816		56.24(1.90)	329.21	64.00	265.21	114.92
820		2000.00	327.23	86.00	241.23	104.53
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	389.26	100.80	288.46	125.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

I-OPRS	0.00	535.18	49.80	485.38	210.33
I-700	0.00	375.46	88.00	287.46	124.57
I-701	0.00	367.59	88.00	279.59	121.15
O-702	0.00	376.20	69.00	307.20	133.12
O-703	0.00	344.28	69.00	275.28	119.29
O-704	0.00	378.47	58.00	320.47	138.87
O-705	0.00	346.18	58.00	288.18	124.88
O-706	0.00	376.44	54.00	322.44	139.72
O-707	0.00	344.01	54.00	290.01	125.67
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.39	100.80	434.59	188.32
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.33	820	104.53
28	207.77	808	105.72
24	188.69	O-701	107.55
I-FRPRS	188.32	804	108.94
I-CRPRV	187.85	800	110.52

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	10.39	737	0.00
141	9.82	813	0.10
135	9.43	21	0.10
117	9.33	841	0.17
49	8.18	801	0.18

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	321.50
FRPRS	PRV-1	125.00	ACTIVATED	188.32	125.00	1203.00
OPRS	PRV-1	147.00	ACTIVATED	210.33	147.00	5123.53

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6648.03	

NET SYSTEM INFLOW = 6648.03
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6648.03

=====
 Case: 2

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 2)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 9 TRIALS: ACCURACY = 0.94930E-04

**SDSU Mission Valley Project
 Ultimate Water System Analysis
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 794 and 796**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE NUMBERS #1 #2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0 I-CRPRV	328.36	0.00	0.00	0.10	0.00	0.00
41	24 I-FRPRS	1132.02	0.05	0.00	1.81	0.91	0.91
45	28 24	1132.02	0.02	0.00	0.20	0.00	0.00
49	28 I-OPRS	5116.21	0.29	0.00	8.16	14.89	14.89
53	0 28	6248.23	0.52	0.00	1.11	0.10	0.10
101	O-CRPRV 104	328.36	1.33	0.00	0.93	0.37	0.37
105	104 108	233.36	0.11	0.00	0.66	0.20	0.20
109	108 112	185.86	0.03	0.00	0.30	0.03	0.03
117	112 I-706	1497.43	4.23	0.00	9.56	44.75	44.75
121	116 112	1311.58	1.28	0.00	2.09	1.20	1.20
125	120 116	2953.38	0.34	0.00	4.71	5.38	5.38
127	120 O-OPRS	-5116.21	0.22	0.00	8.16	14.89	14.89
129	124 120	-2162.83	0.51	0.00	3.45	3.02	3.02
131	116 I-704	1641.80	2.50	0.00	10.48	53.07	53.07
133	124 126	2162.83	2.90	0.00	3.45	3.02	3.02
135	126 I-702	1507.33	2.31	0.00	9.62	45.30	45.30
137	126 128	655.50	0.18	0.00	1.05	0.33	0.33
139	128 130	256.50	0.56	0.00	0.73	0.24	0.24
141	130 I-700	1388.53	7.16	0.00	8.86	38.91	38.91
143	130 132	-1132.02	4.58	0.00	3.21	3.70	3.70

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

145	132	O-FRPRS	-1132.02	0.02	0.00	1.81	0.91	0.91
700	O-700	I-701	1388.53	0.64	0.00	5.67	13.13	13.13
701	O-701	804	1388.53	0.65	0.00	3.94	5.40	5.40
702	O-702	I-703	1507.33	0.61	0.00	6.16	15.28	15.28
703	O-703	708	1507.33	0.57	0.00	4.28	6.29	6.29
704	O-704	I-705	1641.80	0.81	0.00	6.71	17.90	17.90
705	O-705	714	1641.80	2.58	0.00	4.66	7.37	7.37
706	O-706	I-707	1497.43	1.14	0.00	6.12	15.10	15.10
707	O-707	744	1497.43	1.73	0.00	4.25	6.21	6.21
709	710	708	-516.42	0.04	0.00	1.46	0.86	0.86
713	710	712	185.36	0.04	0.00	0.53	0.13	0.13
715	712	714	185.36	0.05	0.00	0.53	0.13	0.13
717	714	716	1827.17	0.17	0.00	5.18	8.98	8.98
721	716	720	1141.99	0.96	0.00	3.24	3.76	3.76
725	720	710	-331.06	1.23	0.00	2.11	2.73	2.73
729	720	724	260.68	0.83	0.00	1.66	1.76	1.76
733	740	716	-648.13	1.47	0.00	1.84	1.32	1.32
737	740	744	68.54	0.01	0.00	0.19	0.02	0.02
745	744	752	1565.97	2.36	0.00	4.44	6.75	6.75
749	752	756	-29.50	0.01	0.00	0.19	0.03	0.03
753	756	736	-561.33	0.28	0.00	3.58	7.27	7.27
757	736	740	-579.59	2.07	0.00	3.70	7.72	7.72
761	732	736	-18.26	0.01	0.00	0.12	0.01	0.01
765	728	732	391.26	1.74	0.00	2.50	3.73	3.73
769	720	728	994.82	0.83	0.00	2.82	2.91	2.91
773	708	728	990.91	2.10	0.00	2.81	2.89	2.89
777	772	728	-1594.46	2.20	0.00	4.52	6.98	6.98
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42
785	780	772	-967.88	0.71	0.00	2.75	2.77	2.77
789	768	772	-262.36	0.82	0.00	1.67	1.78	1.78
793	732	768	409.52	1.28	0.00	2.61	4.06	4.06
797	768	784	265.46	0.46	0.00	1.69	1.82	1.82
801	764	768	-167.40	0.36	0.00	1.07	0.77	0.77
805	756	764	457.35	1.37	0.00	2.92	4.98	4.98
809	788	764	-419.39	1.08	0.00	2.68	4.24	4.24
813	764	760	205.36	0.45	0.00	1.31	1.13	1.13
817	760	752	-1512.82	1.81	0.00	4.29	6.33	6.33
821	760	792	1548.70	1.81	0.00	4.39	6.61	6.61
825	792	794	2377.66	8.36	0.00	6.74	14.63	14.63
827	794	796	377.66	0.48	0.00	1.07	0.48	0.48
829	796	816	-1622.34	5.59	0.00	4.60	7.21	7.21
831	792	788	-992.55	1.19	0.00	2.82	2.90	2.90
833	788	798	208.13	0.33	0.00	1.33	1.16	1.16
837	784	788	832.97	0.98	0.00	2.36	2.10	2.10
841	780	784	624.51	0.58	0.00	1.77	1.23	1.23
845	800	780	-343.36	0.11	0.00	0.97	0.41	0.41
849	798	800	-271.56	1.78	0.00	1.73	1.89	1.89
853	804	800	4.96	0.00	0.00	0.01	0.00	0.00
857	812	798	-295.01	1.76	0.00	1.88	2.21	2.21
861	808	812	265.41	0.80	0.00	1.69	1.82	1.82
865	808	804	-1383.57	2.74	0.00	3.92	5.37	5.37
869	820	808	-1118.16	1.52	0.00	3.17	3.62	3.62
873	816	820	-1118.16	1.62	0.00	3.17	3.62	3.62
877	816	812	-560.42	2.34	0.00	3.58	7.25	7.25

SDSU Mission Valley Project
Ultimate Water System Analysis (505166B5)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1388.53	289.51	283.04	-6.5
701	1388.53	282.40	251.12	-31.3
702	1507.33	314.09	307.13	-7.0
703	1507.33	306.52	275.16	-31.4
704	1641.80	327.96	320.36	-7.6
705	1641.80	319.55	288.04	-31.5
706	1497.43	328.96	322.05	-6.9
707	1497.43	320.90	289.54	-31.4

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.46	100.00	435.46	188.70
28		0.00	535.48	56.00	479.48	207.77
104		95.00(1.90)	387.33	117.00	270.33	117.14
108		47.50(1.90)	387.22	87.00	300.22	130.10
112		0.00	387.19	54.00	333.19	144.38
116		0.00	388.47	54.00	334.47	144.94
120		0.00	388.81	50.00	338.81	146.82
124		0.00	388.30	58.00	330.30	143.13
126		0.00	385.40	69.00	316.40	137.11
128		399.00(1.90)	385.23	70.00	315.23	136.60
130		0.00	384.66	95.00	289.66	125.52
132		0.00	389.24	100.00	289.24	125.34
O-700		0.00	371.04	88.00	283.04	122.65
O-701		0.00	339.12	88.00	251.12	108.82
I-702		0.00	383.09	69.00	314.09	136.10
I-703		0.00	375.52	69.00	306.52	132.83
I-704		0.00	385.96	58.00	327.96	142.12
I-705		0.00	377.55	58.00	319.55	138.47
I-706		0.00	382.96	54.00	328.96	142.55
I-707		0.00	374.90	54.00	320.90	139.06
708		0.00	343.59	75.00	268.59	116.39
710		0.00	343.55	75.00	268.55	116.37
712		0.00	343.51	75.00	268.51	116.35
714		0.00	343.46	71.00	272.46	118.06
716		37.05(1.90)	343.28	71.00	272.28	117.99
720		217.55(1.90)	342.32	71.00	271.32	117.57
724		260.68(1.90)	341.49	68.00	273.49	118.51
728		0.00	341.49	71.00	270.49	117.21
732		0.00	339.74	67.00	272.74	118.19
736		0.00	339.75	65.00	274.75	119.06
740		0.00	341.82	65.00	276.82	119.96
744		0.00	341.81	63.00	278.81	120.82
752		82.65(1.90)	339.45	63.00	276.45	119.80
756		74.48(1.90)	339.47	65.00	274.47	118.94
760		169.48(1.90)	337.64	63.00	274.64	119.01
764		0.00	338.10	65.00	273.10	118.34

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

768	239.02(1.90)	338.46	67.00	271.46	117.63
772	243.96(1.90)	339.28	71.00	268.28	116.26
776	120.27(1.90)	339.19	74.00	265.19	114.92
780	0.00	338.58	77.00	261.58	113.35
784	57.00(1.90)	338.00	74.00	264.00	114.40
788	51.68(1.90)	337.02	71.00	266.02	115.28
792	163.59(1.90)	335.83	68.00	267.83	116.06
794	2000.00(**)	327.48	55.00	272.48	118.07
796	2000.00(**)	327.00	56.00	271.00	117.43
798	184.68(1.90)	336.69	68.00	268.69	116.43
800	76.76(1.90)	338.46	82.00	256.46	111.13
804	0.00	338.46	84.00	254.46	110.27
808	0.00	335.73	84.00	251.73	109.08
812	0.00	334.93	58.00	276.93	120.00
816	56.24(1.90)	332.58	64.00	268.58	116.39
820	0.00	334.21	86.00	248.21	107.56
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.19	49.80	485.39	210.34
I-700	0.00	377.51	88.00	289.51	125.45
I-701	0.00	370.40	88.00	282.40	122.37
O-702	0.00	376.13	69.00	307.13	133.09
O-703	0.00	344.16	69.00	275.16	119.23
O-704	0.00	378.36	58.00	320.36	138.82
O-705	0.00	346.04	58.00	288.04	124.82
O-706	0.00	376.05	54.00	322.05	139.55
O-707	0.00	343.54	54.00	289.54	125.47
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.41	100.80	434.61	188.33
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.34	820	107.56
28	207.77	O-701	108.82
24	188.70	808	109.08
I-FRPRS	188.33	804	110.27
I-CRPRV	187.85	800	111.13

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	10.48	853	0.01
135	9.62	21	0.10
117	9.56	761	0.12
141	8.86	749	0.19
49	8.16	737	0.19

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

REGULATING VALVE REPORT

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	328.36
FRPRS	PRV-1	125.00	ACTIVATED	188.33	125.00	1132.02
OPRS	PRV-1	147.00	ACTIVATED	210.34	147.00	5116.21

SUMMARY OF INFLOWS AND OUTFLOWS

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6576.59	

NET SYSTEM INFLOW = 6576.59
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6576.59

=====
 Case: 3

CHANGES FOR NEXT SIMULATION (Change Number = 3)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 11 TRIALS: ACCURACY = 0.55656E-06

**SDSU Mission Valley Project
 Ultimate Water System Analysis
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 784 and 788**

PIPELINE RESULTS

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

PIPE NAME	NODE NUMBERS		FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
	#1	#2						
21	0	I-CRPRV	327.37	0.00	0.00	0.10	0.00	0.00
41	24	I-FRPRS	1109.41	0.05	0.00	1.77	0.88	0.88
45	28	24	1109.41	0.02	0.00	0.20	0.00	0.00
49	28	I-OPRS	5102.57	0.29	0.00	8.14	14.82	14.82
53	0	28	6211.98	0.51	0.00	1.10	0.10	0.10
101	O-CRPRV	104	327.37	1.32	0.00	0.93	0.37	0.37
105	104	108	232.37	0.11	0.00	0.66	0.20	0.20
109	108	112	184.87	0.03	0.00	0.29	0.03	0.03

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

117	112	I-706	1492.18	4.21	0.00	9.52	44.46	44.46
121	116	112	1307.31	1.27	0.00	2.09	1.19	1.19
125	120	116	2954.72	0.34	0.00	4.71	5.39	5.39
127	120	O-OPRS	-5102.57	0.22	0.00	8.14	14.82	14.82
129	124	120	-2147.84	0.51	0.00	3.43	2.98	2.98
131	116	I-704	1647.41	2.52	0.00	10.51	53.41	53.41
133	124	126	2147.84	2.86	0.00	3.43	2.98	2.98
135	126	I-702	1520.82	2.35	0.00	9.71	46.06	46.06
137	126	128	627.02	0.16	0.00	1.00	0.31	0.31
139	128	130	228.02	0.45	0.00	0.65	0.19	0.19
141	130	I-700	1337.43	6.68	0.00	8.54	36.30	36.30
143	130	132	-1109.41	4.41	0.00	3.15	3.56	3.56
145	132	O-FRPRS	-1109.41	0.02	0.00	1.77	0.88	0.88
700	O-700	I-701	1337.43	0.60	0.00	5.46	12.25	12.25
701	O-701	804	1337.43	0.61	0.00	3.79	5.04	5.04
702	O-702	I-703	1520.82	0.62	0.00	6.21	15.54	15.54
703	O-703	708	1520.82	0.58	0.00	4.31	6.39	6.39
704	O-704	I-705	1647.41	0.82	0.00	6.73	18.02	18.02
705	O-705	714	1647.41	2.60	0.00	4.67	7.41	7.41
706	O-706	I-707	1492.18	1.14	0.00	6.10	15.00	15.00
707	O-707	744	1492.18	1.72	0.00	4.23	6.17	6.17
709	710	708	-508.36	0.03	0.00	1.44	0.84	0.84
713	710	712	172.53	0.04	0.00	0.49	0.11	0.11
715	712	714	172.53	0.05	0.00	0.49	0.11	0.11
717	714	716	1819.94	0.17	0.00	5.16	8.92	8.92
721	716	720	1171.04	1.01	0.00	3.32	3.94	3.94
725	720	710	-335.84	1.26	0.00	2.14	2.81	2.81
729	720	724	260.68	0.83	0.00	1.66	1.76	1.76
733	740	716	-611.85	1.32	0.00	1.74	1.18	1.18
737	740	744	26.17	0.00	0.00	0.07	0.00	0.00
745	744	752	1518.35	2.23	0.00	4.31	6.37	6.37
749	752	756	90.39	0.10	0.00	0.58	0.25	0.25
753	756	736	-485.15	0.21	0.00	3.10	5.55	5.55
757	736	740	-585.68	2.11	0.00	3.74	7.87	7.87
761	732	736	-100.53	0.14	0.00	0.64	0.30	0.30
765	728	732	382.42	1.67	0.00	2.44	3.57	3.57
769	720	728	1028.65	0.89	0.00	2.92	3.10	3.10
773	708	728	1012.46	2.19	0.00	2.87	3.01	3.01
777	772	728	-1658.68	2.37	0.00	4.71	7.51	7.51
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42
785	780	772	-996.42	0.74	0.00	2.83	2.92	2.92
789	768	772	-298.03	1.04	0.00	1.90	2.25	2.25
793	732	768	482.95	1.74	0.00	3.08	5.50	5.50
797	768	784	596.81	2.05	0.00	3.81	8.15	8.15
801	764	768	54.84	0.05	0.00	0.35	0.10	0.10
805	756	764	501.06	1.62	0.00	3.20	5.89	5.89
809	788	764	-599.40	2.09	0.00	3.83	8.21	8.21
813	764	760	-153.18	0.26	0.00	0.98	0.66	0.66
817	760	752	-1345.31	1.46	0.00	3.82	5.09	5.09
821	760	792	1022.65	0.84	0.00	2.90	3.07	3.07
825	792	794	-270.01	0.15	0.00	0.77	0.26	0.26
827	794	796	-305.92	0.32	0.00	0.87	0.33	0.33
829	796	816	-341.45	0.31	0.00	0.97	0.40	0.40
831	792	788	1129.07	1.51	0.00	3.20	3.68	3.68
833	788	798	-339.99	0.82	0.00	2.17	2.87	2.87
837	784	788	-68.46	0.01	0.00	0.19	0.02	0.02
841	780	784	1334.73	2.35	0.00	3.79	5.02	5.02
845	800	780	338.31	0.11	0.00	0.96	0.40	0.40
849	798	800	-258.90	1.62	0.00	1.65	1.73	1.73
853	804	800	673.97	1.11	0.00	1.91	1.42	1.42
857	812	798	265.77	1.45	0.00	1.70	1.82	1.82

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

861	808	812	223.03	0.58	0.00	1.42	1.32	1.32
865	808	804	-663.46	0.70	0.00	1.88	1.38	1.38
869	820	808	-440.44	0.27	0.00	1.25	0.64	0.64
873	816	820	-440.44	0.29	0.00	1.25	0.64	0.64
877	816	812	42.75	0.02	0.00	0.27	0.06	0.06

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1337.43	290.16	283.88	-6.3
701	1337.43	283.28	252.02	-31.3
702	1520.82	314.09	307.08	-7.0
703	1520.82	306.46	275.08	-31.4
704	1647.41	327.95	320.32	-7.6
705	1647.41	319.50	287.98	-31.5
706	1492.18	328.99	322.10	-6.9
707	1492.18	320.97	289.61	-31.4

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.47	100.00	435.47	188.70
28		0.00	535.49	56.00	479.49	207.78
104		95.00(1.90)	387.33	117.00	270.33	117.14
108		47.50(1.90)	387.23	87.00	300.23	130.10
112		0.00	387.20	54.00	333.20	144.39
116		0.00	388.47	54.00	334.47	144.94
120		0.00	388.81	50.00	338.81	146.82
124		0.00	388.31	58.00	330.31	143.13
126		0.00	385.45	69.00	316.45	137.13
128		399.00(1.90)	385.28	70.00	315.28	136.62
130		0.00	384.83	95.00	289.83	125.59
132		0.00	389.24	100.00	289.24	125.34
O-700		0.00	371.88	88.00	283.88	123.02
O-701		0.00	340.02	88.00	252.02	109.21
I-702		0.00	383.09	69.00	314.09	136.11
I-703		0.00	375.46	69.00	306.46	132.80
I-704		0.00	385.95	58.00	327.95	142.11
I-705		0.00	377.50	58.00	319.50	138.45
I-706		0.00	382.99	54.00	328.99	142.56
I-707		0.00	374.97	54.00	320.97	139.09
708		0.00	343.50	75.00	268.50	116.35
710		0.00	343.47	75.00	268.47	116.34
712		0.00	343.43	75.00	268.43	116.32
714		0.00	343.38	71.00	272.38	118.03
716		37.05(1.90)	343.21	71.00	272.21	117.96
720		217.55(1.90)	342.20	71.00	271.20	117.52
724		260.68(1.90)	341.37	68.00	273.37	118.46
728		0.00	341.31	71.00	270.31	117.14

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

732	0.00	339.64	67.00	272.64	118.15
736	0.00	339.78	65.00	274.78	119.07
740	0.00	341.90	65.00	276.90	119.99
744	0.00	341.89	63.00	278.89	120.85
752	82.65(1.90)	339.67	63.00	276.67	119.89
756	74.48(1.90)	339.57	65.00	274.57	118.98
760	169.48(1.90)	338.21	63.00	275.21	119.26
764	0.00	337.95	65.00	272.95	118.28
768	239.02(1.90)	337.90	67.00	270.90	117.39
772	243.96(1.90)	338.94	71.00	267.94	116.11
776	120.27(1.90)	338.86	74.00	264.86	114.77
780	0.00	338.20	77.00	261.20	113.19
784	2000.00(**)	335.85	74.00	261.85	113.47
788	2000.00(**)	335.86	71.00	264.86	114.77
792	163.59(1.90)	337.37	68.00	269.37	116.73
794	35.91(1.90)	337.52	55.00	282.52	122.42
796	35.53(1.90)	337.84	56.00	281.84	122.13
798	184.68(1.90)	336.68	68.00	268.68	116.43
800	76.76(1.90)	338.31	82.00	256.31	111.07
804	0.00	339.42	84.00	255.42	110.68
808	0.00	338.71	84.00	254.71	110.38
812	0.00	338.13	58.00	280.13	121.39
816	56.24(1.90)	338.15	64.00	274.15	118.80
820	0.00	338.44	86.00	252.44	109.39
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.20	49.80	485.40	210.34
I-700	0.00	378.16	88.00	290.16	125.73
I-701	0.00	371.28	88.00	283.28	122.76
O-702	0.00	376.08	69.00	307.08	133.07
O-703	0.00	344.08	69.00	275.08	119.20
O-704	0.00	378.32	58.00	320.32	138.80
O-705	0.00	345.98	58.00	287.98	124.79
O-706	0.00	376.10	54.00	322.10	139.58
O-707	0.00	343.61	54.00	289.61	125.50
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.42	100.80	434.62	188.33
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.34	O-701	109.21
28	207.78	820	109.39
24	188.70	808	110.38
I-FRPRS	188.33	804	110.68
I-CRPRV	187.85	800	111.07

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	10.51	737	0.07
135	9.71	21	0.10
117	9.52	837	0.19
141	8.54	45	0.20
49	8.14	877	0.27

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	327.37
FRPRS	PRV-1	125.00	ACTIVATED	188.33	125.00	1109.41
OPRS	PRV-1	147.00	ACTIVATED	210.34	147.00	5102.57

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

- (+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
- (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6539.35	

NET SYSTEM INFLOW = 6539.35
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6539.35

=====
 Case: 4

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 4)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 11 TRIALS: ACCURACY = 0.49918E-06

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

SDSU Mission Valley Project
 Ultimate Water System Analysis
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 780 and 800

PIPELINE RESULTS

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

PIPE NAME	NODE #1	NUMBERS #2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0	I-CRPRV	323.43	0.00	0.00	0.10	0.00	0.00
41	24	I-FRPRS	1129.68	0.05	0.00	1.80	0.91	0.91
45	28	24	1129.68	0.02	0.00	0.20	0.00	0.00
49	28	I-OPRS	5118.16	0.29	0.00	8.17	14.91	14.91
53	0	28	6247.84	0.52	0.00	1.11	0.10	0.10
101	O-CRPRV	104	323.43	1.29	0.00	0.92	0.36	0.36
105	104	108	228.43	0.10	0.00	0.65	0.19	0.19
109	108	112	180.93	0.03	0.00	0.29	0.03	0.03
117	112	I-706	1469.89	4.09	0.00	9.38	43.24	43.24
121	116	112	1288.96	1.23	0.00	2.06	1.16	1.16
125	120	116	2944.69	0.34	0.00	4.70	5.35	5.35
127	120	O-OPRS	-5118.16	0.22	0.00	8.17	14.91	14.91
129	124	120	-2173.47	0.52	0.00	3.47	3.05	3.05
131	116	I-704	1655.73	2.54	0.00	10.57	53.91	53.91
133	124	126	2173.47	2.92	0.00	3.47	3.05	3.05
135	126	I-702	1528.90	2.38	0.00	9.76	46.51	46.51
137	126	128	644.57	0.17	0.00	1.03	0.32	0.32
139	128	130	245.57	0.52	0.00	0.70	0.22	0.22
141	130	I-700	1375.24	7.03	0.00	8.78	38.23	38.23
143	130	132	-1129.68	4.56	0.00	3.20	3.69	3.69
145	132	O-FRPRS	-1129.68	0.02	0.00	1.80	0.91	0.91
700	O-700	I-701	1375.24	0.63	0.00	5.62	12.89	12.89
701	O-701	804	1375.24	0.64	0.00	3.90	5.31	5.31
702	O-702	I-703	1528.90	0.62	0.00	6.25	15.69	15.69
703	O-703	708	1528.90	0.58	0.00	4.34	6.46	6.46
704	O-704	I-705	1655.73	0.82	0.00	6.76	18.18	18.18
705	O-705	714	1655.73	2.62	0.00	4.70	7.48	7.48
706	O-706	I-707	1469.89	1.11	0.00	6.00	14.59	14.59
707	O-707	744	1469.89	1.67	0.00	4.17	6.00	6.00
709	710	708	-465.48	0.03	0.00	1.32	0.71	0.71
713	710	712	119.22	0.02	0.00	0.34	0.06	0.06
715	712	714	119.22	0.02	0.00	0.34	0.06	0.06
717	714	716	1774.96	0.16	0.00	5.03	8.51	8.51
721	716	720	1245.16	1.13	0.00	3.53	4.41	4.41
725	720	710	-346.26	1.34	0.00	2.21	2.97	2.97
729	720	724	260.68	0.83	0.00	1.66	1.76	1.76
733	740	716	-492.74	0.88	0.00	1.40	0.79	0.79
737	740	744	-69.04	0.01	0.00	0.20	0.02	0.02
745	744	752	1400.85	1.92	0.00	3.97	5.49	5.49
749	752	756	126.78	0.18	0.00	0.81	0.46	0.46
753	756	736	-385.96	0.14	0.00	2.46	3.63	3.63
757	736	740	-561.79	1.96	0.00	3.59	7.28	7.28
761	732	736	-175.83	0.40	0.00	1.12	0.85	0.85
765	728	732	301.13	1.07	0.00	1.92	2.29	2.29
769	720	728	1113.19	1.03	0.00	3.16	3.59	3.59
773	708	728	1063.42	2.39	0.00	3.02	3.30	3.30
777	772	728	-1875.48	2.98	0.00	5.32	9.43	9.43
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

785	780	772	-1633.85	1.86	0.00	4.63	7.30	7.30
789	768	772	122.60	0.20	0.00	0.78	0.43	0.43
793	732	768	476.96	1.70	0.00	3.04	5.38	5.38
797	768	784	353.00	0.77	0.00	2.25	3.08	3.08
801	764	768	237.65	0.69	0.00	1.52	1.48	1.48
805	756	764	438.26	1.27	0.00	2.80	4.60	4.60
809	788	764	-360.80	0.81	0.00	2.30	3.21	3.21
813	764	760	-160.19	0.29	0.00	1.02	0.71	0.71
817	760	752	-1191.42	1.16	0.00	3.38	4.07	4.07
821	760	792	861.75	0.61	0.00	2.44	2.23	2.23
825	792	794	83.66	0.02	0.00	0.24	0.03	0.03
827	794	796	47.75	0.01	0.00	0.14	0.01	0.01
829	796	816	12.22	0.00	0.00	0.03	0.00	0.00
831	792	788	614.49	0.49	0.00	1.74	1.19	1.19
833	788	798	255.29	0.48	0.00	1.63	1.69	1.69
837	784	788	-668.32	0.65	0.00	1.90	1.39	1.39
841	780	784	-964.32	1.29	0.00	2.74	2.75	2.75
845	800	780	-598.17	0.31	0.00	1.70	1.14	1.14
849	798	800	271.00	1.77	0.00	1.73	1.89	1.89
853	804	800	1130.84	2.89	0.00	3.21	3.69	3.69
857	812	798	200.39	0.86	0.00	1.28	1.08	1.08
861	808	812	107.16	0.15	0.00	0.68	0.34	0.34
865	808	804	-244.41	0.11	0.00	0.69	0.22	0.22
869	820	808	-137.25	0.03	0.00	0.39	0.07	0.07
873	816	820	-137.25	0.03	0.00	0.39	0.07	0.07
877	816	812	93.23	0.08	0.00	0.60	0.26	0.26

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1375.24	289.65	283.24	-6.4
701	1375.24	282.61	251.33	-31.3
702	1528.90	313.99	306.94	-7.1
703	1528.90	306.32	274.93	-31.4
704	1655.73	327.92	320.25	-7.7
705	1655.73	319.43	287.90	-31.5
706	1469.89	329.14	322.35	-6.8
707	1469.89	321.24	289.91	-31.3

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.46	100.00	435.46	188.70
28		0.00	535.48	56.00	479.48	207.77
104		95.00(1.90)	387.36	117.00	270.36	117.16
108		47.50(1.90)	387.26	87.00	300.26	130.11
112		0.00	387.23	54.00	333.23	144.40
116		0.00	388.47	54.00	334.47	144.94
120		0.00	388.81	50.00	338.81	146.82

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

124	0.00	388.29	58.00	330.29	143.13
126	0.00	385.37	69.00	316.37	137.09
128	399.00(1.90)	385.20	70.00	315.20	136.59
130	0.00	384.68	95.00	289.68	125.53
132	0.00	389.24	100.00	289.24	125.34
O-700	0.00	371.24	88.00	283.24	122.74
O-701	0.00	339.33	88.00	251.33	108.91
I-702	0.00	382.99	69.00	313.99	136.06
I-703	0.00	375.32	69.00	306.32	132.74
I-704	0.00	385.92	58.00	327.92	142.10
I-705	0.00	377.43	58.00	319.43	138.42
I-706	0.00	383.14	54.00	329.14	142.63
I-707	0.00	375.24	54.00	321.24	139.21
708	0.00	343.35	75.00	268.35	116.28
710	0.00	343.32	75.00	268.32	116.27
712	0.00	343.30	75.00	268.30	116.26
714	0.00	343.27	71.00	272.27	117.99
716	37.05(1.90)	343.11	71.00	272.11	117.91
720	217.55(1.90)	341.98	71.00	270.98	117.42
724	260.68(1.90)	341.15	68.00	273.15	118.36
728	0.00	340.95	71.00	269.95	116.98
732	0.00	339.88	67.00	272.88	118.25
736	0.00	340.27	65.00	275.27	119.29
740	0.00	342.23	65.00	277.23	120.13
744	0.00	342.24	63.00	279.24	121.00
752	82.65(1.90)	340.32	63.00	277.32	120.17
756	74.48(1.90)	340.13	65.00	275.13	119.22
760	169.48(1.90)	339.15	63.00	276.15	119.67
764	0.00	338.87	65.00	273.87	118.68
768	239.02(1.90)	338.17	67.00	271.17	117.51
772	243.96(1.90)	337.97	71.00	266.97	115.69
776	120.27(1.90)	337.89	74.00	263.89	114.35
780	2000.00	336.11	77.00	259.11	112.28
784	57.00(1.90)	337.40	74.00	263.40	114.14
788	51.68(1.90)	338.05	71.00	267.05	115.72
792	163.59(1.90)	338.54	68.00	270.54	117.23
794	35.91(1.90)	338.52	55.00	283.52	122.86
796	35.53(1.90)	338.51	56.00	282.51	122.42
798	184.68(1.90)	337.57	68.00	269.57	116.81
800	2000.00(**)	335.80	82.00	253.80	109.98
804	0.00	338.69	84.00	254.69	110.37
808	0.00	338.58	84.00	254.58	110.32
812	0.00	338.43	58.00	280.43	121.52
816	56.24(1.90)	338.51	64.00	274.51	118.96
820	0.00	338.55	86.00	252.55	109.44
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.19	49.80	485.39	210.34
I-700	0.00	377.65	88.00	289.65	125.52
I-701	0.00	370.61	88.00	282.61	122.46
O-702	0.00	375.94	69.00	306.94	133.01
O-703	0.00	343.93	69.00	274.93	119.14
O-704	0.00	378.25	58.00	320.25	138.77
O-705	0.00	345.90	58.00	287.90	124.75
O-706	0.00	376.35	54.00	322.35	139.68
O-707	0.00	343.91	54.00	289.91	125.63
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.41	100.80	434.61	188.33
O-OPRS	----	389.03	49.80	339.23	147.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.34	O-701	108.91
28	207.77	820	109.44
24	188.70	800	109.98
I-FRPRS	188.33	808	110.32
I-CRPRV	187.85	804	110.37

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	10.57	829	0.03
135	9.76	21	0.10
117	9.38	827	0.14
141	8.78	737	0.20
49	8.17	45	0.20

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	323.43
FRPRS	PRV-1	125.00	ACTIVATED	188.33	125.00	1129.68
OPRS	PRV-1	147.00	ACTIVATED	210.34	147.00	5118.16

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6571.27	

NET SYSTEM INFLOW = 6571.27
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6571.27

=====
 Case: 5

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 5)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 11 TRIALS: ACCURACY = 0.81331E-05

**SDSU Mission Valley Project
 Ultimate Water System Analysis
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 720 and 724**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE NUMBERS #1	#2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0	I-CRPRV	300.23	0.00	0.00	0.09	0.00	0.00
41	24	I-FRPRS	994.07	0.04	0.00	1.59	0.72	0.72
45	28	24	994.07	0.01	0.00	0.18	0.00	0.00
49	28	I-OPRS	4875.50	0.26	0.00	7.78	13.62	13.62
53	0	28	5869.57	0.46	0.00	1.04	0.09	0.09
101	O-CRPRV	104	300.23	1.12	0.00	0.85	0.32	0.32
105	104	108	205.23	0.08	0.00	0.58	0.16	0.16
109	108	112	157.73	0.02	0.00	0.25	0.02	0.02
117	112	I-706	1358.77	3.54	0.00	8.67	37.38	37.38
121	116	112	1201.04	1.08	0.00	1.92	1.02	1.02
125	120	116	2848.38	0.32	0.00	4.54	5.03	5.03
127	120	O-OPRS	-4875.50	0.20	0.00	7.78	13.62	13.62
129	124	120	-2027.12	0.45	0.00	3.23	2.68	2.68
131	116	I-704	1647.34	2.52	0.00	10.51	53.40	53.40
133	124	126	2027.12	2.57	0.00	3.23	2.68	2.68
135	126	I-702	1550.63	2.44	0.00	9.90	47.74	47.74
137	126	128	476.49	0.10	0.00	0.76	0.18	0.18
139	128	130	77.49	0.06	0.00	0.22	0.03	0.03
141	130	I-700	1071.56	4.43	0.00	6.84	24.08	24.08
143	130	132	-994.07	3.60	0.00	2.82	2.91	2.91
145	132	O-FRPRS	-994.07	0.02	0.00	1.59	0.72	0.72
700	O-700	I-701	1071.56	0.40	0.00	4.38	8.12	8.12
701	O-701	804	1071.56	0.40	0.00	3.04	3.34	3.34
702	O-702	I-703	1550.63	0.64	0.00	6.33	16.10	16.10
703	O-703	708	1550.63	0.60	0.00	4.40	6.63	6.63
704	O-704	I-705	1647.34	0.82	0.00	6.73	18.01	18.01
705	O-705	714	1647.34	2.60	0.00	4.67	7.41	7.41
706	O-706	I-707	1358.77	0.96	0.00	5.55	12.61	12.61
707	O-707	744	1358.77	1.44	0.00	3.85	5.19	5.19
709	710	708	-708.93	0.06	0.00	2.01	1.56	1.56
713	710	712	165.23	0.03	0.00	0.47	0.10	0.10
715	712	714	165.23	0.04	0.00	0.47	0.10	0.10
717	714	716	1812.57	0.17	0.00	5.14	8.85	8.85
721	716	720	2045.01	2.84	0.00	5.80	11.06	11.06
725	720	710	-543.70	3.08	0.00	3.47	6.85	6.85
729	720	724	2000.00	36.19	0.00	12.76	76.49	76.49
733	740	716	269.49	0.29	0.00	0.76	0.26	0.26
737	740	744	-562.94	0.32	0.00	1.60	1.01	1.01
745	744	752	795.84	0.67	0.00	2.26	1.93	1.93
749	752	756	148.07	0.25	0.00	0.95	0.62	0.62

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

753	756	736	-81.34	0.01	0.00	0.52	0.20	0.20
757	736	740	-293.44	0.59	0.00	1.87	2.19	2.19
761	732	736	-212.11	0.56	0.00	1.35	1.20	1.20
765	728	732	-172.63	0.38	0.00	1.10	0.82	0.82
769	720	728	-1411.30	1.59	0.00	4.00	5.57	5.57
773	708	728	841.70	1.55	0.00	2.39	2.14	2.14
777	772	728	396.96	0.17	0.00	1.13	0.53	0.53
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42
785	780	772	639.49	0.33	0.00	1.81	1.29	1.29
789	768	772	121.70	0.20	0.00	0.78	0.43	0.43
793	732	768	39.48	0.02	0.00	0.25	0.05	0.05
797	768	784	-147.99	0.15	0.00	0.94	0.62	0.62
801	764	768	173.25	0.39	0.00	1.11	0.82	0.82
805	756	764	154.93	0.18	0.00	0.99	0.67	0.67
809	788	764	-89.35	0.06	0.00	0.57	0.24	0.24
813	764	760	-107.68	0.14	0.00	0.69	0.34	0.34
817	760	752	-565.11	0.29	0.00	1.60	1.02	1.02
821	760	792	287.96	0.08	0.00	0.82	0.29	0.29
825	792	794	-161.13	0.06	0.00	0.46	0.10	0.10
827	794	796	-197.04	0.14	0.00	0.56	0.15	0.15
829	796	816	-232.57	0.15	0.00	0.66	0.20	0.20
831	792	788	285.50	0.12	0.00	0.81	0.29	0.29
833	788	798	0.77	0.00	0.00	0.00	0.00	0.00
837	784	788	-322.40	0.17	0.00	0.91	0.36	0.36
841	780	784	-117.41	0.03	0.00	0.33	0.06	0.06
845	800	780	522.08	0.24	0.00	1.48	0.88	0.88
849	798	800	-39.00	0.05	0.00	0.25	0.05	0.05
853	804	800	637.85	1.00	0.00	1.81	1.28	1.28
857	812	798	144.91	0.47	0.00	0.92	0.59	0.59
861	808	812	143.97	0.26	0.00	0.92	0.59	0.59
865	808	804	-433.72	0.32	0.00	1.23	0.63	0.63
869	820	808	-289.74	0.12	0.00	0.82	0.30	0.30
873	816	820	-289.74	0.13	0.00	0.82	0.30	0.30
877	816	812	0.93	0.00	0.00	0.01	0.00	0.00

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1071.56	293.22	287.73	-5.5
701	1071.56	287.34	256.16	-31.2
702	1550.63	314.37	307.21	-7.2
703	1550.63	306.57	275.17	-31.4
704	1647.34	327.99	320.36	-7.6
705	1647.34	319.54	288.02	-31.5
706	1358.77	329.89	323.54	-6.4
707	1358.77	322.58	291.31	-31.3

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.52	100.00	435.52	188.73
28		0.00	535.54	56.00	479.54	207.80
104		95.00(1.90)	387.53	117.00	270.53	117.23
108		47.50(1.90)	387.45	87.00	300.45	130.19
112		0.00	387.42	54.00	333.42	144.48
116		0.00	388.51	54.00	334.51	144.95
120		0.00	388.83	50.00	338.83	146.83
124		0.00	388.37	58.00	330.37	143.16
126		0.00	385.81	69.00	316.81	137.28
128		399.00(1.90)	385.71	70.00	315.71	136.81
130		0.00	385.65	95.00	290.65	125.95
132		0.00	389.25	100.00	289.25	125.34
O-700		0.00	375.73	88.00	287.73	124.68
O-701		0.00	344.16	88.00	256.16	111.00
I-702		0.00	383.37	69.00	314.37	136.23
I-703		0.00	375.57	69.00	306.57	132.85
I-704		0.00	385.99	58.00	327.99	142.13
I-705		0.00	377.54	58.00	319.54	138.47
I-706		0.00	383.89	54.00	329.89	142.95
I-707		0.00	376.58	54.00	322.58	139.78
708		0.00	343.57	75.00	268.57	116.38
710		0.00	343.50	75.00	268.50	116.35
712		0.00	343.47	75.00	268.47	116.34
714		0.00	343.43	71.00	272.43	118.05
716		37.05(1.90)	343.26	71.00	272.26	117.98
720		2000.00(**)	340.42	71.00	269.42	116.75
724		2000.00(**)	304.23	68.00	236.23	102.37
728		0.00	342.01	71.00	271.01	117.44
732		0.00	342.40	67.00	275.40	119.34
736		0.00	342.96	65.00	277.96	120.45
740		0.00	343.54	65.00	278.54	120.70
744		0.00	343.87	63.00	280.87	121.71
752		82.65(1.90)	343.19	63.00	280.19	121.42
756		74.48(1.90)	342.95	65.00	277.95	120.44
760		169.48(1.90)	342.90	63.00	279.90	121.29
764		0.00	342.76	65.00	277.76	120.36
768		239.02(1.90)	342.38	67.00	275.38	119.33
772		243.96(1.90)	342.18	71.00	271.18	117.51
776		120.27(1.90)	342.09	74.00	268.09	116.17
780		0.00	342.51	77.00	265.51	115.05
784		57.00(1.90)	342.53	74.00	268.53	116.36
788		51.68(1.90)	342.70	71.00	271.70	117.74
792		163.59(1.90)	342.82	68.00	274.82	119.09
794		35.91(1.90)	342.88	55.00	287.88	124.75
796		35.53(1.90)	343.02	56.00	287.02	124.38
798		184.68(1.90)	342.70	68.00	274.70	119.04
800		76.76(1.90)	342.75	82.00	260.75	112.99
804		0.00	343.75	84.00	259.75	112.56
808		0.00	343.43	84.00	259.43	112.42
812		0.00	343.17	58.00	285.17	123.58
816		56.24(1.90)	343.17	64.00	279.17	120.98
820		0.00	343.31	86.00	257.31	111.50
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	389.26	100.80	288.46	125.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

I-OPRS	0.00	535.27	49.80	485.47	210.37
I-700	0.00	381.22	88.00	293.22	127.06
I-701	0.00	375.34	88.00	287.34	124.51
O-702	0.00	376.21	69.00	307.21	133.13
O-703	0.00	344.17	69.00	275.17	119.24
O-704	0.00	378.36	58.00	320.36	138.82
O-705	0.00	346.02	58.00	288.02	124.81
O-706	0.00	377.54	54.00	323.54	140.20
O-707	0.00	345.31	54.00	291.31	126.23
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.48	100.80	434.68	188.36
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.37	724	102.37
28	207.80	O-701	111.00
24	188.73	820	111.50
I-FRPRS	188.36	808	112.42
I-CRPRV	187.85	804	112.56

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
729	12.76	833	0.00
131	10.51	877	0.01
135	9.90	21	0.09
117	8.67	45	0.18
49	7.78	139	0.22

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	300.23
FRPRS	PRV-1	125.00	ACTIVATED	188.36	125.00	994.07
OPRS	PRV-1	147.00	ACTIVATED	210.37	147.00	4875.50

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6169.80	

NET SYSTEM INFLOW = 6169.80
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6169.80

=====
 Case: 6

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 6)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 143 is CLOSED

RESULTS OBTAINED AFTER 11 TRIALS: ACCURACY = 0.62377E-06

**SDSU Mission Valley Project
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 808 and 820
 Pipe 143 Out of Service**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE NUMBERS #1 #2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0 I-CRPRV	368.41	0.00	0.00	0.12	0.00	0.00
41	24 I-FRPRS	0.00	0.00	0.00	0.00	0.00	0.00
45	28 24	0.00	0.00	0.00	0.00	0.00	0.00
49	28 I-OPRS	6279.61	0.42	0.00	10.02	21.77	21.77
53	0 28	6279.61	0.53	0.00	1.11	0.10	0.10
101	O-CRPRV 104	368.41	1.64	0.00	1.05	0.46	0.46
105	104 108	273.41	0.14	0.00	0.78	0.27	0.27
109	108 112	225.91	0.04	0.00	0.36	0.05	0.05
117	112 I-706	1643.52	5.03	0.00	10.49	53.17	53.17
121	116 112	1417.61	1.47	0.00	2.26	1.38	1.38
125	120 116	3243.13	0.41	0.00	5.17	6.40	6.40
127	120 O-OPRS	-6279.61	0.32	0.00	10.02	21.77	21.77
129	124 120	-3036.49	0.96	0.00	4.84	5.67	5.67
131	116 I-704	1825.52	3.05	0.00	11.65	64.59	64.59
133	124 126	3036.49	5.43	0.00	4.84	5.67	5.67
135	126 I-702	1488.45	2.26	0.00	9.50	44.26	44.26
137	126 128	1548.04	0.86	0.00	2.47	1.63	1.63
139	128 130	1149.04	9.03	0.00	3.26	3.80	3.80
141	130 I-700	1149.04	5.04	0.00	7.33	27.40	27.40

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

143-XX	130	132						
145	132	O-FRPRS	0.00	0.00	0.00	0.00	0.00	0.00
700	O-700	I-701	1149.04	0.45	0.00	4.69	9.24	9.24
701	O-701	804	1149.04	0.46	0.00	3.26	3.80	3.80
702	O-702	I-703	1488.45	0.59	0.00	6.08	14.93	14.93
703	O-703	708	1488.45	0.56	0.00	4.22	6.14	6.14
704	O-704	I-705	1825.52	0.99	0.00	7.46	21.79	21.79
705	O-705	714	1825.52	3.14	0.00	5.18	8.97	8.97
706	O-706	I-707	1643.52	1.36	0.00	6.71	17.94	17.94
707	O-707	744	1643.52	2.05	0.00	4.66	7.38	7.38
709	710	708	-410.69	0.02	0.00	1.16	0.57	0.57
713	710	712	60.96	0.01	0.00	0.17	0.02	0.02
715	712	714	60.96	0.01	0.00	0.17	0.02	0.02
717	714	716	1886.48	0.18	0.00	5.35	9.53	9.53
721	716	720	1265.60	1.17	0.00	3.59	4.55	4.55
725	720	710	-349.73	1.36	0.00	2.23	3.03	3.03
729	720	724	260.68	0.83	0.00	1.66	1.76	1.76
733	740	716	-583.83	1.21	0.00	1.66	1.09	1.09
737	740	744	-32.88	0.00	0.00	0.09	0.01	0.01
745	744	752	1610.64	2.48	0.00	4.57	7.11	7.11
749	752	756	74.15	0.07	0.00	0.47	0.17	0.17
753	756	736	-500.06	0.23	0.00	3.19	5.87	5.87
757	736	740	-616.71	2.32	0.00	3.94	8.66	8.66
761	732	736	-116.65	0.19	0.00	0.74	0.40	0.40
765	728	732	358.24	1.48	0.00	2.29	3.17	3.17
769	720	728	1137.10	1.07	0.00	3.23	3.73	3.73
773	708	728	1077.76	2.45	0.00	3.06	3.38	3.38
777	772	728	-1856.62	2.92	0.00	5.27	9.25	9.25
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42
785	780	772	-1355.23	1.32	0.00	3.84	5.16	5.16
789	768	772	-137.16	0.25	0.00	0.88	0.53	0.53
793	732	768	474.89	1.69	0.00	3.03	5.33	5.33
797	768	784	418.62	1.06	0.00	2.67	4.22	4.22
801	764	768	45.59	0.03	0.00	0.29	0.07	0.07
805	756	764	499.73	1.62	0.00	3.19	5.86	5.86
809	788	764	-455.76	1.26	0.00	2.91	4.94	4.94
813	764	760	-1.61	0.00	0.00	0.01	0.00	0.00
817	760	752	-1453.84	1.68	0.00	4.12	5.88	5.88
821	760	792	1282.75	1.28	0.00	3.64	4.66	4.66
825	792	794	1235.00	2.48	0.00	3.50	4.35	4.35
827	794	796	1199.09	4.07	0.00	3.40	4.12	4.12
829	796	816	1163.56	3.02	0.00	3.30	3.89	3.89
831	792	788	-115.84	0.02	0.00	0.33	0.05	0.05
833	788	798	601.68	2.37	0.00	3.84	8.27	8.27
837	784	788	313.44	0.16	0.00	0.89	0.34	0.34
841	780	784	-48.18	0.01	0.00	0.14	0.01	0.01
845	800	780	-1403.40	1.52	0.00	3.98	5.51	5.51
849	798	800	-199.13	1.00	0.00	1.27	1.07	1.07
853	804	800	-1127.51	2.87	0.00	3.20	3.67	3.67
857	812	798	-616.13	6.89	0.00	3.93	8.64	8.64
861	808	812	-419.24	1.87	0.00	2.68	4.24	4.24
865	808	804	-2276.55	6.88	0.00	6.46	13.50	13.50
869	820	808	-695.80	0.63	0.00	1.97	1.50	1.50
873	816	820	1304.20	2.16	0.00	3.70	4.81	4.81
877	816	812	-196.88	0.34	0.00	1.26	1.04	1.04

SDSU Mission Valley Project
Ultimate Water System Analysis (505166B5)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1149.04	279.39	273.70	-5.7
701	1149.04	273.25	242.06	-31.2
702	1488.45	311.06	304.19	-6.9
703	1488.45	303.59	272.24	-31.4
704	1825.52	327.25	318.60	-8.6
705	1825.52	317.61	285.79	-31.8
706	1643.52	327.80	320.19	-7.6
707	1643.52	318.83	287.31	-31.5

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.47	100.00	435.47	188.71
28		0.00	535.47	56.00	479.47	207.77
104		95.00(1.90)	387.01	117.00	270.01	117.00
108		47.50(1.90)	386.87	87.00	299.87	129.94
112		0.00	386.83	54.00	332.83	144.22
116		0.00	388.30	54.00	334.30	144.86
120		0.00	388.71	50.00	338.71	146.77
124		0.00	387.75	58.00	329.75	142.89
126		0.00	382.32	69.00	313.32	135.77
128		399.00(1.90)	381.46	70.00	311.46	134.96
130		0.00	372.43	95.00	277.43	120.22
132		0.00	535.47	100.00	435.47	188.71
O-700		0.00	361.70	88.00	273.70	118.61
O-701		0.00	330.06	88.00	242.06	104.89
I-702		0.00	380.06	69.00	311.06	134.79
I-703		0.00	372.59	69.00	303.59	131.56
I-704		0.00	385.25	58.00	327.25	141.81
I-705		0.00	375.61	58.00	317.61	137.63
I-706		0.00	381.80	54.00	327.80	142.05
I-707		0.00	372.83	54.00	318.83	138.16
708		0.00	340.68	75.00	265.68	115.13
710		0.00	340.66	75.00	265.66	115.12
712		0.00	340.65	75.00	265.65	115.12
714		0.00	340.65	71.00	269.65	116.85
716		37.05(1.90)	340.46	71.00	269.46	116.77
720		217.55(1.90)	339.30	71.00	268.30	116.26
724		260.68(1.90)	338.47	68.00	270.47	117.20
728		0.00	338.23	71.00	267.23	115.80
732		0.00	336.75	67.00	269.75	116.89
736		0.00	336.93	65.00	271.93	117.84
740		0.00	339.26	65.00	274.26	118.84
744		0.00	339.26	63.00	276.26	119.71
752		82.65(1.90)	336.77	63.00	273.77	118.64
756		74.48(1.90)	336.71	65.00	271.71	117.74
760		169.48(1.90)	335.09	63.00	272.09	117.91
764		0.00	335.09	65.00	270.09	117.04

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

768	239.02(1.90)	335.06	67.00	268.06	116.16
772	243.96(1.90)	335.31	71.00	264.31	114.53
776	120.27(1.90)	335.22	74.00	261.22	113.20
780	0.00	333.99	77.00	256.99	111.36
784	57.00(1.90)	334.00	74.00	260.00	112.67
788	51.68(1.90)	333.84	71.00	262.84	113.90
792	163.59(1.90)	333.81	68.00	265.81	115.19
794	35.91(1.90)	331.33	55.00	276.33	119.74
796	35.53(1.90)	327.26	56.00	271.26	117.55
798	184.68(1.90)	331.47	68.00	263.47	114.17
800	76.76(1.90)	332.47	82.00	250.47	108.54
804	0.00	329.60	84.00	245.60	106.42
808	2000.00	322.72	84.00	238.72	103.44
812	0.00	324.58	58.00	266.58	115.52
816	56.24(1.90)	324.24	64.00	260.24	112.77
820	2000.00	322.08	86.00	236.08	102.30
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	535.47	100.80	434.67	188.36
I-OPRS	0.00	535.05	49.80	485.25	210.28
I-700	0.00	367.39	88.00	279.39	121.07
I-701	0.00	361.25	88.00	273.25	118.41
O-702	0.00	373.19	69.00	304.19	131.81
O-703	0.00	341.24	69.00	272.24	117.97
O-704	0.00	376.60	58.00	318.60	138.06
O-705	0.00	343.79	58.00	285.79	123.84
O-706	0.00	374.19	54.00	320.19	138.75
O-707	0.00	341.31	54.00	287.31	124.50
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.47	100.80	434.67	188.36
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.28	820	102.30
28	207.77	808	103.44
132	188.71	O-701	104.89
24	188.71	804	106.42
O-FRPRS	188.36	800	108.54

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	11.65	813	0.01
117	10.49	737	0.09
49	10.02	21	0.12
127	10.02	841	0.14
135	9.50	713	0.17

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

REGULATING VALVE REPORT

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	368.41
FRPRS	PRV-1	125.00	WIDE OPEN	188.36	188.36	0.00
OPRS	PRV-1	147.00	ACTIVATED	210.28	147.00	6279.61

SUMMARY OF INFLOWS AND OUTFLOWS

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6648.03	

NET SYSTEM INFLOW = 6648.03
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6648.03

=====
 Case: 7

CHANGES FOR NEXT SIMULATION (Change Number = 7)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 129 is CLOSED
 Pipe 143 is OPENED

RESULTS OBTAINED AFTER 16 TRIALS: ACCURACY = 0.82015E-05

**SDSU Mission Valley Project
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 720 and 724
 Pipe 129 Out of Service**

PIPELINE RESULTS

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

PIPE NAME	NODE #1	NODE #2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0	I-CRPRV	400.34	0.00	0.00	0.13	0.00	0.00
41	24	I-FRPRS	1968.79	0.14	0.00	3.14	2.54	2.54
45	28	24	1968.79	0.05	0.00	0.35	0.01	0.01
49	28	I-OPRS	3800.68	0.17	0.00	6.06	8.59	8.59
53	0	28	5769.47	0.45	0.00	1.02	0.09	0.09
101	O-CRPRV	104	400.34	1.92	0.00	1.14	0.54	0.54

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

105	104	108	305.34	0.18	0.00	0.87	0.33	0.33
109	108	112	257.84	0.05	0.00	0.41	0.06	0.06
117	112	I-706	1859.03	6.32	0.00	11.86	66.80	66.80
121	116	112	1601.19	1.85	0.00	2.55	1.73	1.73
125	120	116	3800.68	0.55	0.00	6.06	8.59	8.59
127	120	O-OPRS	-3800.68	0.13	0.00	6.06	8.59	8.59
129-XX	124	120						
131	116	I-704	2199.49	4.31	0.00	14.04	91.21	91.21
133	124	126	0.00	0.00	0.00	0.00	0.00	0.00
135	126	I-702	479.60	0.28	0.00	3.06	5.43	5.43
137	126	128	-479.60	0.10	0.00	0.77	0.19	0.19
139	128	130	-878.60	5.49	0.00	2.49	2.31	2.31
141	130	I-700	1090.18	4.57	0.00	6.96	24.86	24.86
143	130	132	-1968.79	12.76	0.00	5.58	10.31	10.31
145	132	O-FRPRS	-1968.79	0.06	0.00	3.14	2.54	2.54
700	O-700	I-701	1090.18	0.41	0.00	4.45	8.39	8.39
701	O-701	804	1090.18	0.42	0.00	3.09	3.45	3.45
702	O-702	I-703	479.60	0.07	0.00	1.96	1.83	1.83
703	O-703	708	479.60	0.07	0.00	1.36	0.75	0.75
704	O-704	I-705	2199.49	1.39	0.00	8.98	30.77	30.77
705	O-705	714	2199.49	4.44	0.00	6.24	12.66	12.66
706	O-706	I-707	1859.03	1.71	0.00	7.59	22.53	22.53
707	O-707	744	1859.03	2.58	0.00	5.27	9.27	9.27
709	710	708	98.39	0.00	0.00	0.28	0.04	0.04
713	710	712	-572.04	0.33	0.00	1.62	1.05	1.05
715	712	714	-572.04	0.42	0.00	1.62	1.05	1.05
717	714	716	1627.45	0.14	0.00	4.62	7.25	7.25
721	716	720	2106.71	3.00	0.00	5.98	11.69	11.69
725	720	710	-473.66	2.39	0.00	3.02	5.31	5.31
729	720	724	2000.00	36.19	0.00	12.76	76.49	76.49
733	740	716	516.31	0.96	0.00	1.46	0.86	0.86
737	740	744	-853.45	0.70	0.00	2.42	2.19	2.19
745	744	752	1005.57	1.04	0.00	2.85	2.97	2.97
749	752	756	199.45	0.43	0.00	1.27	1.07	1.07
753	756	736	-69.59	0.01	0.00	0.44	0.15	0.15
757	736	740	-337.14	0.76	0.00	2.15	2.83	2.83
761	732	736	-267.55	0.86	0.00	1.71	1.84	1.84
765	728	732	-243.75	0.73	0.00	1.56	1.55	1.55
769	720	728	-1419.64	1.61	0.00	4.03	5.63	5.63
773	708	728	577.99	0.77	0.00	1.64	1.07	1.07
777	772	728	597.89	0.36	0.00	1.70	1.13	1.13
781	772	776	120.27	0.09	0.00	0.77	0.42	0.42
785	780	772	794.04	0.49	0.00	2.25	1.92	1.92
789	768	772	168.08	0.36	0.00	1.07	0.78	0.78
793	732	768	23.80	0.01	0.00	0.15	0.02	0.02
797	768	784	-166.93	0.19	0.00	1.07	0.77	0.77
801	764	768	216.37	0.58	0.00	1.38	1.24	1.24
805	756	764	194.56	0.28	0.00	1.24	1.02	1.02
809	788	764	-125.40	0.12	0.00	0.80	0.45	0.45
813	764	760	-147.20	0.24	0.00	0.94	0.61	0.61
817	760	752	-723.47	0.46	0.00	2.05	1.61	1.61
821	760	792	406.78	0.15	0.00	1.15	0.56	0.56
825	792	794	-143.56	0.05	0.00	0.41	0.08	0.08
827	794	796	-179.47	0.12	0.00	0.51	0.12	0.12
829	796	816	-215.00	0.13	0.00	0.61	0.17	0.17
831	792	788	386.76	0.21	0.00	1.10	0.51	0.51
833	788	798	42.91	0.02	0.00	0.27	0.06	0.06
837	784	788	-417.56	0.27	0.00	1.18	0.58	0.58
841	780	784	-193.63	0.07	0.00	0.55	0.14	0.14
845	800	780	600.42	0.32	0.00	1.70	1.14	1.14
849	798	800	11.34	0.00	0.00	0.07	0.01	0.01

SDSU Mission Valley Project
Ultimate Water System Analysis (505166B5)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

853	804	800	665.83	1.08	0.00	1.89	1.38	1.38
857	812	798	153.11	0.52	0.00	0.98	0.66	0.66
861	808	812	141.24	0.25	0.00	0.90	0.56	0.56
865	808	804	-424.35	0.31	0.00	1.20	0.60	0.60
869	820	808	-283.11	0.12	0.00	0.80	0.28	0.28
873	816	820	-283.11	0.13	0.00	0.80	0.28	0.28
877	816	812	11.87	0.00	0.00	0.08	0.01	0.01

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1090.18	283.88	278.35	-5.5
701	1090.18	277.94	246.75	-31.2
702	479.60	301.58	295.74	-5.8
703	479.60	295.67	263.93	-31.7
704	2199.49	326.05	314.62	-11.4
705	2199.49	313.23	280.05	-33.2
706	1859.03	326.19	317.33	-8.9
707	1859.03	315.62	283.72	-31.9

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.50	100.00	435.50	188.72
28		0.00	535.55	56.00	479.55	207.81
104		95.00(1.90)	386.74	117.00	269.74	116.89
108		47.50(1.90)	386.56	87.00	299.56	129.81
112		0.00	386.51	54.00	332.51	144.09
116		0.00	388.35	54.00	334.35	144.89
120		0.00	388.90	50.00	338.90	146.86
124		0.00	370.86	58.00	312.86	135.57
126		0.00	370.86	69.00	301.86	130.81
128		399.00(1.90)	370.96	70.00	300.96	130.41
130		0.00	376.45	95.00	281.45	121.96
132		0.00	389.21	100.00	289.21	125.32
O-700		0.00	366.35	88.00	278.35	120.62
O-701		0.00	334.75	88.00	246.75	106.93
I-702		0.00	370.58	69.00	301.58	130.68
I-703		0.00	364.67	69.00	295.67	128.12
I-704		0.00	384.05	58.00	326.05	141.29
I-705		0.00	371.23	58.00	313.23	135.73
I-706		0.00	380.19	54.00	326.19	141.35
I-707		0.00	369.62	54.00	315.62	136.77
708		0.00	332.86	75.00	257.86	111.74
710		0.00	332.87	75.00	257.87	111.74
712		0.00	333.20	75.00	258.20	111.89
714		0.00	333.62	71.00	262.62	113.80
716		37.05(1.90)	333.48	71.00	262.48	113.74
720		2000.00(**)	330.48	71.00	259.48	112.44

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

724	2000.00(**)	294.29	68.00	226.29	98.06
728	0.00	332.09	71.00	261.09	113.14
732	0.00	332.82	67.00	265.82	115.19
736	0.00	333.68	65.00	268.68	116.43
740	0.00	334.44	65.00	269.44	116.76
744	0.00	335.14	63.00	272.14	117.93
752	82.65(1.90)	334.10	63.00	271.10	117.48
756	74.48(1.90)	333.67	65.00	268.67	116.42
760	169.48(1.90)	333.64	63.00	270.64	117.28
764	0.00	333.39	65.00	268.39	116.30
768	239.02(1.90)	332.81	67.00	265.81	115.18
772	243.96(1.90)	332.45	71.00	261.45	113.29
776	120.27(1.90)	332.36	74.00	258.36	111.96
780	0.00	332.94	77.00	255.94	110.91
784	57.00(1.90)	333.00	74.00	259.00	112.23
788	51.68(1.90)	333.28	71.00	262.28	113.65
792	163.59(1.90)	333.48	68.00	265.48	115.04
794	35.91(1.90)	333.53	55.00	278.53	120.70
796	35.53(1.90)	333.65	56.00	277.65	120.32
798	184.68(1.90)	333.26	68.00	265.26	114.95
800	76.76(1.90)	333.25	82.00	251.25	108.88
804	0.00	334.34	84.00	250.34	108.48
808	0.00	334.03	84.00	250.03	108.35
812	0.00	333.78	58.00	275.78	119.50
816	56.24(1.90)	333.78	64.00	269.78	116.91
820	0.00	333.91	86.00	247.91	107.43
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.39	49.80	485.59	210.42
I-700	0.00	371.88	88.00	283.88	123.01
I-701	0.00	365.94	88.00	277.94	120.44
O-702	0.00	364.74	69.00	295.74	128.16
O-703	0.00	332.93	69.00	263.93	114.37
O-704	0.00	372.62	58.00	314.62	136.34
O-705	0.00	338.05	58.00	280.05	121.36
O-706	0.00	371.33	54.00	317.33	137.51
O-707	0.00	337.72	54.00	283.72	122.94
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.36	100.80	434.56	188.31
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.42	724	98.06
28	207.81	O-701	106.93
24	188.72	820	107.43
I-FRPRS	188.31	808	108.35
I-CRPRV	187.85	804	108.48

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	14.04	849	0.07
729	12.76	877	0.08
117	11.86	21	0.13
704	8.98	793	0.15
706	7.59	833	0.27

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	400.34
FRPRS	PRV-1	125.00	ACTIVATED	188.31	125.00	1968.79
OPRS	PRV-1	147.00	ACTIVATED	210.42	147.00	3800.68

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6169.81	

NET SYSTEM INFLOW = 6169.81
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6169.80

=====
 Case: 8

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 8)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 125 is CLOSED
 Pipe 129 is OPENED

RESULTS OBTAINED AFTER 11 TRIALS: ACCURACY = 0.32148E-05

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

**SDSU Mission Valley Project
 Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 720 and 724
 Pipe 125 Out of Service**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE NUMBERS #1 #2	FLOWRATE gpm	HEAD ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0 I-CRPRV	1489.19	0.03	0.00	0.47	0.03	0.03
41	24 I-FRPRS	1535.33	0.09	0.00	2.45	1.60	1.60
45	28 24	1535.33	0.03	0.00	0.27	0.01	0.01
49	28 I-OPRS	3145.28	0.12	0.00	5.02	6.05	6.05
53	0 28	4680.61	0.30	0.00	0.83	0.06	0.06
101	O-CRPRV 104	1489.19	21.83	0.00	4.22	6.15	6.15
105	104 108	1394.19	2.93	0.00	3.95	5.44	5.44
109	108 112	1346.69	1.13	0.00	2.15	1.26	1.26
117	112 I-706	636.73	0.87	0.00	4.06	9.18	9.18
121	116 112	-709.96	0.41	0.00	1.13	0.38	0.38
125-XX	120 116						
127	120 O-OPRS	-3145.28	0.09	0.00	5.02	6.05	6.05
129	124 120	-3145.28	1.03	0.00	5.02	6.05	6.05
131	116 I-704	709.96	0.53	0.00	4.53	11.23	11.23
133	124 126	3145.28	5.79	0.00	5.02	6.05	6.05
135	126 I-702	2447.26	5.68	0.00	15.62	111.15	111.15
137	126 128	698.02	0.20	0.00	1.11	0.37	0.37
139	128 130	299.02	0.75	0.00	0.85	0.31	0.31
141	130 I-700	1834.35	11.98	0.00	11.71	65.17	65.17
143	130 132	-1535.33	8.05	0.00	4.36	6.51	6.51
145	132 O-FRPRS	-1535.33	0.04	0.00	2.45	1.60	1.60
700	O-700 I-701	1834.35	1.08	0.00	7.49	21.98	21.98
701	O-701 804	1834.35	1.09	0.00	5.20	9.05	9.05
702	O-702 I-703	2447.26	1.49	0.00	10.00	37.49	37.49
703	O-703 708	2447.26	1.40	0.00	6.94	15.43	15.43
704	O-704 I-705	709.96	0.17	0.00	2.90	3.79	3.79
705	O-705 714	709.96	0.55	0.00	2.01	1.56	1.56
706	O-706 I-707	636.73	0.23	0.00	2.60	3.10	3.10
707	O-707 744	636.73	0.35	0.00	1.81	1.27	1.27
709	710 708	-1450.24	0.24	0.00	4.11	5.85	5.85
713	710 712	835.57	0.67	0.00	2.37	2.11	2.11
715	712 714	835.57	0.84	0.00	2.37	2.11	2.11
717	714 716	1545.54	0.13	0.00	4.38	6.59	6.59
721	716 720	1795.79	2.23	0.00	5.09	8.70	8.70
725	720 710	-614.67	3.87	0.00	3.92	8.60	8.60
729	720 724	2000.00	36.19	0.00	12.76	76.49	76.49
733	740 716	287.30	0.32	0.00	0.81	0.29	0.29
737	740 744	-363.36	0.14	0.00	1.03	0.45	0.45
745	744 752	273.37	0.09	0.00	0.78	0.27	0.27
749	752 756	88.84	0.10	0.00	0.57	0.24	0.24
753	756 736	53.66	0.00	0.00	0.34	0.09	0.09
757	736 740	-76.06	0.05	0.00	0.49	0.18	0.18
761	732 736	-129.72	0.23	0.00	0.83	0.48	0.48
765	728 732	-149.60	0.29	0.00	0.95	0.63	0.63
769	720 728	-1589.54	1.99	0.00	4.51	6.94	6.94
773	708 728	997.02	2.12	0.00	2.83	2.92	2.92
777	772 728	442.93	0.21	0.00	1.26	0.65	0.65
781	772 776	120.27	0.09	0.00	0.77	0.42	0.42

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

785	780	772	726.34	0.41	0.00	2.06	1.63	1.63
789	768	772	80.83	0.09	0.00	0.52	0.20	0.20
793	732	768	-19.88	0.00	0.00	0.13	0.01	0.01
797	768	784	-205.84	0.29	0.00	1.31	1.13	1.13
801	764	768	133.89	0.24	0.00	0.85	0.51	0.51
805	756	764	-39.30	0.01	0.00	0.25	0.05	0.05
809	788	764	99.27	0.07	0.00	0.63	0.29	0.29
813	764	760	-73.91	0.07	0.00	0.47	0.17	0.17
817	760	752	-101.88	0.01	0.00	0.29	0.04	0.04
821	760	792	-141.52	0.02	0.00	0.40	0.08	0.08
825	792	794	-399.56	0.31	0.00	1.13	0.54	0.54
827	794	796	-435.47	0.62	0.00	1.24	0.63	0.63
829	796	816	-471.00	0.57	0.00	1.34	0.73	0.73
831	792	788	94.45	0.02	0.00	0.27	0.04	0.04
833	788	798	-179.52	0.25	0.00	1.15	0.88	0.88
837	784	788	-123.02	0.03	0.00	0.35	0.06	0.06
841	780	784	139.82	0.04	0.00	0.40	0.08	0.08
845	800	780	866.15	0.62	0.00	2.46	2.25	2.25
849	798	800	-117.90	0.38	0.00	0.75	0.40	0.40
853	804	800	1060.81	2.57	0.00	3.01	3.28	3.28
857	812	798	246.30	1.26	0.00	1.57	1.58	1.58
861	808	812	256.60	0.75	0.00	1.64	1.71	1.71
865	808	804	-773.54	0.93	0.00	2.19	1.83	1.83
869	820	808	-516.94	0.36	0.00	1.47	0.87	0.87
873	816	820	-516.94	0.39	0.00	1.47	0.87	0.87
877	816	812	-10.30	0.00	0.00	0.07	0.00	0.00

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1834.35	281.19	272.49	-8.7
701	1834.35	271.41	239.57	-31.8
702	2447.26	307.44	293.61	-13.8
703	2447.26	292.12	257.19	-34.9
704	709.96	303.83	297.64	-6.2
705	709.96	297.47	265.58	-31.9
706	636.73	307.90	301.81	-6.1
707	636.73	301.58	269.73	-31.8

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.66	100.00	435.66	188.79
28		0.00	535.70	56.00	479.70	207.87
104		95.00(1.90)	366.83	117.00	249.83	108.26
108		47.50(1.90)	363.90	87.00	276.90	119.99
112		0.00	362.77	54.00	308.77	133.80
116		0.00	362.36	54.00	308.36	133.62
120		0.00	388.94	50.00	338.94	146.87

SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios

April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166

124	0.00	387.92	58.00	329.92	142.96
126	0.00	382.12	69.00	313.12	135.69
128	399.00(1.90)	381.92	70.00	311.92	135.17
130	0.00	381.18	95.00	286.18	124.01
132	0.00	389.23	100.00	289.23	125.33
O-700	0.00	360.49	88.00	272.49	118.08
O-701	0.00	327.57	88.00	239.57	103.81
I-702	0.00	376.44	69.00	307.44	133.23
I-703	0.00	361.12	69.00	292.12	126.59
I-704	0.00	361.83	58.00	303.83	131.66
I-705	0.00	355.47	58.00	297.47	128.90
I-706	0.00	361.90	54.00	307.90	133.42
I-707	0.00	355.58	54.00	301.58	130.68
708	0.00	324.79	75.00	249.79	108.24
710	0.00	324.55	75.00	249.55	108.14
712	0.00	323.88	75.00	248.88	107.85
714	0.00	323.03	71.00	252.03	109.21
716	37.05(1.90)	322.91	71.00	251.91	109.16
720	2000.00(**)	320.68	71.00	249.68	108.19
724	2000.00(**)	284.49	68.00	216.49	93.81
728	0.00	322.66	71.00	251.66	109.05
732	0.00	322.96	67.00	255.96	110.91
736	0.00	323.18	65.00	258.18	111.88
740	0.00	323.23	65.00	258.23	111.90
744	0.00	323.38	63.00	260.38	112.83
752	82.65(1.90)	323.28	63.00	260.28	112.79
756	74.48(1.90)	323.19	65.00	258.19	111.88
760	169.48(1.90)	323.27	63.00	260.27	112.78
764	0.00	323.20	65.00	258.20	111.89
768	239.02(1.90)	322.96	67.00	255.96	110.92
772	243.96(1.90)	322.87	71.00	251.87	109.14
776	120.27(1.90)	322.78	74.00	248.78	107.81
780	0.00	323.28	77.00	246.28	106.72
784	57.00(1.90)	323.25	74.00	249.25	108.01
788	51.68(1.90)	323.28	71.00	252.28	109.32
792	163.59(1.90)	323.29	68.00	255.29	110.63
794	35.91(1.90)	323.60	55.00	268.60	116.39
796	35.53(1.90)	324.22	56.00	268.22	116.23
798	184.68(1.90)	323.53	68.00	255.53	110.73
800	76.76(1.90)	323.91	82.00	241.91	104.83
804	0.00	326.47	84.00	242.47	105.07
808	0.00	325.54	84.00	241.54	104.67
812	0.00	324.79	58.00	266.79	115.61
816	56.24(1.90)	324.79	64.00	260.79	113.01
820	0.00	325.18	86.00	239.18	103.64
0	----	536.00			
I-CRPRV	0.00	535.97	102.50	433.47	187.84
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.58	49.80	485.78	210.50
I-700	0.00	369.19	88.00	281.19	121.85
I-701	0.00	359.41	88.00	271.41	117.61
O-702	0.00	362.61	69.00	293.61	127.23
O-703	0.00	326.19	69.00	257.19	111.45
O-704	0.00	355.64	58.00	297.64	128.98
O-705	0.00	323.58	58.00	265.58	115.08
O-706	0.00	355.81	54.00	301.81	130.79
O-707	0.00	323.73	54.00	269.73	116.88
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.57	100.80	434.77	188.40
O-OPRS	----	389.03	49.80	339.23	147.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.50	724	93.81
28	207.87	820	103.64
24	188.79	O-701	103.81
I-FRPRS	188.40	808	104.67
I-CRPRV	187.84	800	104.83

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
135	15.62	877	0.07
729	12.76	793	0.13
141	11.71	805	0.25
702	10.00	831	0.27
700	7.49	45	0.27

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.84	124.00	1489.19
FRPRS	PRV-1	125.00	ACTIVATED	188.40	125.00	1535.33
OPRS	PRV-1	147.00	ACTIVATED	210.50	147.00	3145.28

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
 (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6169.80	

NET SYSTEM INFLOW = 6169.80
 NET SYSTEM OUTFLOW = 0.00
 NET SYSTEM DEMAND = 6169.80

=====
 Case: 9

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 9)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 125 is OPENED

RESULTS OBTAINED AFTER 13 TRIALS: ACCURACY = 0.72117E-06

**SDSU Mission Valley Project
 Ultimate Water System Analysis
 Peak Hour Demand**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	N O D E N U M B E R S		F L O W R A T E gpm	H E A D L O S S ft	M I N O R L O S S ft	L I N E V E L O . ft/s	H L + M L / 1000 ft/f	H L / 1000 ft/f
	#1	#2						
21	0	I-CRPRV	325.44	0.00	0.00	0.10	0.00	0.00
41	24	I-FRPRS	1050.12	0.04	0.00	1.68	0.79	0.79
45	28	24	1050.12	0.02	0.00	0.19	0.00	0.00
49	28	I-OPRS	4896.09	0.26	0.00	7.81	13.73	13.73
53	0	28	5946.21	0.47	0.00	1.05	0.09	0.09
101	O-CRPRV	104	325.44	1.31	0.00	0.92	0.37	0.37
105	104	108	100.44	0.02	0.00	0.28	0.04	0.04
109	108	112	-12.06	0.00	0.00	0.02	0.00	0.00
117	112	I-706	1256.91	3.06	0.00	8.02	32.36	32.36
121	116	112	1268.97	1.20	0.00	2.02	1.13	1.13
125	120	116	2751.71	0.30	0.00	4.39	4.72	4.72
127	120	O-OPRS	-4896.09	0.20	0.00	7.81	13.73	13.73
129	124	120	-2144.38	0.50	0.00	3.42	2.98	2.98
131	116	I-704	1482.74	2.07	0.00	9.46	43.94	43.94
133	124	126	2144.38	2.85	0.00	3.42	2.98	2.98
135	126	I-702	1287.37	1.73	0.00	8.22	33.83	33.83
137	126	128	857.01	0.29	0.00	1.37	0.54	0.54
139	128	130	-87.99	0.08	0.00	0.25	0.03	0.03
141	130	I-700	962.13	3.63	0.00	6.14	19.73	19.73
143	130	132	-1050.12	3.98	0.00	2.98	3.22	3.22
145	132	O-FRPRS	-1050.12	0.02	0.00	1.68	0.79	0.79
700	O-700	I-701	962.13	0.33	0.00	3.93	6.65	6.65
701	O-701	804	962.13	0.33	0.00	2.73	2.74	2.74
702	O-702	I-703	1287.37	0.45	0.00	5.26	11.41	11.41
703	O-703	708	1287.37	0.43	0.00	3.65	4.70	4.70
704	O-704	I-705	1482.74	0.67	0.00	6.06	14.82	14.82
705	O-705	714	1482.74	2.14	0.00	4.21	6.10	6.10
706	O-706	I-707	1256.91	0.83	0.00	5.13	10.92	10.92
707	O-707	744	1256.91	1.25	0.00	3.57	4.49	4.49
709	710	708	-469.04	0.03	0.00	1.33	0.72	0.72
713	710	712	131.80	0.02	0.00	0.37	0.07	0.07
715	712	714	131.80	0.03	0.00	0.37	0.07	0.07
717	714	716	1614.54	0.14	0.00	4.58	7.14	7.14
721	716	720	1217.69	1.09	0.00	3.45	4.24	4.24
725	720	710	-337.24	1.27	0.00	2.15	2.83	2.83
729	720	724	617.40	4.10	0.00	3.94	8.67	8.67
733	740	716	-309.10	0.37	0.00	0.88	0.33	0.33
737	740	744	-131.59	0.02	0.00	0.37	0.07	0.07
745	744	752	1125.31	1.28	0.00	3.19	3.66	3.66

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

749	752	756	94.05	0.11	0.00	0.60	0.27	0.27
753	756	736	-347.27	0.12	0.00	2.22	2.99	2.99
757	736	740	-440.69	1.25	0.00	2.81	4.65	4.65
761	732	736	-93.43	0.12	0.00	0.60	0.26	0.26
765	728	732	196.04	0.48	0.00	1.25	1.04	1.04
769	720	728	422.28	0.17	0.00	1.20	0.60	0.60
773	708	728	818.33	1.47	0.00	2.32	2.03	2.03
777	772	728	-1044.57	1.01	0.00	2.96	3.19	3.19
781	772	776	284.85	0.43	0.00	1.82	2.07	2.07
785	780	772	-76.21	0.01	0.00	0.22	0.03	0.03
789	768	772	-105.72	0.15	0.00	0.67	0.33	0.33
793	732	768	289.46	0.68	0.00	1.85	2.13	2.13
797	768	784	-54.67	0.02	0.00	0.35	0.10	0.10
801	764	768	116.25	0.18	0.00	0.74	0.39	0.39
805	756	764	264.92	0.50	0.00	1.69	1.81	1.81
809	788	764	-156.11	0.17	0.00	1.00	0.68	0.68
813	764	760	-7.44	0.00	0.00	0.05	0.00	0.00
817	760	752	-835.51	0.60	0.00	2.37	2.11	2.11
821	760	792	426.67	0.17	0.00	1.21	0.61	0.61
825	792	794	-23.74	0.00	0.00	0.07	0.00	0.00
827	794	796	-108.79	0.05	0.00	0.31	0.05	0.05
829	796	816	-192.94	0.11	0.00	0.55	0.14	0.14
831	792	788	62.97	0.01	0.00	0.18	0.02	0.02
833	788	798	177.40	0.25	0.00	1.13	0.86	0.86
837	784	788	80.73	0.01	0.00	0.23	0.03	0.03
841	780	784	270.39	0.12	0.00	0.77	0.26	0.26
845	800	780	194.19	0.04	0.00	0.55	0.14	0.14
849	798	800	-124.79	0.42	0.00	0.80	0.45	0.45
853	804	800	500.78	0.64	0.00	1.42	0.82	0.82
857	812	798	135.21	0.42	0.00	0.86	0.52	0.52
861	808	812	152.43	0.29	0.00	0.97	0.65	0.65
865	808	804	-461.35	0.36	0.00	1.31	0.70	0.70
869	820	808	-308.92	0.14	0.00	0.88	0.33	0.33
873	816	820	-308.92	0.15	0.00	0.88	0.33	0.33
877	816	812	-17.23	0.00	0.00	0.11	0.01	0.01

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	962.13	293.63	288.39	-5.2
701	962.13	288.06	256.05	-32.0
702	1287.37	314.74	308.64	-6.1
703	1287.37	308.19	276.95	-31.2
704	1482.74	328.45	321.60	-6.8
705	1482.74	320.93	289.58	-31.3
706	1256.91	330.26	324.26	-6.0
707	1256.91	323.44	292.21	-31.2

SDSU Mission Valley Project
Ultimate Water System Analysis (505166B5)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.51	100.00	435.51	188.72
28		0.00	535.53	56.00	479.53	207.79
104		225.00(4.50)	387.35	117.00	270.35	117.15
108		112.50(4.50)	387.33	87.00	300.33	130.14
112		0.00	387.33	54.00	333.33	144.44
116		0.00	388.53	54.00	334.53	144.96
120		0.00	388.83	50.00	338.83	146.83
124		0.00	388.32	58.00	330.32	143.14
126		0.00	385.47	69.00	316.47	137.14
128		945.00(4.50)	385.18	70.00	315.18	136.58
130		0.00	385.26	95.00	290.26	125.78
132		0.00	389.24	100.00	289.24	125.34
O-700		0.00	376.39	88.00	288.39	124.97
O-701		0.00	344.05	88.00	256.05	110.95
I-702		0.00	383.74	69.00	314.74	136.39
I-703		0.00	377.19	69.00	308.19	133.55
I-704		0.00	386.45	58.00	328.45	142.33
I-705		0.00	378.93	58.00	320.93	139.07
I-706		0.00	384.26	54.00	330.26	143.11
I-707		0.00	377.44	54.00	323.44	140.16
708		0.00	345.53	75.00	270.53	117.23
710		0.00	345.50	75.00	270.50	117.22
712		0.00	345.48	75.00	270.48	117.21
714		0.00	345.45	71.00	274.45	118.93
716		87.75(4.50)	345.31	71.00	274.31	118.87
720		515.25(4.50)	344.22	71.00	273.22	118.40
724		617.40(4.50)	340.12	68.00	272.12	117.92
728		0.00	344.05	71.00	273.05	118.32
732		0.00	343.57	67.00	276.57	119.85
736		0.00	343.69	65.00	278.69	120.77
740		0.00	344.94	65.00	279.94	121.31
744		0.00	344.96	63.00	281.96	122.18
752		195.75(4.50)	343.68	63.00	280.68	121.63
756		176.40(4.50)	343.58	65.00	278.58	120.72
760		401.40(4.50)	343.08	63.00	280.08	121.37
764		0.00	343.08	65.00	278.08	120.50
768		566.10(4.50)	342.89	67.00	275.89	119.55
772		577.80(4.50)	343.05	71.00	272.05	117.89
776		284.85(4.50)	342.62	74.00	268.62	116.40
780		0.00	343.04	77.00	266.04	115.28
784		135.00(4.50)	342.92	74.00	268.92	116.53
788		122.40(4.50)	342.91	71.00	271.91	117.83
792		387.45(4.50)	342.91	68.00	274.91	119.13
794		85.05(4.50)	342.91	55.00	287.91	124.76
796		84.15(4.50)	342.96	56.00	286.96	124.35
798		437.40(4.50)	342.66	68.00	274.66	119.02
800		181.80(4.50)	343.08	82.00	261.08	113.13
804		0.00	343.72	84.00	259.72	112.54
808		0.00	343.36	84.00	259.36	112.39
812		0.00	343.07	58.00	285.07	123.53
816		133.20(4.50)	343.07	64.00	279.07	120.93
820		0.00	343.22	86.00	257.22	111.46
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	389.26	100.80	288.46	125.00

**SDSU Mission Valley Project
 Ultimate Water System Analysis (505166B5)
 Average Day, Maximum Day plus Fire Flow, and
 Peak Hour Demand Scenarios**

**April 18, 2019
 Dexter Wilson Engr., Inc.
 Job No. 505-166**

I-OPRS	0.00	535.26	49.80	485.46	210.37
I-700	0.00	381.63	88.00	293.63	127.24
I-701	0.00	376.06	88.00	288.06	124.83
O-702	0.00	377.64	69.00	308.64	133.75
O-703	0.00	345.95	69.00	276.95	120.01
O-704	0.00	379.60	58.00	321.60	139.36
O-705	0.00	347.58	58.00	289.58	125.49
O-706	0.00	378.26	54.00	324.26	140.51
O-707	0.00	346.21	54.00	292.21	126.62
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.46	100.80	434.66	188.35
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.37	O-701	110.95
28	207.79	820	111.46
24	188.72	808	112.39
I-FRPRS	188.35	804	112.54
I-CRPRV	187.85	800	113.13

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
131	9.46	109	0.02
135	8.22	813	0.05
117	8.02	825	0.07
49	7.81	21	0.10
127	7.81	877	0.11

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	325.44
FRPRS	PRV-1	125.00	ACTIVATED	188.35	125.00	1050.12
OPRS	PRV-1	147.00	ACTIVATED	210.37	147.00	4896.09

SDSU Mission Valley Project
Ultimate Water System Analysis (505166B5)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

- (+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
- (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	6271.65	

NET SYSTEM INFLOW = 6271.65
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 6271.65

APPENDIX G

**BUILD-OUT WATER SYSTEM
DETAILED COMPUTER MODEL RESULTS SUMMARY
FOR PUBLIC SYSTEM CONNECTION POINTS**

SDSU MISSION VALLEY BUILD-OUT WATER SYSTEM DETAILED COMPUTER MODEL RESULTS SUMMARY FOR PUBLIC SYSTEM				
Meter	Lateral Flow, gpm	Lateral Velocity, fps	Residual Pressure at Connection Point, psi	Pressure Drop at Connection Point, psi
Average Day Demand				
A	255.3	1.6	127.3	0.5
B	283.1	1.8	138.6	0.5
C	300.4	1.9	145.2	0.4
D	269.9	1.7	145.1	0.5
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820				
A	1538.6	9.8	125.3	2.5
B	1477.1	9.4	137.1	2.0
C	1628.5	10.4	144.9	0.6
D	1462.4	9.3	144.4	1.2
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 794 and 796				
A	1388.5	8.9	125.5	2.3
B	1507.3	9.6	137.1	2.0
C	1641.8	10.5	144.9	0.6
D	1497.4	9.6	144.4	1.2
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 784 and 788				
A	1337.4	8.5	125.6	2.2
B	1520.8	9.7	137.1	2.0
C	1647.4	10.5	144.9	0.6
D	1492.2	9.5	144.4	1.2
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 780 and 800				
A	1375.2	8.8	125.5	2.3
B	1528.9	9.8	137.1	2.0
C	1655.7	10.6	144.9	0.6
D	1469.9	9.4	144.4	1.2
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 720 and 724				
A	1071.6	6.8	126.0	1.9
B	1550.6	9.9	137.3	1.8
C	1647.3	10.5	145.0	0.6
D	1358.8	8.7	144.5	1.1
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820 with Pipe 143 closed				
A	1149.0	7.3	120.2	7.6
B	1488.5	9.5	135.8	3.3
C	1825.5	11.7	144.9	0.7
D	1643.5	10.5	144.2	1.4
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 720 and 724 with Pipe 129 closed				
A	1090.2	7.0	122.0	5.9
B	479.6	3.1	130.8	8.3
C	2199.5	14.0	144.9	0.7
D	1859.0	11.9	144.1	1.5
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 720 and 724 with Pipe 125 closed				
A	1834.4	11.7	124.0	3.8
B	2447.3	15.6	135.7	3.4
C	710.0	4.5	133.6	12.0
D	636.7	4.1	133.8	11.8
Peak Hour Demand				
A	962.1	6.1	125.8	2.0
B	1287.4	8.2	137.1	1.9
C	1482.7	9.5	145.0	0.6
D	1256.9	8.0	144.4	1.1

APPENDIX H

PHASE 1 WATER SYSTEM COMPUTER MODELING OUTPUT

NODE AND PIPE DIAGRAM REFERENCE:

Exhibit B

CONDITIONS MODELED:

1. Average Day Demand
2. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820.
3. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 788 and 798.
4. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 728 and 772.
5. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820 with Pipe 143 closed.
6. Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 788 and 798 with Pipe 125 closed.
7. Peak Hour Demand

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Average Day Demand

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	0	0
41	16	219.09	0.35
45	48	219.09	0.04
49	16	417.31	0.67
53	48	636.4	0.11
101	12	0	0
105	12	-50	0.14
109	16	-75	0.12
121	16	75	0.12
125	16	184.87	0.29
127	16	-417.31	0.67
129	16	-232.44	0.37
131	8	109.87	0.7
133	16	232.44	0.37
135	8	109.54	0.7
137	16	122.9	0.2
139	12	-87.1	0.25
141	8	131.99	0.84
143	12	-219.09	0.62
145	16	-219.09	0.35

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	0	0
41	16	1544.34	2.46
45	48	1544.34	0.27
49	16	3919.38	6.25
53	48	5463.72	0.97
101	12	0	0
105	12	-115	0.33
109	16	-172.5	0.28
121	16	172.5	0.28
125	16	1457.7	2.33
127	16	-3919.38	6.25
129	16	-2461.68	3.93
131	8	1285.2	8.2
133	16	2461.68	3.93
135	8	1344.61	8.58
137	16	1117.07	1.78
139	12	634.07	1.8
141	8	2178.41	13.9
143	12	-1544.34	4.38
145	16	-1544.34	2.46

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 788 and 798

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	0	0
41	16	1431.25	2.28
45	48	1431.25	0.25
49	16	3808.91	6.08
53	48	5240.16	0.93
101	12	0	0
105	12	-115	0.33
109	16	-172.5	0.28
121	16	172.5	0.28
125	16	1436.26	2.29
127	16	-3808.91	6.08
129	16	-2372.65	3.79
131	8	1263.76	8.07
133	16	2372.65	3.79
135	8	1342.23	8.57
137	16	1030.42	1.64
139	12	547.42	1.55
141	8	1978.67	12.63
143	12	-1431.25	4.06
145	16	-1431.25	2.28

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 728 and 772

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	0	0
41	16	1356.67	2.16
45	48	1356.67	0.24
49	16	4107.05	6.55
53	48	5463.72	0.97
101	12	0	0
105	12	-115	0.33
109	16	-172.5	0.28
121	16	172.5	0.28
125	16	1617.1	2.58
127	16	-4107.05	6.55
129	16	-2489.94	3.97
131	8	1444.6	9.22
133	16	2489.94	3.97
135	8	1600.58	10.22
137	16	889.37	1.42
139	12	406.37	1.15
141	8	1763.04	11.25
143	12	-1356.67	3.85
145	16	-1356.67	2.16

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (143) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	47.4	0.01
41	16	0	0
45	48	0	0
49	16	5416.32	8.64
53	48	5416.32	0.96
101	12	47.4	0.13
105	12	-67.6	0.19
109	16	-125.1	0.2
121	16	125.1	0.2
125	16	1729.59	2.76
127	16	-5416.32	8.64
129	16	-3686.74	5.88
131	8	1604.48	10.24
133	16	3686.74	5.88
135	8	1401.7	8.95
137	16	2285.03	3.65
139	12	1802.03	5.11
141	8	1802.03	11.5
143-XX	12		
145	16	0	0

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (125) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 788 and 798

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	875.53	0.28
41	16	1559.24	2.49
45	48	1559.24	0.28
49	16	2805.39	4.48
53	48	4364.63	0.77
101	12	875.53	2.48
105	12	760.53	2.16
109	16	703.03	1.12
121	16	-703.03	1.12
125-XX	16		
127	16	-2805.39	4.48
129	16	-2805.39	4.48
131	8	703.03	4.49
133	16	2805.39	4.48
135	8	1798.58	11.48
137	16	1006.8	1.61
139	12	523.8	1.49
141	8	2083.04	13.29
143	12	-1559.24	4.42
145	16	-1559.24	2.49

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Peak Hour Demand

Pipe No.	Pipe Size (inches)	Model Run Flow (gpm)	Model Run Velocity (fps)
21	36	42.99	0.01
41	16	823.58	1.31
45	48	823.58	0.15
49	16	2506.35	4
53	48	3329.93	0.59
101	12	42.99	0.12
105	12	-222.01	0.63
109	16	-354.51	0.57
121	16	354.51	0.57
125	16	962.19	1.54
127	16	-2506.35	4
129	16	-1544.16	2.46
131	8	607.68	3.88
133	16	1544.16	2.46
135	8	461.6	2.95
137	16	1082.56	1.73
139	12	-30.44	0.09
141	8	793.14	5.06
143	12	-823.58	2.34
145	16	-823.58	1.31

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Average Day Demand

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.9	0.0
28	56	536	208.0	208.0	0.0
104	117	390	118.3	117.9	0.4
108	87	390	131.3	130.9	0.4
112	54	390	145.6	145.2	0.4
116	54	390	145.6	145.2	0.4
120	50	390	147.3	146.9	0.4
124	58	390	143.8	143.4	0.4
126	69	390	139.1	138.7	0.4
128	70	390	138.6	138.2	0.4
130	95	390	127.8	127.4	0.4
132	100	390	125.6	125.4	0.3

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.7	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.8	0.5
108	87	390	131.3	130.8	0.5
112	54	390	145.6	145.1	0.5
116	54	390	145.6	145.1	0.5
120	50	390	147.3	146.9	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	136.7	2.3
128	70	390	138.6	136.1	2.5
130	95	390	127.8	124.0	3.8
132	100	390	125.6	125.3	0.3

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 788 and 798

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.8	0.1
28	56	536	208.0	207.8	0.1
104	117	390	118.3	117.8	0.5
108	87	390	131.3	130.8	0.5
112	54	390	145.6	145.1	0.5
116	54	390	145.6	145.1	0.5
120	50	390	147.3	146.9	0.5
124	58	390	143.8	143.1	0.7
126	69	390	139.1	136.9	2.2
128	70	390	138.6	136.3	2.4
130	95	390	127.8	124.4	3.4
132	100	390	125.6	125.3	0.3

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 728 and 772

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.8	0.2
28	56	536	208.0	207.8	0.2
104	117	390	118.3	117.7	0.6
108	87	390	131.3	130.7	0.5
112	54	390	145.6	145.1	0.5
116	54	390	145.6	145.1	0.5
120	50	390	147.3	146.9	0.5
124	58	390	143.8	143.1	0.8
126	69	390	139.1	136.7	2.4
128	70	390	138.6	136.1	2.5
130	95	390	127.8	124.7	3.1
132	100	390	125.6	125.3	0.3

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (143) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 808 and 820

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.8	0.1
28	56	536	208.0	207.8	0.1
104	117	390	118.3	117.7	0.6
108	87	390	131.3	130.7	0.6
112	54	390	145.6	145.0	0.6
116	54	390	145.6	145.0	0.6
120	50	390	147.3	146.8	0.5
124	58	390	143.8	142.7	1.1
126	69	390	139.1	134.6	4.5
128	70	390	138.6	133.4	5.2
130	95	390	127.8	113.6	14.2
132	100	536	188.9	188.8	0.1

Date: 04/18/19

Job Number: 505-166

Scenario: Pipe Break (125) - Max Day Demand Plus 4000 gpm Fire Flow split between Nodes 788 and 798

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.8	0.1
28	56	536	208.0	207.9	0.1
104	117	390	118.3	114.2	4.1
108	87	390	131.3	126.8	4.5
112	54	390	145.6	140.9	4.7
116	54	390	145.6	140.8	4.8
120	50	390	147.3	146.9	0.4
124	58	390	143.8	143.1	0.8
126	69	390	139.1	136.3	2.8
128	70	390	138.6	135.7	3.0
130	95	390	127.8	123.9	3.9
132	100	390	125.6	125.3	0.3

Date: 04/18/19

Job Number: 505-166

Scenario: All Pipes Open - Peak Hour Demand

Node No.	Node El. Ft.	HGL Zone Ft. (Static)	Static P psi	Model Run P, psi	Delta P from Static
24	100	536	188.9	188.9	0.0
28	56	536	208.0	207.9	0.0
104	117	390	118.3	117.7	0.6
108	87	390	131.3	130.8	0.5
112	54	390	145.6	145.1	0.5
116	54	390	145.6	145.1	0.4
120	50	390	147.3	146.9	0.4
124	58	390	143.8	143.3	0.5
126	69	390	139.1	137.9	1.2
128	70	390	138.6	137.2	1.4
130	95	390	127.8	126.4	1.4
132	100	390	125.6	125.3	0.3

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

U N I T S S P E C I F I E D

FLOWRATE = gallons/minute
HEAD (HGL) = feet
PRESSURE = psig

R E G U L A T I N G V A L V E D A T A

VALVE LABEL	VALVE TYPE	VALVE SETTING (ft or gpm)
CRPRV	PRV-1	388.65
FRPRS	PRV-1	389.26
OPRS	PRV-1	389.03

P I P E L I N E D A T A

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E NAME	NODE #1	NODE #2	LENGTH (ft)	DIAMETER (in)	ROUGHNESS COEFF.	MINOR LOSS COEFF.
21	0	I-CRPRV	860.20	36.00	120.0000	0.00
41	24	I-FRPRS	56.50	16.00	120.0000	0.00
45	28	24	4114.40	48.00	120.0000	0.00
49	28	I-OPRS	19.30	16.00	120.0000	0.00
53	0	28	5084.10	48.00	120.0000	0.00
101	O-CRPRV	104	3549.60	12.00	120.0000	0.00
105	104	108	537.90	12.00	120.0000	0.00
109	108	112	897.10	16.00	120.0000	0.00
121	116	112	1065.20	16.00	120.0000	0.00
125	120	116	63.90	16.00	120.0000	0.00
127	120	O-OPRS	14.80	16.00	120.0000	0.00
129	124	120	169.50	16.00	120.0000	0.00
131	116	I-704	47.20	8.00	120.0000	0.00
133	124	126	957.70	16.00	120.0000	0.00
135	126	I-702	51.10	8.00	120.0000	0.00
137	126	128	531.20	16.00	120.0000	0.00
139	128	130	2373.60	12.00	120.0000	0.00
141	130	I-700	183.90	8.00	120.0000	0.00
143	130	132	1236.90	12.00	120.0000	0.00
145	132	O-FRPRS	22.10	16.00	120.0000	0.00
700	O-700	I-701	49.00	10.00	120.0000	0.00
701	O-701	804	120.90	12.00	120.0000	0.00
702	O-702	I-703	39.80	10.00	120.0000	0.00
703	O-703	708	90.60	12.00	120.0000	0.00
704	O-704	I-705	45.30	10.00	120.0000	0.00
705	O-705	714	350.30	12.00	120.0000	0.00
709	710	708	41.50	12.00	120.0000	0.00
713	710	712	317.30	12.00	120.0000	0.00
715	712	714	399.80	12.00	120.0000	0.00
773	708	728	726.40	12.00	120.0000	0.00
777	772	728	315.90	12.00	120.0000	0.00
785	780	772	258.40	12.00	120.0000	0.00
833	788	798	286.20	8.00	120.0000	0.00

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

837	784	788	467.90	12.00	120.0000	0.00
841	780	784	467.20	12.00	120.0000	0.00
845	800	780	272.70	12.00	120.0000	0.00
853	804	800	782.00	12.00	120.0000	0.00
857	812	798	797.00	8.00	120.0000	0.00
861	808	812	440.70	8.00	120.0000	0.00
865	808	804	509.80	12.00	120.0000	0.00
869	820	808	420.20	12.00	120.0000	0.00
873	816	820	449.10	12.00	120.0000	0.00
877	816	812	323.30	8.00	120.0000	0.00

P U M P / L O S S E L E M E N T D A T A

THERE IS A DEVICE AT NODE 700 DESCRIBED BY THE FOLLOWING DATA: (ID= 8" Badger FSAA)

HEAD (ft)	FLOWRATE (gpm)
0.00	0.00
-4.62	100.00
-6.92	1500.00
-20.77	3000.00
-36.92	4000.00

THERE IS A DEVICE AT NODE 701 DESCRIBED BY THE FOLLOWING DATA: (ID= 10" Wilkins 375DA)

HEAD (ft)	FLOWRATE (gpm)
-23.08	0.00
-31.15	100.00
-32.31	2000.00
-46.15	3100.00

THERE IS A DEVICE AT NODE 702> (ID= 8" Badger FSAA)

THERE IS A DEVICE AT NODE 703> (ID= 10" Wilkins 375DA)

THERE IS A DEVICE AT NODE 704> (ID= 8" Badger FSAA)

THERE IS A DEVICE AT NODE 705> (ID= 10" Wilkins 375DA)

N O D E D A T A

NODE NAME	NODE TITLE	EXTERNAL DEMAND (gpm)	JUNCTION ELEVATION (ft)	EXTERNAL GRADE (ft)
24		0.00	100.00	
28		0.00	56.00	
104		50.00	117.00	
108		25.00	87.00	
112		0.00	54.00	
116		0.00	54.00	
120		0.00	50.00	
124		0.00	58.00	
126		0.00	69.00	

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

128	210.00	70.00	
130	0.00	95.00	
132	0.00	100.00	
O-700	0.00	88.00	
O-701	0.00	88.00	
I-702	0.00	69.00	
I-703	0.00	69.00	
I-704	0.00	58.00	
I-705	0.00	58.00	
708	0.00	75.00	
710	0.00	75.00	
712	0.00	75.00	
714	0.00	71.00	
728	0.00	71.00	
772	0.00	71.00	
780	0.00	77.00	
784	254.20	74.00	
788	0.00	71.00	
798	97.20	68.00	
800	0.00	82.00	
804	0.00	84.00	
808	0.00	84.00	
812	0.00	58.00	
816	0.00	64.00	
820	0.00	86.00	
0	----	0.00	536.00
I-CRPRV	0.00	102.50	
O-FRPRS	----	100.80	389.26
I-OPRS	0.00	49.80	
I-700	0.00	88.00	
I-701	0.00	88.00	
O-702	0.00	69.00	
O-703	0.00	69.00	
O-704	0.00	58.00	
O-705	0.00	58.00	
O-CRPRV	----	102.50	388.65
I-FRPRS	0.00	100.80	
O-OPRS	----	49.80	389.03

O U T P U T O P T I O N D A T A

OUTPUT SELECTION: ALL RESULTS ARE INCLUDED IN THE TABULATED OUTPUT
MAXIMUM AND MINIMUM PRESSURES = 5
MAXIMUM AND MINIMUM VELOCITIES = 5

S Y S T E M C O N F I G U R A T I O N

NUMBER OF PIPES (P) = 43
NUMBER OF END NODES (J) = 37
NUMBER OF PRIMARY LOOPS (L) = 6
NUMBER OF SUPPLY NODES (F) = 1
NUMBER OF SUPPLY ZONES (Z) = 1

=====
Case: 0

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

RESULTS OBTAINED AFTER 20 TRIALS: ACCURACY = 0.11958E-05

**SDSU Mission Valley Project
Phase 1 Water System Analysis
Average Day Demand**

PIPELINE RESULTS

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

PIPE NAME	NODE NUMBERS		FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
	#1	#2						
21	0	I-CRPRV	0.00	0.00	0.00	0.00	0.00	0.00
41	24	I-FRPRS	219.09	0.00	0.00	0.35	0.04	0.04
45	28	24	219.09	0.00	0.00	0.04	0.00	0.00
49	28	I-OPRS	417.31	0.00	0.00	0.67	0.14	0.14
53	0	28	636.40	0.01	0.00	0.11	0.00	0.00
101	O-CRPRV	104	0.00	0.00	0.00	0.00	0.00	0.00
105	104	108	-50.00	0.01	0.00	0.14	0.01	0.01
109	108	112	-75.00	0.01	0.00	0.12	0.01	0.01
121	116	112	75.00	0.01	0.00	0.12	0.01	0.01
125	120	116	184.87	0.00	0.00	0.29	0.03	0.03
127	120	O-OPRS	-417.31	0.00	0.00	0.67	0.14	0.14
129	124	120	-232.44	0.01	0.00	0.37	0.05	0.05
131	116	I-704	109.87	0.02	0.00	0.70	0.35	0.35
133	124	126	232.44	0.05	0.00	0.37	0.05	0.05
135	126	I-702	109.54	0.02	0.00	0.70	0.35	0.35
137	126	128	122.90	0.01	0.00	0.20	0.01	0.01
139	128	130	-87.10	0.08	0.00	0.25	0.03	0.03
141	130	I-700	131.99	0.09	0.00	0.84	0.50	0.50
143	130	132	-219.09	0.22	0.00	0.62	0.18	0.18
145	132	O-FRPRS	-219.09	0.00	0.00	0.35	0.04	0.04
700	O-700	I-701	131.99	0.01	0.00	0.54	0.17	0.17
701	O-701	804	131.99	0.01	0.00	0.37	0.07	0.07
702	O-702	I-703	109.54	0.00	0.00	0.45	0.12	0.12
703	O-703	708	109.54	0.00	0.00	0.31	0.05	0.05
704	O-704	I-705	109.87	0.01	0.00	0.45	0.12	0.12
705	O-705	714	109.87	0.02	0.00	0.31	0.05	0.05
709	710	708	109.87	0.00	0.00	0.31	0.05	0.05
713	710	712	-109.87	0.02	0.00	0.31	0.05	0.05
715	712	714	-109.87	0.02	0.00	0.31	0.05	0.05
773	708	728	219.41	0.13	0.00	0.62	0.18	0.18
777	772	728	-219.41	0.06	0.00	0.62	0.18	0.18
785	780	772	-219.41	0.05	0.00	0.62	0.18	0.18
833	788	798	26.17	0.01	0.00	0.17	0.02	0.02
837	784	788	26.17	0.00	0.00	0.07	0.00	0.00
841	780	784	280.37	0.13	0.00	0.80	0.28	0.28
845	800	780	60.96	0.00	0.00	0.17	0.02	0.02
853	804	800	60.96	0.01	0.00	0.17	0.02	0.02
857	812	798	71.03	0.13	0.00	0.45	0.16	0.16
861	808	812	35.58	0.02	0.00	0.23	0.04	0.04
865	808	804	-71.03	0.01	0.00	0.20	0.02	0.02
869	820	808	-35.44	0.00	0.00	0.10	0.01	0.01
873	816	820	-35.44	0.00	0.00	0.10	0.01	0.01
877	816	812	35.44	0.01	0.00	0.23	0.04	0.04

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	131.99	300.95	296.14	-4.8
701	131.99	296.13	264.88	-31.3
702	109.54	319.96	315.28	-4.7
703	109.54	315.27	284.09	-31.2
704	109.87	331.01	326.33	-4.7
705	109.87	326.32	295.14	-31.2

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.99	100.00	435.99	188.93
28		0.00	535.99	56.00	479.99	208.00
104		50.00	389.01	117.00	272.01	117.87
108		25.00	389.01	87.00	302.01	130.87
112		0.00	389.02	54.00	335.02	145.18
116		0.00	389.03	54.00	335.03	145.18
120		0.00	389.03	50.00	339.03	146.91
124		0.00	389.02	58.00	331.02	143.44
126		0.00	388.97	69.00	319.97	138.66
128		210.00	388.97	70.00	318.97	138.22
130		0.00	389.04	95.00	294.04	127.42
132		0.00	389.26	100.00	289.26	125.35
O-700		0.00	384.14	88.00	296.14	128.33
O-701		0.00	352.88	88.00	264.88	114.78
I-702		0.00	388.96	69.00	319.96	138.65
I-703		0.00	384.27	69.00	315.27	136.62
I-704		0.00	389.01	58.00	331.01	143.44
I-705		0.00	384.32	58.00	326.32	141.41
708		0.00	353.08	75.00	278.08	120.50
710		0.00	353.08	75.00	278.08	120.50
712		0.00	353.10	75.00	278.10	120.51
714		0.00	353.12	71.00	282.12	122.25
728		0.00	352.95	71.00	281.95	122.18
772		0.00	352.90	71.00	281.90	122.16
780		0.00	352.85	77.00	275.85	119.54
784		254.20	352.72	74.00	278.72	120.78
788		0.00	352.72	71.00	281.72	122.08
798		97.20	352.71	68.00	284.71	123.37
800		0.00	352.86	82.00	270.86	117.37
804		0.00	352.87	84.00	268.87	116.51
808		0.00	352.86	84.00	268.86	116.50
812		0.00	352.84	58.00	294.84	127.76
816		0.00	352.85	64.00	288.85	125.17
820		0.00	352.85	86.00	266.85	115.64
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	389.26	100.80	288.46	125.00
I-OPRS		0.00	535.99	49.80	486.19	210.68

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

I-700	0.00	388.95	88.00	300.95	130.41
I-701	0.00	384.13	88.00	296.13	128.32
O-702	0.00	384.28	69.00	315.28	136.62
O-703	0.00	353.09	69.00	284.09	123.10
O-704	0.00	384.33	58.00	326.33	141.41
O-705	0.00	353.14	58.00	295.14	127.89
O-CRPRV	----	389.01	102.50	286.51	124.15
I-FRPRS	0.00	535.99	100.80	435.19	188.58
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.68	O-701	114.78
28	208.00	820	115.64
24	188.93	808	116.50
I-FRPRS	188.58	804	116.51
I-CRPRV	187.85	800	117.37

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	0.84	45	0.04
841	0.80	837	0.07
131	0.70	869	0.10
135	0.70	873	0.10
49	0.67	53	0.11

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	CLOSED	187.85	124.15	0.00
FRPRS	PRV-1	125.00	ACTIVATED	188.58	125.00	219.09
OPRS	PRV-1	147.00	ACTIVATED	210.68	147.00	417.31

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
(-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	636.40	

NET SYSTEM INFLOW = 636.40
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 636.40

=====
Case: 1

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 1)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 15 TRIALS: ACCURACY = 0.25969E-06

**SDSU Mission Valley Project
Phase 1 Water System Analysis
Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 808 and 820**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE NUMBERS		FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
	#1	#2						
21	0	I-CRPRV	0.00	0.00	0.00	0.00	0.00	0.00
41	24	I-FRPRS	1544.34	0.09	0.00	2.46	1.62	1.62
45	28	24	1544.34	0.03	0.00	0.27	0.01	0.01
49	28	I-OPRS	3919.38	0.18	0.00	6.25	9.09	9.09
53	0	28	5463.72	0.41	0.00	0.97	0.08	0.08
101	O-CRPRV	104	0.00	0.00	0.00	0.00	0.00	0.00
105	104	108	-115.00	0.03	0.00	0.33	0.05	0.05
109	108	112	-172.50	0.03	0.00	0.28	0.03	0.03
121	116	112	172.50	0.03	0.00	0.28	0.03	0.03
125	120	116	1457.70	0.09	0.00	2.33	1.46	1.46
127	120	O-OPRS	-3919.38	0.13	0.00	6.25	9.09	9.09
129	124	120	-2461.68	0.65	0.00	3.93	3.84	3.84
131	116	I-704	1285.20	1.59	0.00	8.20	33.72	33.72
133	124	126	2461.68	3.68	0.00	3.93	3.84	3.84
135	126	I-702	1344.61	1.87	0.00	8.58	36.66	36.66
137	126	128	1117.07	0.47	0.00	1.78	0.89	0.89
139	128	130	634.07	3.00	0.00	1.80	1.26	1.26
141	130	I-700	2178.41	16.48	0.00	13.90	89.60	89.60
143	130	132	-1544.34	8.14	0.00	4.38	6.58	6.58
145	132	O-FRPRS	-1544.34	0.04	0.00	2.46	1.62	1.62

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

700	O-700	I-701	2178.41	1.48	0.00	8.90	30.22	30.22
701	O-701	804	2178.41	1.50	0.00	6.18	12.44	12.44
702	O-702	I-703	1344.61	0.49	0.00	5.49	12.37	12.37
703	O-703	708	1344.61	0.46	0.00	3.81	5.09	5.09
704	O-704	I-705	1285.20	0.52	0.00	5.25	11.37	11.37
705	O-705	714	1285.20	1.64	0.00	3.65	4.68	4.68
709	710	708	1285.20	0.19	0.00	3.65	4.68	4.68
713	710	712	-1285.20	1.49	0.00	3.65	4.68	4.68
715	712	714	-1285.20	1.87	0.00	3.65	4.68	4.68
773	708	728	2629.81	12.81	0.00	7.46	17.63	17.63
777	772	728	-2629.81	5.57	0.00	7.46	17.63	17.63
785	780	772	-2629.81	4.56	0.00	7.46	17.63	17.63
833	788	798	908.62	5.08	0.00	5.80	17.74	17.74
837	784	788	908.62	1.15	0.00	2.58	2.46	2.46
841	780	784	1493.28	2.89	0.00	4.24	6.18	6.18
845	800	780	-1136.53	1.02	0.00	3.22	3.73	3.73
853	804	800	-1136.53	2.92	0.00	3.22	3.73	3.73
857	812	798	-685.06	8.38	0.00	4.37	10.52	10.52
861	808	812	-135.83	0.23	0.00	0.87	0.53	0.53
865	808	804	-3314.94	13.80	0.00	9.40	27.07	27.07
869	820	808	-1450.77	2.46	0.00	4.12	5.86	5.86
873	816	820	549.23	0.44	0.00	1.56	0.97	0.97
877	816	812	-549.23	2.26	0.00	3.51	6.98	6.98

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	2178.41	276.61	265.36	-11.2
701	2178.41	263.88	230.82	-33.1
702	1344.61	313.69	307.39	-6.3
703	1344.61	306.90	275.64	-31.3
704	1285.20	329.21	323.12	-6.1
705	1285.20	322.60	291.37	-31.2

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.56	100.00	435.56	188.74
28		0.00	535.59	56.00	479.59	207.82
104		115.00 (2.30)	388.72	117.00	271.72	117.75
108		57.50 (2.30)	388.75	87.00	301.75	130.76
112		0.00	388.77	54.00	334.77	145.07
116		0.00	388.80	54.00	334.80	145.08
120		0.00	388.90	50.00	338.90	146.86
124		0.00	388.24	58.00	330.24	143.11
126		0.00	384.56	69.00	315.56	136.74
128		483.00 (2.30)	384.09	70.00	314.09	136.11
130		0.00	381.09	95.00	286.09	123.97
132		0.00	389.23	100.00	289.23	125.33

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

O-700	0.00	353.36	88.00	265.36	114.99
O-701	0.00	318.82	88.00	230.82	100.02
I-702	0.00	382.69	69.00	313.69	135.93
I-703	0.00	375.90	69.00	306.90	132.99
I-704	0.00	387.21	58.00	329.21	142.66
I-705	0.00	380.60	58.00	322.60	139.79
708	0.00	344.18	75.00	269.18	116.64
710	0.00	344.37	75.00	269.37	116.73
712	0.00	345.86	75.00	270.86	117.37
714	0.00	347.73	71.00	276.73	119.92
728	0.00	331.37	71.00	260.37	112.83
772	0.00	325.80	71.00	254.80	110.41
780	0.00	321.25	77.00	244.25	105.84
784	584.66 (2.30)	318.36	74.00	244.36	105.89
788	0.00	317.21	71.00	246.21	106.69
798	223.56 (2.30)	312.13	68.00	244.13	105.79
800	0.00	320.23	82.00	238.23	103.23
804	0.00	317.32	84.00	233.32	101.10
808	2000.00	303.52	84.00	219.52	95.12
812	0.00	303.75	58.00	245.75	106.49
816	0.00	301.49	64.00	237.49	102.91
820	2000.00	301.06	86.00	215.06	93.19
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.42	49.80	485.62	210.43
I-700	0.00	364.61	88.00	276.61	119.87
I-701	0.00	351.88	88.00	263.88	114.35
O-702	0.00	376.39	69.00	307.39	133.20
O-703	0.00	344.64	69.00	275.64	119.44
O-704	0.00	381.12	58.00	323.12	140.02
O-705	0.00	349.37	58.00	291.37	126.26
O-CRPRV	----	388.72	102.50	286.22	124.03
I-FRPRS	0.00	535.47	100.80	434.67	188.36
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.43	820	93.19
28	207.82	808	95.12
24	188.74	O-701	100.02
I-FRPRS	188.36	804	101.10
I-CRPRV	187.85	816	102.91

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

VELOCITIES

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	13.90	45	0.27
865	9.40	109	0.28
700	8.90	121	0.28
135	8.58	105	0.33
131	8.20	861	0.87

REGULATING VALVE REPORT

VALVE LABEL	VALVE TYPE	VALVE SETTING (psi or gpm)	VALVE STATUS	UPSTREAM PRESSURE (psi)	DOWNSTREAM PRESSURE (psi)	THROUGH FLOW (gpm)
CRPRV	PRV-1	124.00	CLOSED	187.85	124.03	0.00
FRPRS	PRV-1	125.00	ACTIVATED	188.36	125.00	1544.34
OPRS	PRV-1	147.00	ACTIVATED	210.43	147.00	3919.38

SUMMARY OF INFLOWS AND OUTFLOWS

- (+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
- (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE (gpm)	NODE TITLE
0	5463.72	

NET SYSTEM INFLOW = 5463.72
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 5463.72

=====
Case: 2

CHANGES FOR NEXT SIMULATION (Change Number = 2)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 15 TRIALS: ACCURACY = 0.21172E-06

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

**SDSU Mission Valley Project
Phase 1 Water System Analysis
Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 788 and 798**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	N O D E N U M B E R S		F L O W R A T E gpm	H E A D ft	M I N O R L O S S ft	L I N E V E L O . ft/s	H L + M L / 1000 ft/f	H L / 1000 ft/f
	#1	#2						
21	0	I-CRPRV	0.00	0.00	0.00	0.00	0.00	0.00
41	24	I-FRPRS	1431.25	0.08	0.00	2.28	1.41	1.41
45	28	24	1431.25	0.03	0.00	0.25	0.01	0.01
49	28	I-OPRS	3808.91	0.17	0.00	6.08	8.62	8.62
53	0	28	5240.16	0.38	0.00	0.93	0.07	0.07
101	O-CRPRV	104	0.00	0.00	0.00	0.00	0.00	0.00
105	104	108	-115.00	0.03	0.00	0.33	0.05	0.05
109	108	112	-172.50	0.03	0.00	0.28	0.03	0.03
121	116	112	172.50	0.03	0.00	0.28	0.03	0.03
125	120	116	1436.26	0.09	0.00	2.29	1.42	1.42
127	120	O-OPRS	-3808.91	0.13	0.00	6.08	8.62	8.62
129	124	120	-2372.65	0.61	0.00	3.79	3.59	3.59
131	116	I-704	1263.76	1.54	0.00	8.07	32.69	32.69
133	124	126	2372.65	3.44	0.00	3.79	3.59	3.59
135	126	I-702	1342.23	1.87	0.00	8.57	36.54	36.54
137	126	128	1030.42	0.41	0.00	1.64	0.77	0.77
139	128	130	547.42	2.29	0.00	1.55	0.96	0.96
141	130	I-700	1978.67	13.79	0.00	12.63	74.98	74.98
143	130	132	-1431.25	7.07	0.00	4.06	5.71	5.71
145	132	O-FRPRS	-1431.25	0.03	0.00	2.28	1.41	1.41
700	O-700	I-701	1978.67	1.24	0.00	8.08	25.29	25.29
701	O-701	804	1978.67	1.26	0.00	5.61	10.41	10.41
702	O-702	I-703	1342.23	0.49	0.00	5.48	12.33	12.33
703	O-703	708	1342.23	0.46	0.00	3.81	5.07	5.07
704	O-704	I-705	1263.76	0.50	0.00	5.16	11.03	11.03
705	O-705	714	1263.76	1.59	0.00	3.58	4.54	4.54
709	710	708	1263.76	0.19	0.00	3.58	4.54	4.54
713	710	712	-1263.76	1.44	0.00	3.58	4.54	4.54
715	712	714	-1263.76	1.81	0.00	3.58	4.54	4.54
773	708	728	2605.99	12.59	0.00	7.39	17.33	17.33
777	772	728	-2605.99	5.48	0.00	7.39	17.33	17.33
785	780	772	-2605.99	4.48	0.00	7.39	17.33	17.33
833	788	798	814.34	4.15	0.00	5.20	14.48	14.48
837	784	788	2814.34	9.35	0.00	7.98	19.99	19.99
841	780	784	3399.00	13.25	0.00	9.64	28.35	28.35
845	800	780	793.00	0.52	0.00	2.25	1.91	1.91
853	804	800	793.00	1.50	0.00	2.25	1.91	1.91
857	812	798	1185.66	23.15	0.00	7.57	29.04	29.04
861	808	812	594.02	3.56	0.00	3.79	8.08	8.08
865	808	804	-1185.66	2.06	0.00	3.36	4.03	4.03
869	820	808	-591.65	0.47	0.00	1.68	1.11	1.11
873	816	820	-591.65	0.50	0.00	1.68	1.11	1.11
877	816	812	591.65	2.59	0.00	3.78	8.02	8.02

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1978.67	280.37	270.70	-9.7
701	1978.67	269.46	237.22	-32.2
702	1342.23	313.99	307.70	-6.3
703	1342.23	307.21	275.95	-31.3
704	1263.76	329.27	323.25	-6.0
705	1263.76	322.75	291.52	-31.2

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.60	100.00	435.60	188.76
28		0.00	535.62	56.00	479.62	207.84
104		115.00 (2.30)	388.73	117.00	271.73	117.75
108		57.50 (2.30)	388.76	87.00	301.76	130.76
112		0.00	388.78	54.00	334.78	145.07
116		0.00	388.81	54.00	334.81	145.09
120		0.00	388.90	50.00	338.90	146.86
124		0.00	388.29	58.00	330.29	143.13
126		0.00	384.86	69.00	315.86	136.87
128		483.00 (2.30)	384.45	70.00	314.45	136.26
130		0.00	382.16	95.00	287.16	124.44
132		0.00	389.23	100.00	289.23	125.33
O-700		0.00	358.70	88.00	270.70	117.30
O-701		0.00	325.22	88.00	237.22	102.80
I-702		0.00	382.99	69.00	313.99	136.06
I-703		0.00	376.21	69.00	307.21	133.12
I-704		0.00	387.27	58.00	329.27	142.68
I-705		0.00	380.75	58.00	322.75	139.86
708		0.00	344.49	75.00	269.49	116.78
710		0.00	344.68	75.00	269.68	116.86
712		0.00	346.12	75.00	271.12	117.48
714		0.00	347.93	71.00	276.93	120.00
728		0.00	331.90	71.00	260.90	113.06
772		0.00	326.42	71.00	255.42	110.68
780		0.00	321.94	77.00	244.94	106.14
784		584.66 (2.30)	308.70	74.00	234.70	101.70
788		2000.00	299.34	71.00	228.34	98.95
798		2000.00 (**)	295.20	68.00	227.20	98.45
800		0.00	322.46	82.00	240.46	104.20
804		0.00	323.96	84.00	239.96	103.98
808		0.00	321.91	84.00	237.91	103.09
812		0.00	318.35	58.00	260.35	112.82
816		0.00	320.94	64.00	256.94	111.34
820		0.00	321.44	86.00	235.44	102.02
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	389.26	100.80	288.46	125.00
I-OPRS		0.00	535.46	49.80	485.66	210.45

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

I-700	0.00	368.37	88.00	280.37	121.50
I-701	0.00	357.46	88.00	269.46	116.76
O-702	0.00	376.70	69.00	307.70	133.34
O-703	0.00	344.95	69.00	275.95	119.58
O-704	0.00	381.25	58.00	323.25	140.07
O-705	0.00	349.52	58.00	291.52	126.33
O-CRPRV	----	388.73	102.50	286.23	124.03
I-FRPRS	0.00	535.52	100.80	434.72	188.38
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.45	798	98.45
28	207.84	788	98.95
24	188.76	784	101.70
I-FRPRS	188.38	820	102.02
I-CRPRV	187.85	O-701	102.80

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	12.63	45	0.25
841	9.64	109	0.28
135	8.57	121	0.28
700	8.08	105	0.33
131	8.07	53	0.93

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	CLOSED	187.85	124.03	0.00
FRPRS	PRV-1	125.00	ACTIVATED	188.38	125.00	1431.25
OPRS	PRV-1	147.00	ACTIVATED	210.45	147.00	3808.91

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
(-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	5240.16	

NET SYSTEM INFLOW = 5240.16
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 5240.16

=====
Case: 3

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 3)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

RESULTS OBTAINED AFTER 12 TRIALS: ACCURACY = 0.52366E-04

**SDSU Mission Valley Project
Phase 1 Water System Analysis
Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 728 and 772**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE NUMBERS #1 #2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0 I-CRPRV	0.00	0.00	0.00	0.00	0.00	0.00
41	24 I-FRPRS	1356.67	0.07	0.00	2.16	1.27	1.27
45	28 24	1356.67	0.02	0.00	0.24	0.01	0.01
49	28 I-OPRS	4107.05	0.19	0.00	6.55	9.92	9.92
53	0 28	5463.72	0.41	0.00	0.97	0.08	0.08
101	O-CRPRV 104	0.00	0.00	0.00	0.00	0.00	0.00
105	104 108	-115.00	0.03	0.00	0.33	0.05	0.05
109	108 112	-172.50	0.03	0.00	0.28	0.03	0.03
121	116 112	172.50	0.03	0.00	0.28	0.03	0.03
125	120 116	1617.10	0.11	0.00	2.58	1.76	1.76
127	120 O-OPRS	-4107.05	0.15	0.00	6.55	9.92	9.92
129	124 120	-2489.94	0.67	0.00	3.97	3.92	3.92
131	116 I-704	1444.60	1.98	0.00	9.22	41.87	41.87
133	124 126	2489.94	3.76	0.00	3.97	3.92	3.92
135	126 I-702	1600.58	2.59	0.00	10.22	50.63	50.63
137	126 128	889.37	0.31	0.00	1.42	0.58	0.58
139	128 130	406.37	1.32	0.00	1.15	0.55	0.55
141	130 I-700	1763.04	11.14	0.00	11.25	60.56	60.56
143	130 132	-1356.67	6.40	0.00	3.85	5.17	5.17
145	132 O-FRPRS	-1356.67	0.03	0.00	2.16	1.27	1.27

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

700	O-700	I-701	1763.04	1.00	0.00	7.20	20.43	20.43
701	O-701	804	1763.04	1.02	0.00	5.00	8.41	8.41
702	O-702	I-703	1600.58	0.68	0.00	6.54	17.08	17.08
703	O-703	708	1600.58	0.64	0.00	4.54	7.03	7.03
704	O-704	I-705	1444.60	0.64	0.00	5.90	14.12	14.12
705	O-705	714	1444.60	2.04	0.00	4.10	5.81	5.81
709	710	708	1444.60	0.24	0.00	4.10	5.81	5.81
713	710	712	-1444.60	1.84	0.00	4.10	5.81	5.81
715	712	714	-1444.60	2.32	0.00	4.10	5.81	5.81
773	708	728	3045.18	16.80	0.00	8.64	23.13	23.13
777	772	728	-1045.18	1.01	0.00	2.96	3.19	3.19
785	780	772	954.82	0.70	0.00	2.71	2.70	2.70
833	788	798	-229.10	0.40	0.00	1.46	1.38	1.38
837	784	788	-229.10	0.09	0.00	0.65	0.19	0.19
841	780	784	355.56	0.20	0.00	1.01	0.43	0.43
845	800	780	1310.38	1.32	0.00	3.72	4.85	4.85
853	804	800	1310.38	3.79	0.00	3.72	4.85	4.85
857	812	798	452.66	3.89	0.00	2.89	4.88	4.88
861	808	812	226.78	0.60	0.00	1.45	1.36	1.36
865	808	804	-452.66	0.35	0.00	1.28	0.68	0.68
869	820	808	-225.88	0.08	0.00	0.64	0.19	0.19
873	816	820	-225.88	0.08	0.00	0.64	0.19	0.19
877	816	812	225.88	0.44	0.00	1.44	1.35	1.35

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1763.04	283.70	275.43	-8.3
701	1763.04	274.43	242.73	-31.7
702	1600.58	312.87	305.48	-7.4
703	1600.58	304.80	273.34	-31.5
704	1444.60	328.79	322.11	-6.7
705	1444.60	321.47	290.15	-31.3

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.57	100.00	435.57	188.75
28		0.00	535.59	56.00	479.59	207.82
104		115.00 (2.30)	388.69	117.00	271.69	117.73
108		57.50 (2.30)	388.72	87.00	301.72	130.74
112		0.00	388.74	54.00	334.74	145.05
116		0.00	388.77	54.00	334.77	145.07
120		0.00	388.88	50.00	338.88	146.85
124		0.00	388.22	58.00	330.22	143.09
126		0.00	384.46	69.00	315.46	136.70
128		483.00 (2.30)	384.15	70.00	314.15	136.13
130		0.00	382.83	95.00	287.83	124.73
132		0.00	389.23	100.00	289.23	125.33

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

O-700	0.00	363.43	88.00	275.43	119.35
O-701	0.00	330.73	88.00	242.73	105.18
I-702	0.00	381.87	69.00	312.87	135.58
I-703	0.00	373.80	69.00	304.80	132.08
I-704	0.00	386.79	58.00	328.79	142.48
I-705	0.00	379.47	58.00	321.47	139.30
708	0.00	341.70	75.00	266.70	115.57
710	0.00	341.94	75.00	266.94	115.68
712	0.00	343.79	75.00	268.79	116.48
714	0.00	346.11	71.00	275.11	119.22
728	2000.00	324.90	71.00	253.90	110.02
772	2000.00	323.89	71.00	252.89	109.59
780	0.00	324.59	77.00	247.59	107.29
784	584.66 (2.30)	324.39	74.00	250.39	108.50
788	0.00	324.48	71.00	253.48	109.84
798	223.56 (2.30)	324.87	68.00	256.87	111.31
800	0.00	325.91	82.00	243.91	105.70
804	0.00	329.71	84.00	245.71	106.47
808	0.00	329.36	84.00	245.36	106.32
812	0.00	328.77	58.00	270.77	117.33
816	0.00	329.20	64.00	265.20	114.92
820	0.00	329.28	86.00	243.28	105.42
0	----	536.00			
I-CRPRV	0.00	536.00	102.50	433.50	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.40	49.80	485.60	210.43
I-700	0.00	371.70	88.00	283.70	122.94
I-701	0.00	362.43	88.00	274.43	118.92
O-702	0.00	374.48	69.00	305.48	132.37
O-703	0.00	342.34	69.00	273.34	118.45
O-704	0.00	380.11	58.00	322.11	139.58
O-705	0.00	348.15	58.00	290.15	125.73
O-CRPRV	----	388.69	102.50	286.19	124.01
I-FRPRS	0.00	535.50	100.80	434.70	188.37
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.43	O-701	105.18
28	207.82	820	105.42
24	188.75	800	105.70
I-FRPRS	188.37	808	106.32
I-CRPRV	187.85	804	106.47

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	11.25	45	0.24
135	10.22	109	0.28
131	9.22	121	0.28
773	8.64	105	0.33
700	7.20	869	0.64

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	CLOSED	187.85	124.01	0.00
FRPRS	PRV-1	125.00	ACTIVATED	188.37	125.00	1356.67
OPRS	PRV-1	147.00	ACTIVATED	210.43	147.00	4107.05

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

- (+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
- (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	5463.72	

NET SYSTEM INFLOW = 5463.72
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 5463.72

=====
Case: 4

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 4)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 143 is CLOSED

RESULTS OBTAINED AFTER 9 TRIALS: ACCURACY = 0.54088E-04

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

**SDSU Mission Valley Project
Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 808 and 820
Pipe 143 Out of Service**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	N O D E N U M B E R S		F L O W R A T E gpm	H E A D LOSS ft	M I N O R L O S S ft	L I N E V E L O . ft/s	H L + M L / 1000 ft/f	H L / 1000 ft/f
	#1	#2						
21	0	I-CRPRV	47.40	0.00	0.00	0.01	0.00	0.00
41	24	I-FRPRS	0.00	0.00	0.00	0.00	0.00	0.00
45	28	24	0.00	0.00	0.00	0.00	0.00	0.00
49	28	I-OPRS	5416.32	0.32	0.00	8.64	16.55	16.55
53	0	28	5416.32	0.40	0.00	0.96	0.08	0.08
101	O-CRPRV	104	47.40	0.04	0.00	0.13	0.01	0.01
105	104	108	-67.60	0.01	0.00	0.19	0.02	0.02
109	108	112	-125.10	0.01	0.00	0.20	0.02	0.02
121	116	112	125.10	0.02	0.00	0.20	0.02	0.02
125	120	116	1729.59	0.13	0.00	2.76	2.00	2.00
127	120	O-OPRS	-5416.32	0.24	0.00	8.64	16.55	16.55
129	124	120	-3686.74	1.38	0.00	5.88	8.12	8.12
131	116	I-704	1604.48	2.40	0.00	10.24	50.86	50.86
133	124	126	3686.74	7.78	0.00	5.88	8.12	8.12
135	126	I-702	1401.70	2.02	0.00	8.95	39.60	39.60
137	126	128	2285.03	1.78	0.00	3.65	3.35	3.35
139	128	130	1802.03	20.78	0.00	5.11	8.75	8.75
141	130	I-700	1802.03	11.60	0.00	11.50	63.06	63.06
143-XX	130	132						
145	132	O-FRPRS	0.00	0.00	0.00	0.00	0.00	0.00
700	O-700	I-701	1802.03	1.04	0.00	7.36	21.27	21.27
701	O-701	804	1802.03	1.06	0.00	5.11	8.75	8.75
702	O-702	I-703	1401.70	0.53	0.00	5.73	13.36	13.36
703	O-703	708	1401.70	0.50	0.00	3.98	5.50	5.50
704	O-704	I-705	1604.48	0.78	0.00	6.55	17.16	17.16
705	O-705	714	1604.48	2.47	0.00	4.55	7.06	7.06
709	710	708	1604.48	0.29	0.00	4.55	7.06	7.06
713	710	712	-1604.48	2.24	0.00	4.55	7.06	7.06
715	712	714	-1604.48	2.82	0.00	4.55	7.06	7.06
773	708	728	3006.19	16.40	0.00	8.53	22.58	22.58
777	772	728	-3006.19	7.13	0.00	8.53	22.58	22.58
785	780	772	-3006.19	5.84	0.00	8.53	22.58	22.58
833	788	798	955.66	5.58	0.00	6.10	19.48	19.48
837	784	788	955.66	1.27	0.00	2.71	2.70	2.70
841	780	784	1540.32	3.06	0.00	4.37	6.55	6.55
845	800	780	-1465.87	1.63	0.00	4.16	5.97	5.97
853	804	800	-1465.87	4.67	0.00	4.16	5.97	5.97
857	812	798	-732.10	9.48	0.00	4.67	11.89	11.89
861	808	812	-172.41	0.36	0.00	1.10	0.82	0.82
865	808	804	-3267.90	13.44	0.00	9.27	26.36	26.36
869	820	808	-1440.31	2.43	0.00	4.09	5.78	5.78
873	816	820	559.69	0.45	0.00	1.59	1.00	1.00
877	816	812	-559.69	2.34	0.00	3.57	7.23	7.23

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	1802.03	257.48	248.98	-8.5
701	1802.03	247.94	216.16	-31.8
702	1401.70	308.61	302.10	-6.5
703	1401.70	301.56	270.27	-31.3
704	1604.48	328.26	320.85	-7.4
705	1604.48	320.07	288.60	-31.5

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.60	100.00	435.60	188.76
28		0.00	535.60	56.00	479.60	207.83
104		115.00 (2.30)	388.62	117.00	271.62	117.70
108		57.50 (2.30)	388.63	87.00	301.63	130.71
112		0.00	388.64	54.00	334.64	145.01
116		0.00	388.66	54.00	334.66	145.02
120		0.00	388.79	50.00	338.79	146.81
124		0.00	387.41	58.00	329.41	142.74
126		0.00	379.63	69.00	310.63	134.61
128		483.00 (2.30)	377.86	70.00	307.86	133.40
130		0.00	357.08	95.00	262.08	113.57
132		0.00	535.60	100.00	435.60	188.76
O-700		0.00	336.98	88.00	248.98	107.89
O-701		0.00	304.16	88.00	216.16	93.67
I-702		0.00	377.61	69.00	308.61	133.73
I-703		0.00	370.56	69.00	301.56	130.68
I-704		0.00	386.26	58.00	328.26	142.24
I-705		0.00	378.07	58.00	320.07	138.70
708		0.00	338.77	75.00	263.77	114.30
710		0.00	339.07	75.00	264.07	114.43
712		0.00	341.31	75.00	266.31	115.40
714		0.00	344.13	71.00	273.13	118.36
728		0.00	322.37	71.00	251.37	108.93
772		0.00	315.24	71.00	244.24	105.84
780		0.00	309.40	77.00	232.40	100.71
784		584.66 (2.30)	306.34	74.00	232.34	100.68
788		0.00	305.08	71.00	234.08	101.43
798		223.56 (2.30)	299.50	68.00	231.50	100.32
800		0.00	307.77	82.00	225.77	97.83
804		0.00	303.10	84.00	219.10	94.94
808		2000.00	289.66	84.00	205.66	89.12
812		0.00	290.02	58.00	232.02	100.54
816		0.00	287.69	64.00	223.69	96.93
820		2000.00	287.23	86.00	201.23	87.20
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	535.60	100.80	434.80	188.41
I-OPRS		0.00	535.28	49.80	485.48	210.38

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

I-700	0.00	345.48	88.00	257.48	111.58
I-701	0.00	335.94	88.00	247.94	107.44
O-702	0.00	371.10	69.00	302.10	130.91
O-703	0.00	339.27	69.00	270.27	117.12
O-704	0.00	378.85	58.00	320.85	139.03
O-705	0.00	346.60	58.00	288.60	125.06
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.60	100.80	434.80	188.41
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.38	820	87.20
28	207.83	808	89.12
24	188.76	O-701	93.67
132	188.76	804	94.94
O-FRPRS	188.41	816	96.93

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	11.50	21	0.01
131	10.24	101	0.13
865	9.27	105	0.19
135	8.95	109	0.20
49	8.64	121	0.20

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	47.40
FRPRS	PRV-1	125.00	WIDE OPEN	188.41	188.41	0.00
OPRS	PRV-1	147.00	ACTIVATED	210.38	147.00	5416.32

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

(+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
(-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	5463.72	

NET SYSTEM INFLOW = 5463.72
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 5463.72

=====
Case: 5

C H A N G E S F O R N E X T S I M U L A T I O N (Change Number = 5)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 125 is CLOSED
Pipe 143 is OPENED

RESULTS OBTAINED AFTER 13 TRIALS: ACCURACY = 0.83475E-06

**SDSU Mission Valley Project
Maximum Day Demand plus 4,000 GPM Fire Flow split between Nodes 788 and 798
Pipe 125 Out of Service**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	NODE #1	NODE #2	FLOWRATE gpm	HEAD LOSS ft	MINOR LOSS ft	LINE VELO. ft/s	HL+ML/ 1000 ft/f	HL/ 1000 ft/f
21	0	I-CRPRV	875.53	0.01	0.00	0.28	0.01	0.01
41	24	I-FRPRS	1559.24	0.09	0.00	2.49	1.65	1.65
45	28	24	1559.24	0.03	0.00	0.28	0.01	0.01
49	28	I-OPRS	2805.39	0.09	0.00	4.48	4.89	4.89
53	0	28	4364.63	0.27	0.00	0.77	0.05	0.05
101	O-CRPRV	104	875.53	8.16	0.00	2.48	2.30	2.30
105	104	108	760.53	0.95	0.00	2.16	1.77	1.77
109	108	112	703.03	0.34	0.00	1.12	0.38	0.38
121	116	112	-703.03	0.40	0.00	1.12	0.38	0.38
125-XX	120	116						
127	120	O-OPRS	-2805.39	0.07	0.00	4.48	4.89	4.89
129	124	120	-2805.39	0.83	0.00	4.48	4.89	4.89
131	116	I-704	703.03	0.52	0.00	4.49	11.03	11.03
133	124	126	2805.39	4.69	0.00	4.48	4.89	4.89
135	126	I-702	1798.58	3.21	0.00	11.48	62.84	62.84
137	126	128	1006.80	0.39	0.00	1.61	0.73	0.73
139	128	130	523.80	2.11	0.00	1.49	0.89	0.89
141	130	I-700	2083.04	15.17	0.00	13.29	82.47	82.47

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

143	130	132	-1559.24	8.28	0.00	4.42	6.70	6.70
145	132	O-FRPRS	-1559.24	0.04	0.00	2.49	1.65	1.65
700	O-700	I-701	2083.04	1.36	0.00	8.51	27.82	27.82
701	O-701	804	2083.04	1.38	0.00	5.91	11.45	11.45
702	O-702	I-703	1798.58	0.84	0.00	7.35	21.20	21.20
703	O-703	708	1798.58	0.79	0.00	5.10	8.72	8.72
704	O-704	I-705	703.03	0.17	0.00	2.87	3.72	3.72
705	O-705	714	703.03	0.54	0.00	1.99	1.53	1.53
709	710	708	703.03	0.06	0.00	1.99	1.53	1.53
713	710	712	-703.03	0.49	0.00	1.99	1.53	1.53
715	712	714	-703.03	0.61	0.00	1.99	1.53	1.53
773	708	728	2501.62	11.67	0.00	7.10	16.07	16.07
777	772	728	-2501.62	5.08	0.00	7.10	16.07	16.07
785	780	772	-2501.62	4.15	0.00	7.10	16.07	16.07
833	788	798	807.22	4.08	0.00	5.15	14.25	14.25
837	784	788	2807.22	9.31	0.00	7.96	19.89	19.89
841	780	784	3391.88	13.19	0.00	9.62	28.24	28.24
845	800	780	890.26	0.65	0.00	2.53	2.37	2.37
853	804	800	890.26	1.85	0.00	2.53	2.37	2.37
857	812	798	1192.78	23.41	0.00	7.61	29.37	29.37
861	808	812	597.58	3.60	0.00	3.81	8.17	8.17
865	808	804	-1192.78	2.08	0.00	3.38	4.08	4.08
869	820	808	-595.20	0.47	0.00	1.69	1.13	1.13
873	816	820	-595.20	0.51	0.00	1.69	1.13	1.13
877	816	812	595.20	2.62	0.00	3.80	8.10	8.10

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	2083.04	277.78	267.31	-10.5
701	2083.04	265.95	233.33	-32.6
702	1798.58	311.23	302.75	-8.5
703	1798.58	301.90	270.13	-31.8
704	703.03	320.28	314.10	-6.2
705	703.03	313.93	282.04	-31.9

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.70	100.00	435.70	188.80
28		0.00	535.73	56.00	479.73	207.88
104		115.00 (2.30)	380.49	117.00	263.49	114.18
108		57.50 (2.30)	379.54	87.00	292.54	126.77
112		0.00	379.20	54.00	325.20	140.92
116		0.00	378.80	54.00	324.80	140.75
120		0.00	388.96	50.00	338.96	146.88
124		0.00	388.13	58.00	330.13	143.06
126		0.00	383.44	69.00	314.44	136.26
128		483.00 (2.30)	383.05	70.00	313.05	135.66

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

130	0.00	380.94	95.00	285.94	123.91
132	0.00	389.23	100.00	289.23	125.33
O-700	0.00	355.31	88.00	267.31	115.83
O-701	0.00	321.33	88.00	233.33	101.11
I-702	0.00	380.23	69.00	311.23	134.87
I-703	0.00	370.90	69.00	301.90	130.82
I-704	0.00	378.28	58.00	320.28	138.79
I-705	0.00	371.93	58.00	313.93	136.04
708	0.00	338.34	75.00	263.34	114.12
710	0.00	338.41	75.00	263.41	114.14
712	0.00	338.89	75.00	263.89	114.35
714	0.00	339.51	71.00	268.51	116.35
728	0.00	326.67	71.00	255.67	110.79
772	0.00	321.59	71.00	250.59	108.59
780	0.00	317.44	77.00	240.44	104.19
784	584.66 (2.30)	304.25	74.00	230.25	99.77
788	2000.00	294.94	71.00	223.94	97.04
798	2000.00 (**)	290.86	68.00	222.86	96.57
800	0.00	318.09	82.00	236.09	102.30
804	0.00	319.94	84.00	235.94	102.24
808	0.00	317.86	84.00	233.86	101.34
812	0.00	314.27	58.00	256.27	111.05
816	0.00	316.89	64.00	252.89	109.58
820	0.00	317.39	86.00	231.39	100.27
0	----	536.00			
I-CRPRV	0.00	535.99	102.50	433.49	187.85
O-FRPRS	----	389.26	100.80	288.46	125.00
I-OPRS	0.00	535.64	49.80	485.84	210.53
I-700	0.00	365.78	88.00	277.78	120.37
I-701	0.00	353.95	88.00	265.95	115.24
O-702	0.00	371.75	69.00	302.75	131.19
O-703	0.00	339.13	69.00	270.13	117.06
O-704	0.00	372.10	58.00	314.10	136.11
O-705	0.00	340.04	58.00	282.04	122.22
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.61	100.80	434.81	188.42
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.53	798	96.57
28	207.88	788	97.04
24	188.80	784	99.77
I-FRPRS	188.42	820	100.27
I-CRPRV	187.85	O-701	101.11

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

VELOCITIES

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	13.29	21	0.28
135	11.48	45	0.28
841	9.62	53	0.77
700	8.51	109	1.12
837	7.96	121	1.12

REGULATING VALVE REPORT

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	875.53
FRPRS	PRV-1	125.00	ACTIVATED	188.42	125.00	1559.24
OPRS	PRV-1	147.00	ACTIVATED	210.53	147.00	2805.39

SUMMARY OF INFLOWS AND OUTFLOWS

- (+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
- (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	5240.16	

NET SYSTEM INFLOW = 5240.16
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 5240.16

=====
Case: 6

CHANGES FOR NEXT SIMULATION (Change Number = 6)

JUNCTION DEMANDS CHANGED - PLEASE SEE RESULTS TABLE

Pipe 125 is OPENED

RESULTS OBTAINED AFTER 11 TRIALS: ACCURACY = 0.40068E-05

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

**SDSU Mission Valley Project
Phase 1 Water System Analysis
Peak Hour Demand**

P I P E L I N E R E S U L T S

STATUS CODE: XX -CLOSED PIPE CV -CHECK VALVE

P I P E N A M E	N O D E N U M B E R S		F L O W R A T E gpm	H E A D LOSS ft	M I N O R LOSS ft	L I N E V E L O . ft/s	H L + M L / 1000 ft/f	H L / 1000 ft/f
	#1	#2						
21	0	I-CRPRV	42.99	0.00	0.00	0.01	0.00	0.00
41	24	I-FRPRS	823.58	0.03	0.00	1.31	0.51	0.51
45	28	24	823.58	0.01	0.00	0.15	0.00	0.00
49	28	I-OPRS	2506.35	0.08	0.00	4.00	3.97	3.97
53	0	28	3329.93	0.16	0.00	0.59	0.03	0.03
101	O-CRPRV	104	42.99	0.03	0.00	0.12	0.01	0.01
105	104	108	-222.01	0.10	0.00	0.63	0.18	0.18
109	108	112	-354.51	0.10	0.00	0.57	0.11	0.11
121	116	112	354.51	0.11	0.00	0.57	0.11	0.11
125	120	116	962.19	0.04	0.00	1.54	0.67	0.67
127	120	O-OPRS	-2506.35	0.06	0.00	4.00	3.97	3.97
129	124	120	-1544.16	0.27	0.00	2.46	1.62	1.62
131	116	I-704	607.68	0.40	0.00	3.88	8.42	8.42
133	124	126	1544.16	1.55	0.00	2.46	1.62	1.62
135	126	I-702	461.60	0.26	0.00	2.95	5.06	5.06
137	126	128	1082.56	0.45	0.00	1.73	0.84	0.84
139	128	130	-30.44	0.01	0.00	0.09	0.00	0.00
141	130	I-700	793.14	2.54	0.00	5.06	13.79	13.79
143	130	132	-823.58	2.54	0.00	2.34	2.05	2.05
145	132	O-FRPRS	-823.58	0.01	0.00	1.31	0.51	0.51
700	O-700	I-701	793.14	0.23	0.00	3.24	4.65	4.65
701	O-701	804	793.14	0.23	0.00	2.25	1.91	1.91
702	O-702	I-703	461.60	0.07	0.00	1.89	1.71	1.71
703	O-703	708	461.60	0.06	0.00	1.31	0.70	0.70
704	O-704	I-705	607.68	0.13	0.00	2.48	2.84	2.84
705	O-705	714	607.68	0.41	0.00	1.72	1.17	1.17
709	710	708	607.68	0.05	0.00	1.72	1.17	1.17
713	710	712	-607.68	0.37	0.00	1.72	1.17	1.17
715	712	714	-607.68	0.47	0.00	1.72	1.17	1.17
773	708	728	1069.28	2.42	0.00	3.03	3.33	3.33
777	772	728	-1069.28	1.05	0.00	3.03	3.33	3.33
785	780	772	-1069.28	0.86	0.00	3.03	3.33	3.33
833	788	798	129.79	0.14	0.00	0.83	0.48	0.48
837	784	788	129.79	0.03	0.00	0.37	0.07	0.07
841	780	784	1477.05	2.83	0.00	4.19	6.06	6.06
845	800	780	407.77	0.15	0.00	1.16	0.56	0.56
853	804	800	407.77	0.44	0.00	1.16	0.56	0.56
857	812	798	385.37	2.89	0.00	2.46	3.62	3.62
861	808	812	193.07	0.44	0.00	1.23	1.01	1.01
865	808	804	-385.37	0.26	0.00	1.09	0.50	0.50
869	820	808	-192.30	0.06	0.00	0.55	0.14	0.14
873	816	820	-192.30	0.06	0.00	0.55	0.14	0.14
877	816	812	192.30	0.32	0.00	1.23	1.00	1.00

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

P U M P / L O S S E L E M E N T R E S U L T S

NAME	FLOWRATE gpm	INLET HEAD ft	OUTLET HEAD ft	PUMP HEAD ft
700	793.14	296.17	289.88	-6.3
701	793.14	289.65	257.72	-31.9
702	461.60	317.89	312.08	-5.8
703	461.60	312.02	280.29	-31.7
704	607.68	330.53	324.48	-6.0
705	607.68	324.36	292.53	-31.8

N O D E R E S U L T S

NODE NAME	NODE TITLE	EXTERNAL DEMAND gpm	HYDRAULIC GRADE ft	NODE ELEVATION ft	PRESSURE HEAD ft	NODE PRESSURE psi
24		0.00	535.83	100.00	435.83	188.86
28		0.00	535.84	56.00	479.84	207.93
104		265.00 (5.30)	388.62	117.00	271.62	117.70
108		132.50 (5.30)	388.72	87.00	301.72	130.75
112		0.00	388.82	54.00	334.82	145.09
116		0.00	388.93	54.00	334.93	145.14
120		0.00	388.97	50.00	338.97	146.89
124		0.00	388.70	58.00	330.70	143.30
126		0.00	387.15	69.00	318.15	137.86
128		1113.00 (5.30)	386.70	70.00	316.70	137.24
130		0.00	386.71	95.00	291.71	126.41
132		0.00	389.25	100.00	289.25	125.34
O-700		0.00	377.88	88.00	289.88	125.62
O-701		0.00	345.72	88.00	257.72	111.68
I-702		0.00	386.89	69.00	317.89	137.75
I-703		0.00	381.02	69.00	312.02	135.21
I-704		0.00	388.53	58.00	330.53	143.23
I-705		0.00	382.36	58.00	324.36	140.55
708		0.00	349.23	75.00	274.23	118.83
710		0.00	349.28	75.00	274.28	118.85
712		0.00	349.65	75.00	274.65	119.01
714		0.00	350.12	71.00	279.12	120.95
728		0.00	346.81	71.00	275.81	119.52
772		0.00	345.76	71.00	274.76	119.06
780		0.00	344.90	77.00	267.90	116.09
784		1347.26 (5.30)	342.07	74.00	268.07	116.16
788		0.00	342.04	71.00	271.04	117.45
798		515.16 (5.30)	341.90	68.00	273.90	118.69
800		0.00	345.05	82.00	263.05	113.99
804		0.00	345.49	84.00	261.49	113.31
808		0.00	345.23	84.00	261.23	113.20
812		0.00	344.79	58.00	286.79	124.27
816		0.00	345.11	64.00	281.11	121.81
820		0.00	345.17	86.00	259.17	112.31
0		----	536.00			
I-CRPRV		0.00	536.00	102.50	433.50	187.85
O-FRPRS		----	389.26	100.80	288.46	125.00
I-OPRS		0.00	535.76	49.80	485.96	210.58

**SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios**

**April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166**

I-700	0.00	384.17	88.00	296.17	128.34
I-701	0.00	377.65	88.00	289.65	125.52
O-702	0.00	381.08	69.00	312.08	135.24
O-703	0.00	349.29	69.00	280.29	121.46
O-704	0.00	382.48	58.00	324.48	140.61
O-705	0.00	350.53	58.00	292.53	126.76
O-CRPRV	----	388.65	102.50	286.15	124.00
I-FRPRS	0.00	535.80	100.80	435.00	188.50
O-OPRS	----	389.03	49.80	339.23	147.00

M A X I M U M A N D M I N I M U M V A L U E S

P R E S S U R E S

JUNCTION NUMBER	MAXIMUM PRESSURES psi	JUNCTION NUMBER	MINIMUM PRESSURES psi
I-OPRS	210.58	O-701	111.68
28	207.93	820	112.31
24	188.86	808	113.20
I-FRPRS	188.50	804	113.31
I-CRPRV	187.85	800	113.99

V E L O C I T I E S

PIPE NUMBER	MAXIMUM VELOCITY (ft/s)	PIPE NUMBER	MINIMUM VELOCITY (ft/s)
141	5.06	21	0.01
841	4.19	139	0.09
49	4.00	101	0.12
127	4.00	45	0.15
131	3.88	837	0.37

R E G U L A T I N G V A L V E R E P O R T

VALVE LABEL	VALVE TYPE	VALVE SETTING psi or gpm	VALVE STATUS	UPSTREAM PRESSURE psi	DOWNSTREAM PRESSURE psi	THROUGH FLOW gpm
CRPRV	PRV-1	124.00	ACTIVATED	187.85	124.00	42.99
FRPRS	PRV-1	125.00	ACTIVATED	188.50	125.00	823.58
OPRS	PRV-1	147.00	ACTIVATED	210.58	147.00	2506.35

SDSU Mission Valley Project
Phase 1 Water System Analysis (505166P6)
Average Day, Maximum Day plus Fire Flow, and
Peak Hour Demand Scenarios

April 18, 2019
Dexter Wilson Engr., Inc.
Job No. 505-166

S U M M A R Y O F I N F L O W S A N D O U T F L O W S

- (+) INFLOWS INTO THE SYSTEM FROM SUPPLY NODES
- (-) OUTFLOWS FROM THE SYSTEM INTO SUPPLY NODES

NODE NAME	FLOWRATE gpm	NODE TITLE
0	3372.92	

NET SYSTEM INFLOW = 3372.92
NET SYSTEM OUTFLOW = 0.00
NET SYSTEM DEMAND = 3372.92

APPENDIX I


**PHASE 1 WATER SYSTEM
DETAILED COMPUTER MODEL RESULTS SUMMARY
FOR PUBLIC SYSTEM CONNECTION POINTS**

SDSU MISSION VALLEY PHASE 1 WATER SYSTEM DETAILED COMPUTER MODEL RESULTS SUMMARY FOR PUBLIC SYSTEM				
Meter	Lateral Flow, gpm	Lateral Velocity, fps	Residual Pressure at Connection Point, psi	Pressure Drop at Connection Point, psi
Average Day Demand				
A	132.0	0.8	127.4	0.4
B	109.5	0.7	138.7	0.4
C	109.9	0.7	145.2	0.4
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820				
A	2178.4	13.9	124.0	3.8
B	1344.6	8.6	136.7	2.3
C	1285.2	8.2	145.1	0.5
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 788 and 798				
A	1978.7	12.6	124.4	3.4
B	1342.2	8.6	136.9	2.2
C	1263.8	8.1	145.1	0.5
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 728 and 772				
A	1763.0	11.3	124.7	3.1
B	1600.6	10.2	136.7	2.4
C	1444.6	9.2	145.1	0.5
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 808 and 820 with Pipe 143 closed				
A	1802.0	11.5	113.6	14.2
B	1401.7	9.0	134.6	4.5
C	1604.5	10.2	145.0	0.6
Maximum Day Demand plus 4,000 gpm Fire Flow split between Nodes 788 and 798 with Pipe 125 closed				
A	2083.0	13.3	123.9	3.9
B	1798.6	11.5	136.3	2.8
C	703.0	4.5	140.8	4.8
Peak Hour Demand				
A	793.1	5.1	126.4	1.4
B	461.6	3.0	137.9	1.2
C	607.7	3.9	145.1	0.4

LEGEND

- PROJECT BOUNDARY
- EXISTING 536 ZONE PIPELINE
- EXISTING 390 ZONE PIPELINE
- PROPOSED 536 ZONE PIPELINE
- PROPOSED 390 ZONE PIPELINE
- PROPOSED PRIVATE PIPELINE
- PRESSURE ZONE BOUNDARY
- (768) NODE PIPE COMPUTER MODEL NUMBER
- PIPE COMPUTER MODEL NUMBER
- EXISTING PRESSURE REDUCING STATION
- PROPOSED WATER METER
- PROPOSED BACKFLOW PREVENTER

0 250 FEET



\\ARTIC\DWG\505166\WATER\SSUL_EXHIBIT_A_NP.DWG 04-23-19 08:06:31 LAYOUT: LAYOUT

UNIVERSITY HEIGHTS 390
DEXTER WILSON ENGINEERING, INC.
 CONSULTING ENGINEERS
 2234 FARADAY AVENUE
 CARLSBAD, CA 92008
 (760) 438-4422


EXHIBIT A
 NODE AND PIPE DIAGRAM
 BUILD-OUT WATER SYSTEM
 SDSU MISSION VALLEY

LEGEND

- PROJECT BOUNDARY
- EXISTING 536 ZONE PIPELINE
- EXISTING 390 ZONE PIPELINE
- PROPOSED 536 ZONE PIPELINE
- PROPOSED 390 ZONE PIPELINE
- PROPOSED PRIVATE PIPELINE
- PRESSURE ZONE BOUNDARY
- NODE PIPE COMPUTER MODEL NUMBER
- PIPE COMPUTER MODEL NUMBER
- EXISTING PRESSURE REDUCING STATION
- PROPOSED WATER METER
- PROPOSED BACKFLOW PREVENTER

0 250
FEET

N



\\ARTIC\DWG\505166\WATER\SDSU_EXHIBIT_B_NP.DWG 04-23-19 08:47:09 LAYOUT: LAYOUT

DEXTER WILSON ENGINEERING, INC.
 CONSULTING ENGINEERS
 2234 FARADAY AVENUE
 CARLSBAD, CA 92008
 (760) 438-4422

EXHIBIT B
 NODE AND PIPE DIAGRAM
 PHASE 1 WATER SYSTEM
 SDSU MISSION VALLEY